

# TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

## ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Phoenix

4625 East Cotton Ctr Blvd

Suite 189

Phoenix, AZ 85040

Tel: (602)437-3340

TestAmerica Job ID: 550-80917-1

TestAmerica Sample Delivery Group: Gila Bend School

Client Project/Site: Pb in DW / Gila Bend Unified District

For:

Arizona Dept of Environmental Quality

1110 W. Washington St., MC5415B-1

Phoenix, Arizona 85007

Attn: David A Burchard



Authorized for release by:

4/24/2017 4:18:08 PM

Jannel Franklin, Project Manager I

(732)593-2551

[jannel.franklin@testamericainc.com](mailto:jannel.franklin@testamericainc.com)

Designee for

Susan Armijo, Project Manager II

(602)659-7664

[susan.armijo@testamericainc.com](mailto:susan.armijo@testamericainc.com)

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the items tested and the sample(s) as received by the laboratory.*

### LINKS

Review your project  
results through

TotalAccess

Have a Question?



Visit us at:

[www.testamericainc.com](http://www.testamericainc.com)

1

2

3

4

5

6

7

8

9

10

11

12

13

14



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Definitions/Glossary . . . . .	3
Case Narrative . . . . .	4
Sample Summary . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	9
QC Sample Results . . . . .	14
QC Association Summary . . . . .	16
Lab Chronicle . . . . .	18
Certification Summary . . . . .	24
Method Summary . . . . .	25
Chain of Custody . . . . .	26
Receipt Checklists . . . . .	56

## Definitions/Glossary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

### Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

# Case Narrative

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

**Job ID: 550-80917-1**

**Laboratory: TestAmerica Phoenix**

## Narrative

### Job Narrative 550-80917-1

#### Comments

No additional comments.

#### Receipt

The samples were received on 4/12/2017 12:00 PM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 22.1° C.

#### Receipt Exceptions

The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: GB1 (550-80917-1), GB2 (550-80917-2), GB3 (550-80917-3), GB4 (550-80917-4), GB5 (550-80917-5), GB6 (550-80917-6), GB7 (550-80917-7), GB8 (550-80917-8), GB9 (550-80917-9), GB10 (550-80917-10), GB11 (550-80917-11), GB12 (550-80917-12), GB13 (550-80917-13), GB14 (550-80917-14), GB15 (550-80917-15), GB16 (550-80917-16), GB17 (550-80917-17), GB18 (550-80917-18), GB19 (550-80917-19), GB20 (550-80917-20), GB21 (550-80917-21), GB22 (550-80917-22), GB23 (550-80917-23), GB24 (550-80917-24), GB25 (550-80917-25), GB26 (550-80917-26), GB27 (550-80917-27), GB28 (550-80917-28), GB29 (550-80917-29) and GB30 (550-80917-30). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

#### Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

# Sample Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-80917-1	GB1	Drinking Water	04/03/17 09:32	04/12/17 12:00
550-80917-2	GB2	Drinking Water	04/03/17 09:56	04/12/17 12:00
550-80917-3	GB3	Drinking Water	04/03/17 09:52	04/12/17 12:00
550-80917-4	GB4	Drinking Water	04/03/17 09:37	04/12/17 12:00
550-80917-5	GB5	Drinking Water	04/03/17 09:46	04/12/17 12:00
550-80917-6	GB6	Drinking Water	04/03/17 09:47	04/12/17 12:00
550-80917-7	GB7	Drinking Water	04/03/17 10:00	04/12/17 12:00
550-80917-8	GB8	Drinking Water	04/03/17 10:05	04/12/17 12:00
550-80917-9	GB9	Drinking Water	04/03/17 10:10	04/12/17 12:00
550-80917-10	GB10	Drinking Water	04/03/17 10:12	04/12/17 12:00
550-80917-11	GB11	Drinking Water	04/03/17 10:17	04/12/17 12:00
550-80917-12	GB12	Drinking Water	04/03/17 10:28	04/12/17 12:00
550-80917-13	GB13	Drinking Water	04/03/17 10:27	04/12/17 12:00
550-80917-14	GB14	Drinking Water	04/03/17 10:22	04/12/17 12:00
550-80917-15	GB15	Drinking Water	04/03/17 10:33	04/12/17 12:00
550-80917-16	GB16	Drinking Water	04/03/17 10:36	04/12/17 12:00
550-80917-17	GB17	Drinking Water	04/03/17 10:40	04/12/17 12:00
550-80917-18	GB18	Drinking Water	04/03/17 10:39	04/12/17 12:00
550-80917-19	GB19	Drinking Water	04/04/17 06:31	04/12/17 12:00
550-80917-20	GB20	Drinking Water	04/04/17 06:34	04/12/17 12:00
550-80917-21	GB21	Drinking Water	04/04/17 06:28	04/12/17 12:00
550-80917-22	GB22	Drinking Water	04/04/17 06:15	04/12/17 12:00
550-80917-23	GB23	Drinking Water	04/04/17 06:14	04/12/17 12:00
550-80917-24	GB24	Drinking Water	04/04/17 06:21	04/12/17 12:00
550-80917-25	GB25	Drinking Water	04/03/17 10:54	04/12/17 12:00
550-80917-26	GB26	Drinking Water	04/03/17 10:56	04/12/17 12:00
550-80917-27	GB27	Drinking Water	04/03/17 10:57	04/12/17 12:00
550-80917-28	GB28	Drinking Water	04/03/17 10:55	04/12/17 12:00
550-80917-29	GB29	Drinking Water	04/04/17 06:38	04/12/17 12:00
550-80917-30	GB30	Drinking Water	04/04/17 06:45	04/12/17 12:00

# Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB1

## Lab Sample ID: 550-80917-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.83		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB2

## Lab Sample ID: 550-80917-2

No Detections.

## Client Sample ID: GB3

## Lab Sample ID: 550-80917-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB4

## Lab Sample ID: 550-80917-4

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.54		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB5

## Lab Sample ID: 550-80917-5

No Detections.

## Client Sample ID: GB6

## Lab Sample ID: 550-80917-6

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.4		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB7

## Lab Sample ID: 550-80917-7

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB8

## Lab Sample ID: 550-80917-8

No Detections.

## Client Sample ID: GB9

## Lab Sample ID: 550-80917-9

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.3		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB10

## Lab Sample ID: 550-80917-10

No Detections.

## Client Sample ID: GB11

## Lab Sample ID: 550-80917-11

No Detections.

## Client Sample ID: GB12

## Lab Sample ID: 550-80917-12

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.5		0.50	ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

# Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB13

## Lab Sample ID: 550-80917-13

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.80		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB14

## Lab Sample ID: 550-80917-14

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	17		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB15

## Lab Sample ID: 550-80917-15

No Detections.

## Client Sample ID: GB16

## Lab Sample ID: 550-80917-16

No Detections.

## Client Sample ID: GB17

## Lab Sample ID: 550-80917-17

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	13		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB18

## Lab Sample ID: 550-80917-18

No Detections.

## Client Sample ID: GB19

## Lab Sample ID: 550-80917-19

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB20

## Lab Sample ID: 550-80917-20

No Detections.

## Client Sample ID: GB21

## Lab Sample ID: 550-80917-21

No Detections.

## Client Sample ID: GB22

## Lab Sample ID: 550-80917-22

No Detections.

## Client Sample ID: GB23

## Lab Sample ID: 550-80917-23

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.57		0.50	ppb	1		200.8	Total/NA

## Client Sample ID: GB24

## Lab Sample ID: 550-80917-24

No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

# Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

**Client Sample ID: GB25**

**Lab Sample ID: 550-80917-25**

No Detections.

**Client Sample ID: GB26**

**Lab Sample ID: 550-80917-26**

No Detections.

**Client Sample ID: GB27**

**Lab Sample ID: 550-80917-27**

No Detections.

**Client Sample ID: GB28**

**Lab Sample ID: 550-80917-28**

No Detections.

**Client Sample ID: GB29**

**Lab Sample ID: 550-80917-29**

No Detections.

**Client Sample ID: GB30**

**Lab Sample ID: 550-80917-30**

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.90		0.50	ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

**Client Sample ID: GB1**  
 Date Collected: 04/03/17 09:32  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-1**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.83		0.50	ppb		04/18/17 12:23	04/23/17 14:19	1

**Client Sample ID: GB2**  
 Date Collected: 04/03/17 09:56  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-2**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:23	04/23/17 14:21	1

**Client Sample ID: GB3**  
 Date Collected: 04/03/17 09:52  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-3**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		0.50	ppb		04/18/17 12:23	04/23/17 14:23	1

**Client Sample ID: GB4**  
 Date Collected: 04/03/17 09:37  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-4**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.54		0.50	ppb		04/18/17 12:23	04/23/17 14:25	1

**Client Sample ID: GB5**  
 Date Collected: 04/03/17 09:46  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-5**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:23	04/23/17 14:27	1

**Client Sample ID: GB6**  
 Date Collected: 04/03/17 09:47  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-6**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.4		0.50	ppb		04/18/17 12:23	04/23/17 14:29	1

**Client Sample ID: GB7**  
 Date Collected: 04/03/17 10:00  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-7**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50	ppb		04/18/17 12:23	04/23/17 14:31	1

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

**Client Sample ID: GB8**  
 Date Collected: 04/03/17 10:05  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-8**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:23	04/23/17 14:32	1

**Client Sample ID: GB9**  
 Date Collected: 04/03/17 10:10  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-9**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		0.50	ppb		04/18/17 12:23	04/23/17 14:34	1

**Client Sample ID: GB10**  
 Date Collected: 04/03/17 10:12  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-10**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 14:48	1

**Client Sample ID: GB11**  
 Date Collected: 04/03/17 10:17  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-11**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 14:53	1

**Client Sample ID: GB12**  
 Date Collected: 04/03/17 10:28  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-12**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		0.50	ppb		04/18/17 12:28	04/23/17 14:55	1

**Client Sample ID: GB13**  
 Date Collected: 04/03/17 10:27  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-13**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.80		0.50	ppb		04/18/17 12:28	04/23/17 14:57	1

**Client Sample ID: GB14**  
 Date Collected: 04/03/17 10:22  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-14**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	17		0.50	ppb		04/18/17 12:28	04/23/17 14:59	1

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

**Client Sample ID: GB15**  
 Date Collected: 04/03/17 10:33  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-15**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:01	1

**Client Sample ID: GB16**  
 Date Collected: 04/03/17 10:36  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-16**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:03	1

**Client Sample ID: GB17**  
 Date Collected: 04/03/17 10:40  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-17**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13		0.50	ppb		04/18/17 12:28	04/23/17 15:05	1

**Client Sample ID: GB18**  
 Date Collected: 04/03/17 10:39  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-18**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:07	1

**Client Sample ID: GB19**  
 Date Collected: 04/04/17 06:31  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-19**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50	ppb		04/18/17 12:28	04/23/17 15:09	1

**Client Sample ID: GB20**  
 Date Collected: 04/04/17 06:34  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-20**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:14	1

**Client Sample ID: GB21**  
 Date Collected: 04/04/17 06:28  
 Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-21**  
 Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:16	1

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

**Client Sample ID: GB22**  
Date Collected: 04/04/17 06:15  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-22**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:18	1

**Client Sample ID: GB23**  
Date Collected: 04/04/17 06:14  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-23**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.57		0.50	ppb		04/18/17 12:28	04/23/17 15:20	1

**Client Sample ID: GB24**  
Date Collected: 04/04/17 06:21  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-24**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:22	1

**Client Sample ID: GB25**  
Date Collected: 04/03/17 10:54  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-25**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:24	1

**Client Sample ID: GB26**  
Date Collected: 04/03/17 10:56  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-26**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:26	1

**Client Sample ID: GB27**  
Date Collected: 04/03/17 10:57  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-27**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:28	1

**Client Sample ID: GB28**  
Date Collected: 04/03/17 10:55  
Date Received: 04/12/17 12:00

**Lab Sample ID: 550-80917-28**  
Matrix: Drinking Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:30	1

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB29

Date Collected: 04/04/17 06:38

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-29

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 15:32	1

## Client Sample ID: GB30

Date Collected: 04/04/17 06:45

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-30

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.90		0.50	ppb		04/18/17 17:41	04/23/17 15:52	1

# QC Sample Results

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

## Method: 200.8 - Metals (ICP/MS)

**Lab Sample ID: MB 550-115161/1-A**  
**Matrix: Water**  
**Analysis Batch: 115535**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 115161**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:23	04/23/17 13:42	1

**Lab Sample ID: LCS 550-115161/3-A**  
**Matrix: Water**  
**Analysis Batch: 115535**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 115161**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Lead	100	99.4		ppb		99	85 - 115

**Lab Sample ID: LCSD 550-115161/4-A**  
**Matrix: Water**  
**Analysis Batch: 115535**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 115161**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	100	98.9		ppb		99	85 - 115	0	20

**Lab Sample ID: 550-80863-A-1-B MS**  
**Matrix: Water**  
**Analysis Batch: 115535**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 115161**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Lead	0.56		100	98.5		ppb		98	70 - 130

**Lab Sample ID: 550-80863-A-1-C MSD**  
**Matrix: Water**  
**Analysis Batch: 115535**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 115161**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	0.56		100	99.1		ppb		99	70 - 130	1	20

**Lab Sample ID: MB 550-115162/1-A**  
**Matrix: Water**  
**Analysis Batch: 115536**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 115162**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 12:28	04/23/17 14:40	1

**Lab Sample ID: LCS 550-115162/3-A**  
**Matrix: Water**  
**Analysis Batch: 115536**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 115162**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Lead	100	96.3		ppb		96	85 - 115

**Lab Sample ID: LCSD 550-115162/4-A**  
**Matrix: Water**  
**Analysis Batch: 115536**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 115162**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	100	98.4		ppb		98	85 - 115	2	20

TestAmerica Phoenix

# QC Sample Results

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

**Lab Sample ID: 550-80917-10 MS**  
**Matrix: Drinking Water**  
**Analysis Batch: 115536**

**Client Sample ID: GB10**  
**Prep Type: Total/NA**  
**Prep Batch: 115162**  
 %Rec.

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Lead	ND		100	94.9		ppb		95	70 - 130

**Lab Sample ID: 550-80917-10 MSD**  
**Matrix: Drinking Water**  
**Analysis Batch: 115536**

**Client Sample ID: GB10**  
**Prep Type: Total/NA**  
**Prep Batch: 115162**  
 %Rec.

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	ND		100	96.5		ppb		97	70 - 130	2	20

**Lab Sample ID: MB 550-115202/1-A**  
**Matrix: Water**  
**Analysis Batch: 115537**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 115202**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/18/17 17:41	04/23/17 15:37	1

**Lab Sample ID: LCS 550-115202/4-A**  
**Matrix: Water**  
**Analysis Batch: 115537**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 115202**  
 %Rec.

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Lead	100	98.1		ppb		98	85 - 115

**Lab Sample ID: LCSD 550-115202/5-A**  
**Matrix: Water**  
**Analysis Batch: 115537**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 115202**  
 %Rec.

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	100	98.3		ppb		98	85 - 115	0	20

**Lab Sample ID: 550-81104-A-3-C MS**  
**Matrix: Water**  
**Analysis Batch: 115537**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 115202**  
 %Rec.

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Lead	ND		100	96.4		ppb		96	70 - 130

**Lab Sample ID: 550-81104-A-3-D MSD**  
**Matrix: Water**  
**Analysis Batch: 115537**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 115202**  
 %Rec.

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	ND		100	99.4		ppb		99	70 - 130	3	20

# QC Association Summary

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

## Metals

### Prep Batch: 115161

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80917-1	GB1	Total/NA	Drinking Water	200.8	
550-80917-2	GB2	Total/NA	Drinking Water	200.8	
550-80917-3	GB3	Total/NA	Drinking Water	200.8	
550-80917-4	GB4	Total/NA	Drinking Water	200.8	
550-80917-5	GB5	Total/NA	Drinking Water	200.8	
550-80917-6	GB6	Total/NA	Drinking Water	200.8	
550-80917-7	GB7	Total/NA	Drinking Water	200.8	
550-80917-8	GB8	Total/NA	Drinking Water	200.8	
550-80917-9	GB9	Total/NA	Drinking Water	200.8	
MB 550-115161/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-115161/3-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-115161/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-80863-A-1-B MS	Matrix Spike	Total/NA	Water	200.8	
550-80863-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

### Prep Batch: 115162

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80917-10	GB10	Total/NA	Drinking Water	200.8	
550-80917-11	GB11	Total/NA	Drinking Water	200.8	
550-80917-12	GB12	Total/NA	Drinking Water	200.8	
550-80917-13	GB13	Total/NA	Drinking Water	200.8	
550-80917-14	GB14	Total/NA	Drinking Water	200.8	
550-80917-15	GB15	Total/NA	Drinking Water	200.8	
550-80917-16	GB16	Total/NA	Drinking Water	200.8	
550-80917-17	GB17	Total/NA	Drinking Water	200.8	
550-80917-18	GB18	Total/NA	Drinking Water	200.8	
550-80917-19	GB19	Total/NA	Drinking Water	200.8	
550-80917-20	GB20	Total/NA	Drinking Water	200.8	
550-80917-21	GB21	Total/NA	Drinking Water	200.8	
550-80917-22	GB22	Total/NA	Drinking Water	200.8	
550-80917-23	GB23	Total/NA	Drinking Water	200.8	
550-80917-24	GB24	Total/NA	Drinking Water	200.8	
550-80917-25	GB25	Total/NA	Drinking Water	200.8	
550-80917-26	GB26	Total/NA	Drinking Water	200.8	
550-80917-27	GB27	Total/NA	Drinking Water	200.8	
550-80917-28	GB28	Total/NA	Drinking Water	200.8	
550-80917-29	GB29	Total/NA	Drinking Water	200.8	
MB 550-115162/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-115162/3-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-115162/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-80917-10 MS	GB10	Total/NA	Drinking Water	200.8	
550-80917-10 MSD	GB10	Total/NA	Drinking Water	200.8	

### Prep Batch: 115202

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80917-30	GB30	Total/NA	Drinking Water	200.8	
MB 550-115202/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-115202/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-115202/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-81104-A-3-C MS	Matrix Spike	Total/NA	Water	200.8	
550-81104-A-3-D MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

TestAmerica Phoenix

# QC Association Summary

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

## Analysis Batch: 115535

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80917-1	GB1	Total/NA	Drinking Water	200.8	115161
550-80917-2	GB2	Total/NA	Drinking Water	200.8	115161
550-80917-3	GB3	Total/NA	Drinking Water	200.8	115161
550-80917-4	GB4	Total/NA	Drinking Water	200.8	115161
550-80917-5	GB5	Total/NA	Drinking Water	200.8	115161
550-80917-6	GB6	Total/NA	Drinking Water	200.8	115161
550-80917-7	GB7	Total/NA	Drinking Water	200.8	115161
550-80917-8	GB8	Total/NA	Drinking Water	200.8	115161
550-80917-9	GB9	Total/NA	Drinking Water	200.8	115161
MB 550-115161/1-A	Method Blank	Total/NA	Water	200.8	115161
LCS 550-115161/3-A	Lab Control Sample	Total/NA	Water	200.8	115161
LCSD 550-115161/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	115161
550-80863-A-1-B MS	Matrix Spike	Total/NA	Water	200.8	115161
550-80863-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	115161

## Analysis Batch: 115536

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80917-10	GB10	Total/NA	Drinking Water	200.8	115162
550-80917-11	GB11	Total/NA	Drinking Water	200.8	115162
550-80917-12	GB12	Total/NA	Drinking Water	200.8	115162
550-80917-13	GB13	Total/NA	Drinking Water	200.8	115162
550-80917-14	GB14	Total/NA	Drinking Water	200.8	115162
550-80917-15	GB15	Total/NA	Drinking Water	200.8	115162
550-80917-16	GB16	Total/NA	Drinking Water	200.8	115162
550-80917-17	GB17	Total/NA	Drinking Water	200.8	115162
550-80917-18	GB18	Total/NA	Drinking Water	200.8	115162
550-80917-19	GB19	Total/NA	Drinking Water	200.8	115162
550-80917-20	GB20	Total/NA	Drinking Water	200.8	115162
550-80917-21	GB21	Total/NA	Drinking Water	200.8	115162
550-80917-22	GB22	Total/NA	Drinking Water	200.8	115162
550-80917-23	GB23	Total/NA	Drinking Water	200.8	115162
550-80917-24	GB24	Total/NA	Drinking Water	200.8	115162
550-80917-25	GB25	Total/NA	Drinking Water	200.8	115162
550-80917-26	GB26	Total/NA	Drinking Water	200.8	115162
550-80917-27	GB27	Total/NA	Drinking Water	200.8	115162
550-80917-28	GB28	Total/NA	Drinking Water	200.8	115162
550-80917-29	GB29	Total/NA	Drinking Water	200.8	115162
MB 550-115162/1-A	Method Blank	Total/NA	Water	200.8	115162
LCS 550-115162/3-A	Lab Control Sample	Total/NA	Water	200.8	115162
LCSD 550-115162/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	115162
550-80917-10 MS	GB10	Total/NA	Drinking Water	200.8	115162
550-80917-10 MSD	GB10	Total/NA	Drinking Water	200.8	115162

## Analysis Batch: 115537

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80917-30	GB30	Total/NA	Drinking Water	200.8	115202
MB 550-115202/1-A	Method Blank	Total/NA	Water	200.8	115202
LCS 550-115202/4-A	Lab Control Sample	Total/NA	Water	200.8	115202
LCSD 550-115202/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	115202
550-81104-A-3-C MS	Matrix Spike	Total/NA	Water	200.8	115202
550-81104-A-3-D MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	115202

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB1

Date Collected: 04/03/17 09:32

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:19	TEK	TAL PHX

## Client Sample ID: GB2

Date Collected: 04/03/17 09:56

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-2

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:21	TEK	TAL PHX

## Client Sample ID: GB3

Date Collected: 04/03/17 09:52

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-3

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:23	TEK	TAL PHX

## Client Sample ID: GB4

Date Collected: 04/03/17 09:37

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-4

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:25	TEK	TAL PHX

## Client Sample ID: GB5

Date Collected: 04/03/17 09:46

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-5

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:27	TEK	TAL PHX

## Client Sample ID: GB6

Date Collected: 04/03/17 09:47

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-6

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:29	TEK	TAL PHX

TestAmerica Phoenix

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB7

Date Collected: 04/03/17 10:00  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-7

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:31	TEK	TAL PHX

## Client Sample ID: GB8

Date Collected: 04/03/17 10:05  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-8

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:32	TEK	TAL PHX

## Client Sample ID: GB9

Date Collected: 04/03/17 10:10  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-9

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115161	04/18/17 12:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115535	04/23/17 14:34	TEK	TAL PHX

## Client Sample ID: GB10

Date Collected: 04/03/17 10:12  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-10

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 14:48	TEK	TAL PHX

## Client Sample ID: GB11

Date Collected: 04/03/17 10:17  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-11

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 14:53	TEK	TAL PHX

## Client Sample ID: GB12

Date Collected: 04/03/17 10:28  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-12

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 14:55	TEK	TAL PHX

TestAmerica Phoenix

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB13

Date Collected: 04/03/17 10:27  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-13

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 14:57	TEK	TAL PHX

## Client Sample ID: GB14

Date Collected: 04/03/17 10:22  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-14

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 14:59	TEK	TAL PHX

## Client Sample ID: GB15

Date Collected: 04/03/17 10:33  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-15

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:01	TEK	TAL PHX

## Client Sample ID: GB16

Date Collected: 04/03/17 10:36  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-16

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:03	TEK	TAL PHX

## Client Sample ID: GB17

Date Collected: 04/03/17 10:40  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-17

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:05	TEK	TAL PHX

## Client Sample ID: GB18

Date Collected: 04/03/17 10:39  
Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-18

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:07	TEK	TAL PHX

TestAmerica Phoenix

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Client Sample ID: GB19

Date Collected: 04/04/17 06:31

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-19

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:09	TEK	TAL PHX

## Client Sample ID: GB20

Date Collected: 04/04/17 06:34

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-20

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:14	TEK	TAL PHX

## Client Sample ID: GB21

Date Collected: 04/04/17 06:28

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-21

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:16	TEK	TAL PHX

## Client Sample ID: GB22

Date Collected: 04/04/17 06:15

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-22

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:18	TEK	TAL PHX

## Client Sample ID: GB23

Date Collected: 04/04/17 06:14

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-23

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:20	TEK	TAL PHX

## Client Sample ID: GB24

Date Collected: 04/04/17 06:21

Date Received: 04/12/17 12:00

## Lab Sample ID: 550-80917-24

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:22	TEK	TAL PHX

TestAmerica Phoenix

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
 Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
 SDG: Gila Bend School

**Client Sample ID: GB25**  
**Date Collected: 04/03/17 10:54**  
**Date Received: 04/12/17 12:00**

**Lab Sample ID: 550-80917-25**  
**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:24	TEK	TAL PHX

**Client Sample ID: GB26**  
**Date Collected: 04/03/17 10:56**  
**Date Received: 04/12/17 12:00**

**Lab Sample ID: 550-80917-26**  
**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:26	TEK	TAL PHX

**Client Sample ID: GB27**  
**Date Collected: 04/03/17 10:57**  
**Date Received: 04/12/17 12:00**

**Lab Sample ID: 550-80917-27**  
**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:28	TEK	TAL PHX

**Client Sample ID: GB28**  
**Date Collected: 04/03/17 10:55**  
**Date Received: 04/12/17 12:00**

**Lab Sample ID: 550-80917-28**  
**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:30	TEK	TAL PHX

**Client Sample ID: GB29**  
**Date Collected: 04/04/17 06:38**  
**Date Received: 04/12/17 12:00**

**Lab Sample ID: 550-80917-29**  
**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115162	04/18/17 12:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115536	04/23/17 15:32	TEK	TAL PHX

**Client Sample ID: GB30**  
**Date Collected: 04/04/17 06:45**  
**Date Received: 04/12/17 12:00**

**Lab Sample ID: 550-80917-30**  
**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			115202	04/18/17 17:41	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115537	04/23/17 15:52	TEK	TAL PHX

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

**Laboratory References:**

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

# Accreditation/Certification Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

## Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	EPA Region	Identification Number	Expiration Date
Arizona	State Program	9	AZ0728	06-09-17

Analysis Method	Prep Method	Matrix	Analyte
-----------------	-------------	--------	---------

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

# Method Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Gila Bend Unified District

TestAmerica Job ID: 550-80917-1  
SDG: Gila Bend School

---

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX


---

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340



80917

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	GOLD BRAD SCHOOL DISTRICT #2
School Name	GOLD BRAD SCHOOL
Building (name/number)	A-BUILDING
Type of Fixture (tap, drinking fountain etc.)	WATER FOUNTAIN
Location of Fixture (example, room number)	OUTSIDE A-BUILDING
Sample Identification Number <b>(Write this number on the sample container and on this sheet)</b>	GB 1
Date of Collection	4-3-17
Time of Collection	9:32 AM
Printed Name of Sample Collector	Titia Karabinis
Signature Sample Collector	<i>[Signature]</i>

550-80917 Chain of Custody



Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4-12-17 12:00
Signature	<i>[Signature]</i>
Notes: 22,100      2020      PE GR	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_




These samples were collected for lead screening purposes only and cannot be used for compliance.

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gild Bend Unified School District #24
School Name	Gild Bend School
Building (name/number)	B - building
Type of Fixture (tap, drinking fountain etc.)	Outside Water Fountain
Location of Fixture (example, room number)	Outside B - building
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB2
Date of Collection	4/3/17
Time of Collection	9:56 am
Printed Name of Sample Collector	Title Karabinic
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

②


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Gild Beni Unified School District #24
School Name	Gild Beni School
Building (name/number)	B - building
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Inside B - building office
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB3
Date of Collection	4/3/17
Time of Collection	9:52 am
Printed Name of Sample Collector	Title Karabina
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


(3)

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	B-building
Type of Fixture (tap, drinking fountain etc.)	Sink tap
Location of Fixture (example, room number)	Inside B-building lounge
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	G-B4
Date of Collection	4/3/17
Time of Collection	9:37 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


4

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified School District #24
School Name	Gilbert School
Building (name/number)	C- building
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Home Ec north east sink
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	G-B-5
Date of Collection	4/3/17
Time of Collection	9:46 am
Printed Name of Sample Collector	Rita Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	C-building
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Home Ec south west sink
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	G-B-6
Date of Collection	4/3/17
Time of Collection	9:47 am
Printed Name of Sample Collector	Tina Kerabinis
Signature Sample Collector	

Notes Sample collector:


For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*



### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #29
School Name	Gila Bend School
Building (name/number)	D- building
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Outside D- building
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB7
Date of Collection	4/3/17
Time of Collection	10:00 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	<i>Title Karabinis</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_




*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Girls locker room
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	G-08
Date of Collection	4/3/17
Time of Collection	10:05 am
Printed Name of Sample Collector	Titia Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only.

Relinquished date and signature \_\_\_\_\_

8

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Inside Gym Foyer
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB9
Date of Collection	4/3/17
Time of Collection	10:10 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


9

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Boys Locker Room
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB 10
Date of Collection	4/3/17
Time of Collection	10:12 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #29
School Name	Gila Bend School
Building (name/number)	F-building
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	outside F-building
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	G-B11
Date of Collection	4/3/17
Time of Collection	10:17 am
Printed Name of Sample Collector	Tina Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*



### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Cafeteria
Type of Fixture (tap, drinking fountain etc.)	Sink tap
Location of Fixture (example, room number)	Inside kitchen west wall
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB12
Date of Collection	4/3/17
Time of Collection	10:28 am
Printed Name of Sample Collector	Title Karabats
Signature Sample Collector	<i>Title Karabats</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

12


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Cafeteria
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Inside kitchen south wall
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	6-B13
Date of Collection	4/3/17
Time of Collection	10:27 am
Printed Name of Sample Collector	Title Karabits
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


(B)

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Cafeteria
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	Inside Cafeteria
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB 14
Date of Collection	4/3/17
Time of Collection	10:22 am
Printed Name of Sample Collector	Title Kumbiris
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

14

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	J-Building
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	outside J-building
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	G-BIS
Date of Collection	4/3/17
Time of Collection	10:33 am
Printed Name of Sample Collector	Tate Karabinis
Signature Sample Collector	<i>Tate Karabinis</i>

Notes Sample collector:

For Lab use only	
<del>Analyze this drinking water sample for lead</del>	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

(15)


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend School District #24
School Name	Gila Bend School
Building (name/number)	J-building
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	inside J-building office
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GD16
Date of Collection	4/3/17
Time of Collection	10:36 am
Printed Name of Sample Collector	Tiffie Karbinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead _____	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*





### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #234
School Name	Gila Bend School
Building (name/number)	J - building
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	inside J-building lounge
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	G-B17
Date of Collection	4/2/17
Time of Collection	10:40 am
Printed Name of Sample Collector	Title Karbinis
Signature Sample Collector	<i>Title Karbinis</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gile Bend Unified School District #24
School Name	Gile Bend School
Building (name/number)	J-building
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	inside Nurse's office
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB18
Date of Collection	4/21/17
Time of Collection	10:39 am
Printed Name of Sample Collector	Tina Karabinski
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	K- building
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Pre-school k-17 sink
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB19
Date of Collection	4/4/17
Time of Collection	6:31 am
Printed Name of Sample Collector	THE Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	K-building
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Pre-school K-9 sink
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	G-B 20
Date of Collection	4/4/17
Time of Collection	6:34 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	K-building
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	Pre-school outside water fountain
Sample Identification Number <b>(Write this number on the sample container and on this sheet)</b>	GB 21
Date of Collection	4/4/17
Time of Collection	6:28 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	M-building
Type of Fixture (tap, drinking fountain etc.)	Water fountain
Location of Fixture (example, room number)	East outside water fountain
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB 22
Date of Collection	4/4/17
Time of Collection	6:15 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

22

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	M-Building
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	West outside water fountain
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB 23
Date of Collection	4/4/17
Time of Collection	6:14 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	<i>Title Karabinis</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District
School Name	Gila Bend School
Building (name/number)	M-building
Type of Fixture (tap, drinking fountain etc.)	stainless steel tap
Location of Fixture (example, room number)	Inside M-building lounge
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	GB24
Date of Collection	4/4/17
Time of Collection	6:21 am
Printed Name of Sample Collector	Tithe Karabian
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*



### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Library
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Library foyer south Water Fountain
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB25
Date of Collection	4/3/17
Time of Collection	10:54 am
Printed Name of Sample Collector	Tithe Karabinis
Signature Sample Collector	


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Library
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	East Water Fountain
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB 26
Date of Collection	4/3/17
Time of Collection	10:36 am
Printed Name of Sample Collector	Tithe Karahinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #241
School Name	Gila Bend School
Building (name/number)	Library
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	West Water fountain
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	G-B 27
Date of Collection	4/3/17
Time of Collection	10:57 am
Printed Name of Sample Collector	Tiffie Karabinis
Signature Sample Collector	

Notes Sample collector:


For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Library
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Library lounge sink
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB 28
Date of Collection	4/3/17
Time of Collection	10:55 am
Printed Name of Sample Collector	Tiffie Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Baseball Field
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	baseball Home team dugout
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	GB 29
Date of Collection	4/4/17
Time of Collection	6:30 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

29

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Gila Bend Unified School District #24
School Name	Gila Bend School
Building (name/number)	Football Field
Type of Fixture (tap, drinking fountain etc.)	sink tap
Location of Fixture (example, room number)	Concession Stand sink
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	GB 30
Date of Collection	4/4/17
Time of Collection	6:45 am
Printed Name of Sample Collector	Title Karabinis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_



*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-80917-1  
SDG Number: Gila Bend School

**Login Number: 80917**  
**List Number: 1**  
**Creator: Vilaboy, Monica**

**List Source: TestAmerica Phoenix**

Question	Answer	Comment
Radioactivity wasn't checked or is <math>\leq</math> background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	Check done at department level as required.

