



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ
Lead in Drinking Water School Proj.
1110 W. Washington Street
Phoenix, AZ 85007
Attn: David Burchard

Date Submitted: 03/09/17
Date Reported: 03/27/17

Project: Gilbert Classical Academy

RESULTS

Client ID: 1006-01
ACT Lab No.: BZ03027

Sample Type: Drinking Water
Sample Time: 03/05/17 16:00

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1001-01
ACT Lab No.: BZ03028

Sample Type: Drinking Water
Sample Time: 03/05/17 10:00

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1001-02
ACT Lab No.: BZ03029

Sample Type: Drinking Water
Sample Time: 03/05/17 10:05

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1002-01
ACT Lab No.: BZ03030

Sample Type: Drinking Water
Sample Time: 03/05/17 10:15

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

RESULTS

Client ID: 1002-02
ACT Lab No.: BZ03031

Sample Type: Drinking Water
Sample Time: 03/05/17 10:18

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1003-01
ACT Lab No.: BZ03032

Sample Type: Drinking Water
Sample Time: 03/05/17 10:20

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	1.34	ug/L	SLM

Client ID: 1003-02
ACT Lab No.: BZ03033

Sample Type: Drinking Water
Sample Time: 03/05/17 10:23

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1004-01
ACT Lab No.: BZ03034

Sample Type: Drinking Water
Sample Time: 03/05/17 10:30


<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1004-02
ACT Lab No.: BZ03035

Sample Type: Drinking Water
Sample Time: 03/05/17 10:33

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Reviewed by: _____


Frederick A. Amalfi, Ph.D.
Laboratory Director

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	WORK ROOM
Sample Identification Number (ensure this number is also on the sample container)	1006-01
Date of Collection	3-5-17
Time of Collection	4:00 PM
Name of Sample Collector	STAN WELLS
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03027</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature T. Johnson ACT 12:00
MAR 09 2017
22°C

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

046

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	240 KITCHEN
Sample Identification Number (ensure this number is also on the sample container)	1001-01
Date of Collection	3-5-17
Time of Collection	10:00 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03028</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
 22°C

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	MULTI-PURPOSE ROOM / CAFETERIA
Sample Identification Number (ensure this number is also on the sample container)	1001-02
Date of Collection	3-5-17
Time of Collection	10:05 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03029</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
RC

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	Room 110
Sample Identification Number (ensure this number is also on the sample container)	1002-01
Date of Collection	3-5-17
Time of Collection	10:15 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03030</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
WR

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	Room 109
Sample Identification Number (ensure this number is also on the sample container)	1002-02
Date of Collection	3-5-17
Time of Collection	10:18 AM
Name of Sample Collector	Daniel Roberts
Signature Sample Collector	<i>Daniel Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03031	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
ZZC

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ADMIN LOUNGE
Sample Identification Number (ensure this number is also on the sample container)	1003-01
Date of Collection	3-5-17
Time of Collection	10:20 AM
Name of Sample Collector	Daniel Roberts
Signature Sample Collector	<i>Daniel Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03032</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
 MAR 09 2017
22

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	210 LIBRARY
Sample Identification Number (ensure this number is also on the sample container)	1003-02
Date of Collection	3-5-17
Time of Collection	10:23 AM
Name of Sample Collector	Daniel Robles Robles
Signature Sample Collector	Daniel Robles

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03033</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
ZC

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	130 music room
Sample Identification Number (ensure this number is also on the sample container)	1004-01
Date of Collection	3-5-17
Time of Collection	10:30 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03034	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
280

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Gilbert Classical Academy (formerly GPS Technology Leadership Academy)
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	130 Music Room
Sample Identification Number (ensure this number is also on the sample container)	1004-02
Date of Collection	3-5-17
Time of Collection	10:33 AM
Name of Sample Collector	Daniel Cobles
Signature Sample Collector	<i>Daniel Cobles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03035</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
220

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.