



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ
Lead in Drinking Water School Proj.
1110 W. Washington Street
Phoenix, AZ 85007
Attn: David Burchard

Date Submitted: 03/09/17
Date Reported: 03/27/17

Project: Mesquite HS

RESULTS

Client ID: 1015-01
ACT Lab No.: BZ03036

Sample Type: Drinking Water
Sample Time: 02/26/17 09:58

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1012-01
ACT Lab No.: BZ03037

Sample Type: Drinking Water
Sample Time: 02/26/17 11:49

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1002-01
ACT Lab No.: BZ03038

Sample Type: Drinking Water
Sample Time: 02/26/17 09:50

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1003-01
ACT Lab No.: BZ03039

Sample Type: Drinking Water
Sample Time: 02/26/17 10:18

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

RESULTS

Client ID: 1001-01
ACT Lab No.: BZ03040

Sample Type: Drinking Water
Sample Time: 02/26/17 09:16

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1031-01
ACT Lab No.: BZ03041

Sample Type: Drinking Water
Sample Time: 02/26/17 10:51

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1007-01
ACT Lab No.: BZ03042

Sample Type: Drinking Water
Sample Time: 02/26/17 09:25

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1014-01
ACT Lab No.: BZ03043

Sample Type: Drinking Water
Sample Time: 02/26/17 11:22

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1006-01
ACT Lab No.: BZ03044

Sample Type: Drinking Water
Sample Time: 02/26/17 10:35

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	2.80	ug/L	SLM

Client ID: 1004-01
ACT Lab No.: BZ03045

Sample Type: Drinking Water
Sample Time: 02/26/17 10:08

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	4.38	ug/L	SLM

RESULTS

Client ID: 1017-01
ACT Lab No.: BZ03046

Sample Type: Drinking Water
Sample Time: 02/26/17 11:08

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1013-01
ACT Lab No.: BZ03047

Sample Type: Drinking Water
Sample Time: 02/26/17 11:55

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1005-01
ACT Lab No.: BZ03048

Sample Type: Drinking Water
Sample Time: 02/26/17 10:44

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/20/17	03/20/17	200.8	1.0	<1.00	ug/L	SLM

Reviewed by: _____



Frederick A. Amalfi, Ph.D.
Laboratory Director

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	G-212
Sample Identification Number (ensure this number is also on the sample container)	1015-01
Date of Collection	2-26-17
Time of Collection	9:58 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	BZ-03036

For relinquishing samples upon delivery to labs only

Relinquished date and signature *Johnson ACT* 12:00
MAR 09 2017
200

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

047

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1012
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Field House Visitor
Sample Identification Number (ensure this number is also on the sample container)	1012-01
Date of Collection	2-26-17
Time of Collection	11:49 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03037</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
 MAR 09 2017
RPC

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	A-206
Sample Identification Number (ensure this number is also on the sample container)	1002-01
Date of Collection	2-26-17
Time of Collection	9:50 AM
Name of Sample Collector	Daniel Roberts
Signature Sample Collector	<i>Daniel Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03038</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
[Signature]

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	B-118
Sample Identification Number (ensure this number is also on the sample container)	1003-01
Date of Collection	2-26-17
Time of Collection	10:18 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03039</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ 12:00
MAR 09 2017
ZC

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	A-126
Sample Identification Number (ensure this number is also on the sample container)	1001-01
Date of Collection	2-26-17
Time of Collection	9:16 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03040</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
[Signature]

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1031
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	C-130
Sample Identification Number (ensure this number is also on the sample container)	1031-01
Date of Collection	2-26-16
Time of Collection	10:51 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03041</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
228

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Maintenance Shop
Sample Identification Number (ensure this number is also on the sample container)	1007-01
Date of Collection	2-26-17
Time of Collection	9:25 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03042</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
ZZC

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1014
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	G-111
Sample Identification Number (ensure this number is also on the sample container)	1014-01
Date of Collection	2-26-17
Time of Collection	11:22 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03043</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
228

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Cafeteria
Sample Identification Number (ensure this number is also on the sample container)	1006-01
Date of Collection	2-26-17
Time of Collection	10:35 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03044</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
 MAR 09 2017
 22°C

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	B-222
Sample Identification Number (ensure this number is also on the sample container)	1004-01
Date of Collection	2-26-17
Time of Collection	10:08 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03045</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

12:00
MAR 09 2017
228

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1017
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Auditorium
Sample Identification Number (ensure this number is also on the sample container)	1017-01
Date of Collection	2-26-17
Time of Collection	11:08 AM
Name of Sample Collector	Daniel Rollers
Signature Sample Collector	<i>Daniel Rollers</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03046</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ 12:00
MAR 09 2017
22

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1013
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	Field House Home Side
Sample Identification Number (ensure this number is also on the sample container)	1013-01
Date of Collection	2-26-17
Time of Collection	11:55 AM
Name of Sample Collector	Daniel Roberts
Signature Sample Collector	<i>Daniel Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03047</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ 12:00
MAR 09 2017
[Signature]

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Mesquite High School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	C-112
Sample Identification Number (ensure this number is also on the sample container)	1005-01
Date of Collection	2-26-17
Time of Collection	10:44 AM
Name of Sample Collector	Daniel Robles
Signature Sample Collector	<i>Daniel Robles</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03048</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ 12:00
MAR 09 2017
WR

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.