



# AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106  
P.O. Box 1510  
Tempe, Arizona 85281  
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

## LABORATORY REPORT

**Client:** ADEQ  
Lead in Drinking Water School Proj.  
1110 W. Washington Street  
Phoenix, AZ 85007  
**Attn:** David Burchard

**Date Submitted:** 02/24/17  
**Date Reported:** 03/16/17

**Project:** Desert Ridge High School

## RESULTS

**Client ID:** 1001-01  
**ACT Lab No.:** BZ02170

**Sample Type:** Drinking Water  
**Sample Time:** 02/24/17 05:35

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

**Client ID:** 1002-01  
**ACT Lab No.:** BZ02171

**Sample Type:** Drinking Water  
**Sample Time:** 02/24/17 05:40

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

**Client ID:** 1003-01  
**ACT Lab No.:** BZ02172

**Sample Type:** Drinking Water  
**Sample Time:** 02/24/17 05:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

**Client ID:** 1004-01  
**ACT Lab No.:** BZ02173

**Sample Type:** Drinking Water  
**Sample Time:** 02/24/17 05:50

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

## RESULTS

Client ID: 1005-01  
ACT Lab No.: BZ02174

Sample Type: Drinking Water  
Sample Time: 02/24/17 05:55

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1006-01  
ACT Lab No.: BZ02175

Sample Type: Drinking Water  
Sample Time: 02/24/17 06:10

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1009-01  
ACT Lab No.: BZ02176

Sample Type: Drinking Water  
Sample Time: 02/24/17 06:25

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 1011-01  
ACT Lab No.: BZ02177

Sample Type: Drinking Water  
Sample Time: 02/24/17 06:40

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/06/17	03/06/17	200.8	1.0	<1.00	ug/L	SLM

Reviewed by: \_\_\_\_\_



Frederick A. Amalfi, Ph.D.  
Laboratory Director

*SLM*

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	SCHOOL ADMIN 1001
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Admin. Lobby
Sample Identification Number (ensure this number is also on the sample container)	1001-01
Date of Collection	2-24-17
Time of Collection	5:35 AM
Name of Sample Collector	RON CLAYDON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
<b>BZ-02170</b>	
15:00 FEB 24 2017 	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	LIBRARY/CLASSROOMS 1002
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Building 2 HALLWAY
Sample Identification Number (ensure this number is also on the sample container)	1002-01
Date of Collection	2-24-17
Time of Collection	5:40am
Name of Sample Collector	RON CLAYDON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>Notes:</p> <p style="text-align: center; font-size: 1.2em;"><b>BZ-02171</b></p> <p style="text-align: right;">15:00 FEB 24 2017</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	Gym/CLASSROOMS 1003
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	HALLWAY Girls Locker room 3117
Sample Identification Number (ensure this number is also on the sample container)	1003-01
Date of Collection	2-24-17
Time of Collection	5:45 am
Name of Sample Collector	RON CLAYDON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>Notes:</p> <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="font-size: 24px; font-weight: bold;">BZ-02172</div> <div style="text-align: right;"> <p style="font-size: 24px;">15:00</p> <p>FEB 24 2017</p> </div> </div>	

160

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	CAFETERIA / CLASSROOMS 1004
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (ensure this number is also on the sample container)	1004-01
Date of Collection	2-24-17
Time of Collection	5:50 am
Name of Sample Collector	RON CLAYDON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p style="font-size: 24px; font-weight: bold; margin: 0;">BZ-02173</p> <div style="text-align: right; margin-top: 20px;"> <p style="font-size: 24px; margin: 0;">15:00</p> <p style="margin: 0;">FEB 24 2017</p>  </div>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	CLASSROOMS 1005
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	HALLWAY 51C
Sample Identification Number (ensure this number is also on the sample container)	1005-01
Date of Collection	2-24-17
Time of Collection	5:55am
Name of Sample Collector	Ron Claydon
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>Notes:</p> <div style="display: flex; justify-content: space-between; align-items: flex-end; padding: 10px;"> <div style="font-size: 1.5em; font-weight: bold;">BZ-02174</div> <div style="text-align: right;"> <p style="font-size: 1.2em;">15:00</p> <p>FEB 24 2017</p> </div> </div>	

160

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	Fieldhouse / Concession 1006
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	CONCESSION
Sample Identification Number (ensure this number is also on the sample container)	1006-01
Date of Collection	2-24-17
Time of Collection	6:10 am
Name of Sample Collector	RON CLAYDON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>Notes:</p> <div style="text-align: center; font-size: 1.2em; font-weight: bold;">BZ-02175</div> <div style="text-align: right; margin-top: 10px;"> <span style="font-size: 1.5em;">15:00</span>  <span>FEB 24 2017</span> </div> <div style="text-align: right; margin-top: 10px;">  </div>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District
Name of School	Desert Ridge High School
Building (name/number)	CENTRAL Plant / MAINTENANCE 1009
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Maintenance Shop
Sample Identification Number (ensure this number is also on the sample container)	1009-01
Date of Collection	2-24-17
Time of Collection	6:25 am
Name of Sample Collector	TRON CLAYTON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
<div style="display: flex; justify-content: space-between; align-items: center;"> <span style="font-size: 1.2em; font-weight: bold;">BZ-02176</span> <div style="text-align: right;"> <span style="font-size: 1.2em;">15:00</span>  <span>FEB 24 2017</span> </div> </div>	

160

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Gilbert Unified District	
Name of School	Desert Ridge High School	
Building (name/number)	Building addition 1003	1011
Type of Fixture (tap, drinking fountain etc.)	Tap	
Location of Fixture (example, room number)	Building addition	
Sample Identification Number (ensure this number is also on the sample container)	1011-01	
Date of Collection	2-24-17	
Time of Collection	6:50 am.	
Name of Sample Collector	Ron Claydon	
Signature Sample Collector		

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p style="font-size: 24px; font-weight: bold; margin: 0;">BZ-02177</p> <p style="text-align: right; margin: 0;">15:00 FEB 24 2017 </p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples are collected and are to be analyzed for screening purposes only and cannot be used for compliance.