

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Kiva Elementary School

Reported:
06/06/17 17:01

Analyte

01 (7052175-01) Drinking Water (Grab) Sampled: 05/10/17 05:10 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 16:46	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

02 (7052175-02) Drinking Water (Grab) Sampled: 05/10/17 05:11 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 16:49	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

03 (7052175-03) Drinking Water (Grab) Sampled: 05/10/17 05:15 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 16:51	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

04 (7052175-04) Drinking Water (Grab) Sampled: 05/10/17 05:17 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 16:54	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

05 (7052175-05) Drinking Water (Grab) Sampled: 05/10/17 05:19 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 16:56	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

06 (7052175-06) Drinking Water (Grab) Sampled: 05/10/17 05:21 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 16:59	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

07 (7052175-07) Drinking Water (Grab) Sampled: 05/10/17 05:23 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 34

07 (7052175-07) Drinking Water (Grab) Sampled: 05/10/17 05:23 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	100	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:06	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

08 (7052175-08) Drinking Water (Grab) Sampled: 05/10/17 05:26 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:08	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

09 (7052175-09) Drinking Water (Grab) Sampled: 05/10/17 05:29 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:16	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

10 (7052175-10) Drinking Water (Grab) Sampled: 05/10/17 05:30 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:18	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

11 (7052175-11) Drinking Water (Grab) Sampled: 05/10/17 05:32 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:26	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

12 (7052175-12) Drinking Water (Grab) Sampled: 05/10/17 05:34 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:28	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

13 (7052175-13) Drinking Water (Grab) Sampled: 05/10/17 05:36 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:31	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

14 (7052175-14) Drinking Water (Grab) Sampled: 05/10/17 05:41 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

14 (7052175-14) Drinking Water (Grab) Sampled: 05/10/17 05:41 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:33	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

15 (7052175-15) Drinking Water (Grab) Sampled: 05/10/17 05:43 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:36	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

16 (7052175-16) Drinking Water (Grab) Sampled: 05/10/17 05:45 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:38	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

17 (7052175-17) Drinking Water (Grab) Sampled: 05/10/17 05:47 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:46	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

18 (7052175-18) Drinking Water (Grab) Sampled: 05/10/17 05:49 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:48	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

19 (7052175-19) Drinking Water (Grab) Sampled: 05/10/17 05:55 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:50	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

20 (7052175-20) Drinking Water (Grab) Sampled: 05/10/17 05:56 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1002	06/02/17 10:15	06/02/17 17:53	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

21 (7052175-21) Drinking Water (Grab) Sampled: 05/10/17 05:58 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

21 (7052175-21) Drinking Water (Grab) Sampled: 05/10/17 05:58 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

22 (7052175-22) Drinking Water (Grab) Sampled: 05/10/17 06:00 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

23 (7052175-23) Drinking Water (Grab) Sampled: 05/10/17 06:01 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:18	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

24 (7052175-24) Drinking Water (Grab) Sampled: 05/10/17 06:03 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:20	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

25 (7052175-25) Drinking Water (Grab) Sampled: 05/10/17 06:05 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:23	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

26 (7052175-26) Drinking Water (Grab) Sampled: 05/10/17 06:07 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:25	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

27 (7052175-27) Drinking Water (Grab) Sampled: 05/10/17 06:10 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.1	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:28	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

28 (7052175-28) Drinking Water (Grab) Sampled: 05/10/17 06:12 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Kiva Elementary School

Reported:
06/06/17 17:01

28 (7052175-28) Drinking Water (Grab) Sampled: 05/10/17 06:12 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									
Total Metals									
Lead	<5.0	5.0	ug/L	1	B7F1003	06/02/17 14:00	06/02/17 18:30	EPA 200.8	

Sample Condition Upon Receipt:

Temperature: 21.80 °C
All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.
QA/QC Criteria: All analyses met method requirements unless otherwise qualified.
Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.
Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052175-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	Admin
Type of Fixture (tap, drinking fountain etc.)	Faucet (sink)
Location of Fixture (example, room number)	Nurse office
Sample Identification Number (Write this number on the sample container and on this sheet)	01
Date of Collection	5/10/17
Time of Collection	5:10
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: faucet near microwave

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 5/22/17 1600 21.8°C pH	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052175-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	Admin
Type of Fixture (tap, drinking fountain etc.)	Sink faucet
Location of Fixture (example, room number)	Admin RR
Sample Identification Number (Write this number on the sample container and on this sheet)	02
Date of Collection	5/10/17
Time of Collection	5:11
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052175-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	B
Type of Fixture (tap, drinking fountain etc.)	DE
Location of Fixture (example, room number)	South outside B3
Sample Identification Number (Write this number on the sample container and on this sheet)	03
Date of Collection	5/10/17
Time of Collection	5:15
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	B
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	Rm B1
Sample Identification Number (Write this number on the sample container and on this sheet)	04
Date of Collection	5/10/17
Time of Collection	5:17
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	C rate
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	North ext
Sample Identification Number (Write this number on the sample container and on this sheet)	05
Date of Collection	5/10/17
Time of Collection	5:12
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	C Cafe
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Kitchen Sink NE
Sample Identification Number (Write this number on the sample container and on this sheet)	06
Date of Collection	5/10/17
Time of Collection	5:21
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	

Notes Sample collector:

Sink NE Kitchen

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052175-07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	D
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	West DF
Sample Identification Number (Write this number on the sample container and on this sheet)	07
Date of Collection	6/10/17
Time of Collection	5:23
Printed Name of Sample Collector	Eyle H. H.
Signature Sample Collector	Eyle H. H.

Notes Sample collector: center fountain

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-08

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	D
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	SE DF
Sample Identification Number (Write this number on the sample container and on this sheet)	08
Date of Collection	5/10/17
Time of Collection	5:26
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: center fountain

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052175-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	F
Type of Fixture (tap, drinking fountain etc.)	DE
Location of Fixture (example, room number)	SE DE
Sample Identification Number (Write this number on the sample container and on this sheet)	09
Date of Collection	5/10/17
Time of Collection	5:29
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: center fountain

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-1D

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	F
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	West DF
Sample Identification Number (Write this number on the sample container and on this sheet)	10
Date of Collection	5/10/17
Time of Collection	5:30
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	<i>Kyle Hall</i>

Notes Sample collector: center DF

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-11

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	E
Type of Fixture (tap, drinking fountain etc.)	DE
Location of Fixture (example, room number)	2m 21
Sample Identification Number (Write this number on the sample container and on this sheet)	11
Date of Collection	5/10/17
Time of Collection	5:32
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	<i>Kyle Hall</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-12

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	E
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	Rm E4
Sample Identification Number (Write this number on the sample container and on this sheet)	12
Date of Collection	5/10/17
Time of Collection	5:34
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	<i>Kyle Hall</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-13

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	G
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	Rm 24 G3
Sample Identification Number (Write this number on the sample container and on this sheet)	13
Date of Collection	5/10/17
Time of Collection	5:36
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-14

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	G
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	G1
Sample Identification Number (Write this number on the sample container and on this sheet)	14
Date of Collection	5/10/17
Time of Collection	5:41
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

7058175-15

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	H
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	West DF
Sample Identification Number (Write this number on the sample container and on this sheet)	15
Date of Collection	5/10/17
Time of Collection	5:43
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: center DF

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-14

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	H
Type of Fixture (tap, drinking fountain etc.)	DE
Location of Fixture (example, room number)	SE DF
Sample Identification Number (Write this number on the sample container and on this sheet)	16
Date of Collection	5/10/17
Time of Collection	5:45
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	

Notes Sample collector: center DF

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-17

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	MN
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	North ext
Sample Identification Number (Write this number on the sample container and on this sheet)	17
Date of Collection	5/10/17
Time of Collection	5:47
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: center fountain

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-18

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	MAN
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	South ext middle
Sample Identification Number (Write this number on the sample container and on this sheet)	18
Date of Collection	5/10/17
Time of Collection	5:49
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: center DF

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-19

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	L
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	SW ext
Sample Identification Number (Write this number on the sample container and on this sheet)	17
Date of Collection	5/10/17
Time of Collection	5:55
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: Center DF

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-20

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	L
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	Library DF
Sample Identification Number (Write this number on the sample container and on this sheet)	20
Date of Collection	5/10/17
Time of Collection	5:56
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052175-21

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	J
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	EAST DF
Sample Identification Number (Write this number on the sample container and on this sheet)	21
Date of Collection	5/10/17
Time of Collection	5:58
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-22

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	5
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	Rm 52
Sample Identification Number (Write this number on the sample container and on this sheet)	22
Date of Collection	5/10/17
Time of Collection	6:00
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-23

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	K
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	RM K2
Sample Identification Number (Write this number on the sample container and on this sheet)	23
Date of Collection	5/10/17
Time of Collection	6:01
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-24

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	K
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Rm K1
Sample Identification Number (Write this number on the sample container and on this sheet)	24
Date of Collection	5/10/17
Time of Collection	6:00
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-25

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	Storage
Type of Fixture (tap, drinking fountain etc.)	DE
Location of Fixture (example, room number)	South ext
Sample Identification Number (Write this number on the sample container and on this sheet)	25
Date of Collection	5/10/17
Time of Collection	6:05
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-26

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	Storage
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	mens RR
Sample Identification Number (Write this number on the sample container and on this sheet)	26
Date of Collection	5/10/17
Time of Collection	6:07
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: left sink

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

705215-27

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	I
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Rm I 1
Sample Identification Number (Write this number on the sample container and on this sheet)	27
Date of Collection	5/10/17
Time of Collection	6:10
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052175-28

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Scottsdale Unified District
School Name	Kiva Elementary School
Building (name/number)	I
Type of Fixture (tap, drinking fountain etc.)	DE
Location of Fixture (example, room number)	Rm 14
Sample Identification Number (Write this number on the sample container and on this sheet)	28
Date of Collection	5/10/17
Time of Collection	6:12
Printed Name of Sample Collector	Eyle Hall
Signature Sample Collector	Eyle Hall

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7052175

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Scottsdale Unified District	Kiva Elementary School	1001	✓ ADM	Administration	1957	2
Scottsdale Unified District	Kiva Elementary School	1002	✓ B	Classrooms	1957	2
Scottsdale Unified District	Kiva Elementary School	1003	✓ C	Cafeteria	1958	2
Scottsdale Unified District	Kiva Elementary School	1004	✓ D	Classrooms	1957	2
Scottsdale Unified District	Kiva Elementary School	1005	✓ E	Classrooms	1957	2
Scottsdale Unified District	Kiva Elementary School	1006	✓	Classrooms/Art	1958	2
Scottsdale Unified District	Kiva Elementary School	1007	✓	Classrooms	1958	2
Scottsdale Unified District	Kiva Elementary School	1008	✓ H	Classrooms	1958	2
Scottsdale Unified District	Kiva Elementary School	1009	✓ I	Classrooms	1958	2
Scottsdale Unified District	Kiva Elementary School	1010	✓ J	Classrooms	1964	2
Scottsdale Unified District	Kiva Elementary School	1011	✓ K	Music	1971	2
Scottsdale Unified District	Kiva Elementary School	1012	✓ L	Library	1964	2
Scottsdale Unified District	Kiva Elementary School	1013	✓ MN	Classrooms	1964	2
Scottsdale Unified District	Kiva Elementary School	1014	✓ STOR	Storage	1985	2
Scottsdale Unified District	Kiva Elementary School	1015	Addition to Bldg A	Admin	2002	1
Scottsdale Unified District	Kiva Elementary School	1016	Addition to Bldg C	Cafeteria	2002	1
Scottsdale Unified District	Kiva Elementary School	1017	Addition to Bldg K	Music	2002	1
Address:					Number of Bottles Per Kit:	2031