

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: ANLC

Reported:
06/06/17 16:58

Analyte

001697 (7052174-01) Drinking Water (Grab) Sampled: 05/19/17 05:10 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1001	06/02/17 09:00	06/02/17 16:14	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

001512 (7052174-02) Drinking Water (Grab) Sampled: 05/19/17 05:12 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1001	06/02/17 09:00	06/02/17 16:17	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

001611 (7052174-03) Drinking Water (Grab) Sampled: 05/19/17 05:15 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1001	06/02/17 09:00	06/02/17 16:19	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

001645 (7052174-04) Drinking Water (Grab) Sampled: 05/19/17 05:17 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1001	06/02/17 09:00	06/02/17 16:21	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

001670 (7052174-05) Drinking Water (Grab) Sampled: 05/19/17 05:20 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1001	06/02/17 09:00	06/02/17 16:24	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

001553 (7052174-06) Drinking Water (Grab) Sampled: 05/19/17 05:23 Received: 05/22/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1001	06/02/17 09:00	06/02/17 16:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 21.80 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052174-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified School Dist.
School Name	ANLC
Building (name/number)	500
Type of Fixture (tap, drinking fountain etc.)	Sink right faucet
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (ensure this number is also on the sample container)	001697
Date of Collection	5/19/17
Time of Collection	5:10
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector: 3 compartment sink right faucet

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 5/22/17 1600	
21.8°C pH✓	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7052174-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified School Dist.
School Name	ANLC
Building (name/number)	300
Type of Fixture (tap, drinking fountain etc.)	DF left
Location of Fixture (example, room number)	300 corridor outside 306
Sample Identification Number (ensure this number is also on the sample container)	001512
Date of Collection	5/19/17
Time of Collection	5:12
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052174-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified School Dist.
School Name	ANLC
Building (name/number)	200
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	Rm 204
Sample Identification Number (ensure this number is also on the sample container)	001011
Date of Collection	5/19/17
Time of Collection	5:15
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	Kyle Hall

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052174-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified School Dist
School Name	ANLC
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	DP 12 ft
Location of Fixture (example, room number)	East Ext 100
Sample Identification Number (ensure this number is also on the sample container)	001645
Date of Collection	5/19/17
Time of Collection	5:17
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7052174-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified School Dist.
School Name	ANLC
Building (name/number)	6000
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Nurse office
Sample Identification Number (ensure this number is also on the sample container)	001670
Date of Collection	5/19/17
Time of Collection	5:20
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Scottsdale Unified School Dist.
School Name	ANLC
Building (name/number)	400
Type of Fixture (tap, drinking fountain etc.)	DF
Location of Fixture (example, room number)	400 hallway
Sample Identification Number (ensure this number is also on the sample container)	001553
Date of Collection	5/19/17
Time of Collection	5:23
Printed Name of Sample Collector	Kyle Hall
Signature Sample Collector	

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2