

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Hopi Elementary

Reported:
06/30/17 12:23

Analyte

1 Confirmation- First Draw (7062252-01) Drinking Water (Grab) Sampled: 06/13/17 05:15 Received: 06/15/17 16:30

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	1100	20	ug/L	1	B7F1833	06/28/17 15:15	06/29/17 09:00	EPA 200.8
------	------	----	------	---	---------	----------------	----------------	-----------

2 Confirmation - Flush (7062252-02) Drinking Water (Grab) Sampled: 06/13/17 05:17 Received: 06/15/17 16:30

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1764	06/26/17 12:27	06/27/17 11:20	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

3 Confirmation- First Draw Day 2 (7062252-03) Drinking Water (Grab) Sampled: 06/14/17 05:05 Received: 06/15/17 16:30

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	250	5.0	ug/L	1	B7F1764	06/26/17 12:27	06/27/17 11:25	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 19.90 °C
All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.
QA/QC Criteria: All analyses met method requirements unless otherwise qualified.
Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.
Comments: There were no problems encountered during the processing of the samples, unless otherwise noted. All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

