







Administration



Administration



BUILDING "H"



Scottsdale Unified
SCHOOL DISTRICT
Holokum Elementary School
New Blueprint Work Up
TMA Systems Aug 10, 2009



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0373

Location ID: Lead in Schools

Lab # AB73364

Date Sampled: 03/08/2017

Time Sampled: 07:40


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg A Rm 13 Sink- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	46.4		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0374

Location ID: Lead in Schools

Lab # AB73365

Date Sampled: 03/08/2017

Time Sampled: 07:42


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg A Rm 16 Sink- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.2		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73366

Date Sampled: 03/08/2017

Time Sampled: 07:44

Date Received: 03/08/2017

Report Date: 04/13/2017


Sample ID: SW17-0375

Location Description:

Location ID: Lead in Schools

Hohokam Elem Bldg B East DF- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73367

Date Sampled: 03/08/2017

Time Sampled: 07:46

Date Received: 03/08/2017

Report Date: 04/13/2017


Sample ID: SW17-0376

Location Description:

Location ID: Lead in Schools

Hohokam Elem Bldg B Rm 21 DF- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0377

Location ID: Lead in Schools

Lab # AB73368

Date Sampled: 03/08/2017

Time Sampled: 07:48


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg L Rm 1 DF- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0378

Location ID: Lead in Schools

Lab # AB73369

Date Sampled: 03/08/2017

Time Sampled: 07:50


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg L Rm 2 Sink- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.4		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73370

Date Sampled: 03/08/2017

Time Sampled: 07:52

Date Received: 03/08/2017

Report Date: 04/13/2017


Sample ID: SW17-0379

Location Description:

Location ID: Lead in Schools

Hohokam Elem Bldg C East DF- G

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73371

Date Sampled: 03/08/2017

Time Sampled: 07:54

Date Received: 03/08/2017

Report Date: 04/13/2017


Sample ID: SW17-0380

Location Description:

Location ID: Lead in Schools

Hohokam Elem Bldg C Rm 32 Sink- H

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.2		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0381

Location ID: Lead in Schools

Lab # AB73372

Date Sampled: 03/08/2017

Time Sampled: 07:56


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg D East DF- I

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0382

Location ID: Lead in Schools

Lab # AB73373

Date Sampled: 03/08/2017

Time Sampled: 07:58

Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg D Rm 45 DF- J

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0383

Location ID: Lead in Schools

Lab # AB73374

Date Sampled: 03/08/2017

Time Sampled: 08:00

Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg K Rm 107 DF- K

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0384

Location ID: Lead in Schools

Lab # AB73375

Date Sampled: 03/08/2017

Time Sampled: 08:02

Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg K Nurse Sink- L

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0385

Location ID: Lead in Schools

Lab # AB73376

Date Sampled: 03/08/2017

Time Sampled: 08:04


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg H East DF- M

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0386

Location ID: Lead in Schools

Lab # AB73377

Date Sampled: 03/08/2017

Time Sampled: 08:06


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg H Rm 84 DF- N

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0387

Location ID: Lead in Schools

Lab # AB73378

Date Sampled: 03/08/2017

Time Sampled: 08:08


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg G Rm 75 DF- O

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	3.4		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73379

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0388

Location ID: Lead in Schools

Date Sampled: 03/08/2017

Time Sampled: 08:10


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg G West DF- P

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0389

Location ID: Lead in Schools

Lab # AB73380

Date Sampled: 03/08/2017

Time Sampled: 08:12


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg E West DF- Q

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0390

Location ID: Lead in Schools

Lab # AB73381

Date Sampled: 03/08/2017

Time Sampled: 08:14


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg E Girls RR Sink- R

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0391

Location ID: Lead in Schools

Lab # AB73382

Date Sampled: 03/08/2017

Time Sampled: 08:16

Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg F West DF- S

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0392

Location ID: Lead in Schools

Lab # AB73383

Date Sampled: 03/08/2017

Time Sampled: 08:18


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg F Rm 61 DF- T

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0393

Location ID: Lead in Schools

Lab # AB73384

Date Sampled: 03/08/2017

Time Sampled: 08:20


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg J Cafe DF- U

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0394

Location ID: Lead in Schools

Lab # AB73385

Date Sampled: 03/08/2017

Time Sampled: 08:22


Date Received: 03/08/2017

Report Date: 04/13/2017

Location Description:

Hohokam Elem Bldg J Kitchen Sink- V

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.5		1.00	ug/L	1.0	04/07/2017


Authorized Signature
License #AZ0424