

Scottsdale Unified  
SCHOOL DISTRICT  
Pueblo Elementary School  
New Blueprint Work Up  
TMA Systems Sep 18, 2009



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0496

Location ID: Lead in Schools

Lab # AB73237

Date Sampled: 03/07/2017

Time Sampled: 06:10

Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg A RM-A1 Kinder Sink- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.3		1.00	ug/L	1.0	04/06/2017

Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0497

Location ID: Lead in Schools

Lab # AB73238

Date Sampled: 03/07/2017

Time Sampled: 06:12

Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg A RM-A2 Kinder Sink- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.6		1.00	ug/L	1.0	04/06/2017

Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0498

Location ID: Lead in Schools

Lab # AB73239

Date Sampled: 03/07/2017

Time Sampled: 06:14


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg F Nurse Sink- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424



**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** AH17-0499

**Location ID:** Lead in Schools

**Lab #** AB73240

**Date Sampled:** 03/07/2017

**Time Sampled:** 06:16


**Date Received:** 03/07/2017

**Report Date:** 04/12/2017

**Location Description:**

Pueblo Elem- Bldg F Kitchen Sink- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.2		1.00	ug/L	1.0	04/06/2017

  
**Authorized Signature**  
**License #**AZ0424





Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0500

Location ID: Lead in Schools

Lab # AB73241

Date Sampled: 03/07/2017

Time Sampled: 06:18


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg D P.E. DF- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424



**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

**Lab # AB73242**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** AH17-0501

**Location ID:** Lead in Schools

**Date Sampled:** 03/07/2017

**Time Sampled:** 06:20


**Date Received:** 03/07/2017

**Report Date:** 04/12/2017

**Location Description:**

Pueblo Elem- Bldg D Outdoor DF- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017

  
**Authorized Signature**  
**License #AZ0424**



**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** AH17-0502

**Location ID:** Lead in Schools

**Lab #** AB73243

**Date Sampled:** 03/07/2017

**Time Sampled:** 06:22


**Date Received:** 03/07/2017

**Report Date:** 04/12/2017

**Location Description:**

Pueblo Elem- Bldg C Outdoor DF 7a- G

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.1		1.00	ug/L	1.0	04/06/2017

  
**Authorized Signature**  
**License #AZ0424**





Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0503

Location ID: Lead in Schools

Lab # AB73244

Date Sampled: 03/07/2017

Time Sampled: 06:24


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg C Outdoor DF 9a- H

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	3.0		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73245

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Date Sampled: 03/07/2017

Time Sampled: 06:26

Date Received: 03/07/2017

Report Date: 04/12/2017


Sample ID: AH17-0504

Location Description:

Location ID: Lead in Schools

Pueblo Elem- Bldg E Library DF- I

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0505

Location ID: Lead in Schools

Lab # AB73246

Date Sampled: 03/07/2017

Time Sampled: 06:28


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg E Library Sink- J

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0506

Location ID: Lead in Schools

Lab # AB73247

Date Sampled: 03/07/2017

Time Sampled: 06:30


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg B RM-B7 Sink- K

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.4		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0507

Location ID: Lead in Schools

Lab # AB73248

Date Sampled: 03/07/2017

Time Sampled: 06:32


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Pueblo Elem- Bldg B RM-B5 Sink- L

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.5		1.00	ug/L	1.0	04/06/2017

  
Authorized Signature  
License #AZ0424