

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Cherokee Elementary School

Reported:  
06/30/17 12:29

## Analyte

**1 Confirmation- First Draw (7062543-01) Drinking Water (Grab) Sampled: 06/19/17 05:58 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	18	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 20:08	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**2 Confirmation- Flush (7062543-02) Drinking Water (Grab) Sampled: 06/19/17 06:00 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 20:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**3 Confirmation - First Draw Day Two (7062543-03) Drinking Water (Grab) Sampled: 06/20/17 05:39 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 20:38	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**4 Screening (7062543-04) Drinking Water (Grab) Sampled: 06/19/17 06:03 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 20:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**5 Screening (7062543-05) Drinking Water (Grab) Sampled: 06/19/17 06:04 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 20:45	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**6 Screening (7062543-06) Drinking Water (Grab) Sampled: 06/19/17 06:07 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 20:49	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**7 Screening (7062543-07) Drinking Water (Grab) Sampled: 06/19/17 06:09 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 4

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Cherokee Elementary School

Reported:  
06/30/17 12:29

**7 Screening (7062543-07) Drinking Water (Grab) Sampled: 06/19/17 06:09 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 20:52	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**8 Screening (7062543-08) Drinking Water (Grab) Sampled: 06/19/17 06:16 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	12	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 20:55	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**9 Screening (7062543-09) Drinking Water (Grab) Sampled: 06/19/17 06:17 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	94	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 21:05	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**10 Screening (7062543-10) Drinking Water (Grab) Sampled: 06/19/17 06:24 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	8.3	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 21:09	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**11 Screening (7062543-11) Drinking Water (Grab) Sampled: 06/19/17 06:26 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	14	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 21:12	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**12 Screening (7062543-12) Drinking Water (Grab) Sampled: 06/19/17 06:27 Received: 06/28/17 08:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	6.2	5.0	ug/L	1	B7F1836	06/28/17 15:30	06/28/17 21:15	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**Sample Condition Upon Receipt:**

Temperature: 26.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.

All samples were analyzed on a "wet" basis unless designated as "dry weight".

---

**Notes and Definitions**

7062543

**Sample Collector Name and Phone Number:**

[illegible]

# RUSH

7/6/17