






BUILDING "500"




BUILDING "400"



BUILDING "300"



BUILDING "100"



BUILDING "CP"

BUILDING "200"



Scottsdale *Unified*
SCHOOL DISTRICT
Laguna Elementary School
New Blueprint Work Up
TMA Systems July 14, 2009



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0467

Location ID: Lead in Schools

Lab # AB73182

Date Sampled: 03/06/2017

Time Sampled: 07:20

Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 200 Kitchen Sink- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	13.7		1.00	ug/L	1.0	04/06/2017

A handwritten signature in black ink, appearing to read "Chizch", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0468

Location ID: Lead in Schools

Lab # AB73183

Date Sampled: 03/06/2017

Time Sampled: 07:22

Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 100 DF- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.1		1.00	ug/L	1.0	04/06/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0469

Location ID: Lead in Schools

Lab # AB73184

Date Sampled: 03/06/2017

Time Sampled: 07:24

Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 300 DF- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	5.0		1.00	ug/L	1.0	04/06/2017

A handwritten signature in black ink, appearing to read "C. Liza", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0470

Location ID: Lead in Schools

Lab # AB73185

Date Sampled: 03/06/2017

Time Sampled: 07:26

Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 500 Nurse DF- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.2		1.00	ug/L	1.0	04/06/2017

A handwritten signature in black ink, appearing to read "C. Lopez", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0471

Location ID: Lead in Schools

Lab # AB73186

Date Sampled: 03/06/2017

Time Sampled: 07:28


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 400 PreK 404 Sink- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	3.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73187

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Date Sampled: 03/06/2017

Time Sampled: 07:30

Date Received: 03/06/2017

Report Date: 04/12/2017

Sample ID: AH17-0472

Location Description:

Location ID: Lead in Schools

Laguna- Bldg 400 PreK 401 Sink- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.2		1.00	ug/L	1.0	04/06/2017

A handwritten signature in black ink, appearing to read "Chizuh", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0473

Location ID: Lead in Schools

Lab # AB73188

Date Sampled: 03/06/2017

Time Sampled: 07:32


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 200 Cafeteria DF- G

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0474

Location ID: Lead in Schools

Lab # AB73189

Date Sampled: 03/06/2017

Time Sampled: 07:34


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 400 PreK 402 Sink- H

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	9.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0475

Location ID: Lead in Schools

Lab # AB73190

Date Sampled: 03/06/2017

Time Sampled: 07:36


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Laguna- Bldg 400 PreK 403 Sink- I

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	4.2		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424