

Scottsdale Unified
SCHOOL DISTRICT
Anasazi Elementary School
New Blueprint Work Up
TMA Systems July 20, 2009



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0460

Location ID: Lead in Schools

Lab # AB73175

Date Sampled: 03/06/2017

Time Sampled: 06:45


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Anasazi- Bldg B Nurse Sink- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73176

Date Sampled: 03/06/2017

Time Sampled: 06:47

Date Received: 03/06/2017

Report Date: 04/12/2017


Sample ID: AH17-0461

Location Description:

Location ID: Lead in Schools

Anasazi- Bldg A DF- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0462

Location ID: Lead in Schools

Lab # AB73177

Date Sampled: 03/06/2017

Time Sampled: 06:49


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Anasazi- Bldg G Kitchen Sink- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.9		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73178

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0463

Location ID: Lead in Schools

Date Sampled: 03/06/2017

Time Sampled: 06:51


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Anasazi- Bldg F RM606 DF- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0464

Location ID: Lead in Schools

Lab # AB73179

Date Sampled: 03/06/2017

Time Sampled: 06:53


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Anasazi- Bldg E RM507 DF- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0465

Location ID: Lead in Schools

Lab # AB73180

Date Sampled: 03/06/2017

Time Sampled: 06:55


Date Received: 03/06/2017

Report Date: 04/12/2017

Location Description:

Anasazi- Bldg D P.E. DF- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73181

Krystal Heyer

Date Sampled: 03/06/2017

City of Scottsdale

Time Sampled: 06:57

8787 E. Hualapai Drive

Date Received: 03/06/2017

Scottsdale, AZ 85255

Report Date: 04/12/2017


Sample ID: AH17-0466

Location Description:

Location ID: Lead in Schools

Anasazi- Bldg C RM304 DF- G

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424