


PHASE 2 (Day 1)

8 MAY 2017



Desert Arroyo Middle School

CAVE CREEK UNIFIED SCHOOL DISTRICT No. 93

□ = 1 min Flush

105,896 sqft

Built 1989-2000



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1087

Location ID: Lead in Schools

Lab # AB75049

Date Sampled: 05/08/2017

Time Sampled: 06:00

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM408- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	9.5		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to be "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1088

Location ID: Lead in Schools

Lab # AB75050

Date Sampled: 05/08/2017

Time Sampled: 06:02

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM408 Flush- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.2		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to be "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB75051

Date Sampled: 05/08/2017

Time Sampled: 06:04

Date Received: 05/08/2017

Report Date: 05/19/2017

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1089

Location ID: Lead in Schools

Location Description:

D.A.- Bldg 400 RM408 Mens RR Sink- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	4.4		1.00	ug/L	1.0	05/17/2017

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1090

Location ID: Lead in Schools

Lab # AB75052

Date Sampled: 05/08/2017

Time Sampled: 06:06

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 400 RM408 Girls RR Sink- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	3.7		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1091

Location ID: Lead in Schools

Lab # AB75053

Date Sampled: 05/08/2017

Time Sampled: 06:08

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM402 Sink1- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	26.8		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1092

Location ID: Lead in Schools

Lab # AB75054

Date Sampled: 05/08/2017

Time Sampled: 06:10

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM402 Sink2- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	21.5		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to read "Cheryl", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1093

Location ID: Lead in Schools

Lab # AB75055

Date Sampled: 05/08/2017

Time Sampled: 06:12

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM402 Sink3- G

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	28.9		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to be "C. Lopez", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1094

Location ID: Lead in Schools

Lab # AB75056

Date Sampled: 05/08/2017

Time Sampled: 06:14

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM402 Sink4- H

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	34.0		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to be "C. Lopez", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1095

Location ID: Lead in Schools

Lab # AB75057

Date Sampled: 05/08/2017

Time Sampled: 06:16


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM402 Sink5- I

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	32.2		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1096

Location ID: Lead in Schools

Lab # AB75058

Date Sampled: 05/08/2017

Time Sampled: 06:18

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 RM402 Sink6- J

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	67.8		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to be "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1097

Location ID: Lead in Schools

Lab # AB75059

Date Sampled: 05/08/2017

Time Sampled: 06:20

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 Mens RR Sink- K

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	6.1		1.00	ug/L	1.0	05/17/2017

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1098

Location ID: Lead in Schools

Lab # AB75060

Date Sampled: 05/08/2017

Time Sampled: 06:22

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 400 Girls RR Sink- L

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	15.4		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1099

Location ID: Lead in Schools

Lab # AB75061

Date Sampled: 05/08/2017

Time Sampled: 06:24

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Kitchen Prep Sink- M

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	315	D2	1.00	ug/L	1.0	05/17/2017

Data Qualifiers

D2 = Sample required dilution due to high concentration of target analyte.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1100

Location ID: Lead in Schools

Lab # AB75062

Date Sampled: 05/08/2017

Time Sampled: 06:26


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Kitchen Prep Sink Flush- N

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.2		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB75063

Krystal Heyer

Date Sampled: 05/08/2017

City of Scottsdale

Time Sampled: 06:28

8787 E. Hualapai Drive

Date Received: 05/08/2017

Scottsdale, AZ 85255

Report Date: 05/19/2017


Sample ID: AH17-1101

Location Description:

Location ID: Lead in Schools

Desert Arroyo- Bldg 600 Kitchen RR Sink- O

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	15.7		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1102

Location ID: Lead in Schools

Lab # AB75064

Date Sampled: 05/08/2017

Time Sampled: 06:30


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 600 RM608 RR Sink- P

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	146		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1103

Location ID: Lead in Schools

Lab # AB75065

Date Sampled: 05/08/2017

Time Sampled: 06:32

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 600 RM606 Sink- Q

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	9.0		1.00	ug/L	1.0	05/17/2017

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1104

Location ID: Lead in Schools

Lab # AB75066

Date Sampled: 05/08/2017

Time Sampled: 06:34

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Hallway Girls RR Sink- R

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1105

Location ID: Lead in Schools

Lab # AB75067

Date Sampled: 05/08/2017

Time Sampled: 06:36


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Hallway Mens RR Sink- S

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	3.6		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1106

Location ID: Lead in Schools

Lab # AB75068

Date Sampled: 05/08/2017

Time Sampled: 06:38

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 600 Nurse Sink- T

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	27.9		1.00	ug/L	1.0	05/17/2017

A handwritten signature in cursive script, appearing to read "Krystal Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1107

Location ID: Lead in Schools

Lab # AB75069

Date Sampled: 05/08/2017

Time Sampled: 06:40

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Womens Locker Sink1- U

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	43.3		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1108

Location ID: Lead in Schools

Lab # AB75070

Date Sampled: 05/08/2017

Time Sampled: 06:42

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Womens Locker Sink2- V

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	46.5		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1109

Location ID: Lead in Schools

Lab # AB75071

Date Sampled: 05/08/2017

Time Sampled: 06:44

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Girls LR Coach RR Sink- W

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	153		1.00	ug/L	1.0	05/17/2017

A handwritten signature in blue ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1110

Location ID: Lead in Schools

Lab # AB75072

Date Sampled: 05/08/2017

Time Sampled: 06:46


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Womens Locker DF- X

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1111

Location ID: Lead in Schools

Lab # AB75073

Date Sampled: 05/08/2017

Time Sampled: 06:48


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Womens Locker Sink3- Y

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	4.1		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB75074

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1112

Location ID: Lead in Schools

Date Sampled: 05/08/2017

Time Sampled: 06:50


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Womens Locker Sink4- Z

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	6.8		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB75075

Krystal Heyer

Date Sampled: 05/08/2017

City of Scottsdale

Time Sampled: 06:52

8787 E. Hualapai Drive

Date Received: 05/08/2017

Scottsdale, AZ 85255

Report Date: 05/19/2017

Sample ID: AH17-1113

Location Description:

Location ID: Lead in Schools

Desert Arroyo- Bldg 600 Gym DF1- AA

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.7		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1114

Location ID: Lead in Schools

Lab # AB75076

Date Sampled: 05/08/2017

Time Sampled: 06:54

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 600 Gym DF2- AB

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.9		1.00	ug/L	1.0	05/17/2017

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1115

Location ID: Lead in Schools

Lab # AB75077

Date Sampled: 05/08/2017

Time Sampled: 06:56

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 600 Gym DF3- AC

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.4		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to be "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1116

Location ID: Lead in Schools

Lab # AB75078

Location Description:

Desert Arroyo- Bldg 600 Gym DF4- AD


Date Sampled: 05/08/2017

Time Sampled: 06:58

Date Received: 05/08/2017

Report Date: 05/19/2017

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.3		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1117

Location ID: Lead in Schools

Lab # AB75079

Date Sampled: 05/08/2017

Time Sampled: 07:00

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

Desert Arroyo- Bldg 600 Boys Locker DF- AI

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.4		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1118

Location ID: Lead in Schools

Lab # AB75080

Date Sampled: 05/08/2017

Time Sampled: 07:02


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Boys Locker Sink1- AF

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	7.8		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1119

Location ID: Lead in Schools

Lab # AB75081

Date Sampled: 05/08/2017

Time Sampled: 07:04


Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A. - Bldg 600 Boys Locker Sink2- AG

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	8.3		1.00	ug/L	1.0	05/17/2017



Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1120

Location ID: Lead in Schools

Lab # AB75082

Date Sampled: 05/08/2017

Time Sampled: 07:06

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A- Bldg 600 Boys LR Coach RR Sink- AH

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	41.6		1.00	ug/L	1.0	05/17/2017

Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-1121

Location ID: Lead in Schools

Lab # AB75083

Date Sampled: 05/08/2017

Time Sampled: 07:08

Date Received: 05/08/2017

Report Date: 05/19/2017

Location Description:

D.A.- Bldg 600 Boys Locker Sink3- Al

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	46.7		1.00	ug/L	1.0	05/17/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

Authorized Signature
License #AZ0424