

Desert Arroyo Middle School  
 CAVE CREEK UNIFIED SCHOOL DISTRICT No. 93

105,896 sqft  
 Built 1989-2000



**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** SW17-0560

**Location ID:** Lead in Schools

**Lab #** AB73899

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:10

**Date Received:** 03/27/2017

**Report Date:** 04/11/2017

**Location Description:**

Desert Arroyo Middle- Bldg400 DF- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	17.3		1.00	ug/L	1.0	04/07/2017

  
**Authorized Signature**  
**License #**AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

## - CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** SW17-0561

**Location ID:** Lead in Schools

**Lab #** AB73900

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:12


**Date Received:** 03/27/2017

**Report Date:** 04/11/2017

**Location Description:**

Desert Arroyo Middle- Bldg300 DF- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	8.4		1.00	ug/L	1.0	04/07/2017

  
Authorized Signature  
License #AZ0424



**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

**Lab # AB73901**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** SW17-0562

**Location ID:** Lead in Schools

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:14


**Date Received:** 03/27/2017

**Report Date:** 04/11/2017

**Location Description:**

Desert Arroyo Middle- Bldg200 DF- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	8.2		1.00	ug/L	1.0	04/07/2017

  
**Authorized Signature**  
**License #AZ0424**



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73902

Date Sampled: 03/27/2017

Time Sampled: 07:16

Date Received: 03/27/2017

Report Date: 04/11/2017


Sample ID: SW17-0563

Location Description:

Location ID: Lead in Schools

Desert Arroyo Middle- Bldg600 Kitchen Prep

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	104		1.00	ug/L	1.0	04/07/2017

  
Authorized Signature  
License #AZ0424



**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

**Lab # AB73903**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:18

**Date Received:** 03/27/2017

**Report Date:** 04/11/2017


**Sample ID:** SW17-0564

**Location Description:**

**Location ID:** Lead in Schools

Desert Arroyo Middle- Bldg100 Nurse Sink- I

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017

  
**Authorized Signature**  
**License #AZ0424**





**Water Quality Laboratory**

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

**Lab # AB73904**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** SW17-0565

**Location ID:** Lead in Schools

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:20


**Date Received:** 03/27/2017

**Report Date:** 04/11/2017

**Location Description:**

Desert Arroyo Middle- Bldg500 Library- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	7.8		1.00	ug/L	1.0	04/07/2017

  
**Authorized Signature**  
**License #AZ0424**