

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Desert Willow

Reported:  
04/27/17 15:20

## Analyte

003770 (7042237-01) Drinking Water (Grab) Sampled: 04/20/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 16:14	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

003829 (7042237-02) Drinking Water (Grab) Sampled: 04/20/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 12:26	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

003860 (7042237-03) Drinking Water (Grab) Sampled: 04/20/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 12:30	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

003767 (7042237-04) Drinking Water (Grab) Sampled: 04/20/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 12:34	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

## Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

## Case Narrative:

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

Legend Technical Services of Arizona, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

*Anna Teter*

Client Services Representative

Phone Number: (602) 324-6100

Page 1 of 6

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Desert Willow

**Reported:**  
04/27/17 15:20

---

### Notes and Definitions

---

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log


7042237

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Desert Willow
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Outside hallway fountain
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	003329 -02
Date of Collection	4-20-17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Mike Santine
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.


picked up from  
City of PHX 4/24/17  
@ lab 1145

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Desert Willow
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Outside by playground kitchen
Sample Identification Number (Write this number on the sample container and on this sheet)	003860 -03
Date of Collection	4.20.17
Time of Collection	7:00 AM
Printed Name of Sample Collector	M. Santana
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042237

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)  
Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Cave Creek USD 93
Desert Willow
1004
Fountain
Multipurpose Room
003767
-04
4.20.17
7:00 AM
M. K. Santos
[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from  
City of PHX 4/24/17  
OS Lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042237

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Desert Willow
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Lounge sink - kitchen
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	003170 -01
Date of Collection	4-20-17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Mike Santina
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

picked up from  
City of PHX 4/24/17  
@ lab H45