

Desert Sun Academy  
CAVE CREEK UNIFIED SCHOOL DISTRICT No. 93

69,053 sqft  
Built 2000



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** SW17-0566

**Location ID:** Lead in Schools

**Lab #** AB73905

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:30

**Date Received:** 03/27/2017

**Report Date:** 04/13/2017

**Location Description:**

Desert Sun Academy- B100 Nurse Sink-A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017

A handwritten signature in black ink, appearing to be "C. Lopez", is written over a horizontal line.

Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0567

Location ID: Lead in Schools

Lab # AB73906

Date Sampled: 03/27/2017

Time Sampled: 07:32

Date Received: 03/27/2017

Report Date: 04/13/2017

Location Description:

Desert Sun Academy- Bldg200 RM205- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017

A handwritten signature in black ink, appearing to read "C. Lopez", is written over a horizontal line.

Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0568

Location ID: Lead in Schools

Lab # AB73907

Date Sampled: 03/27/2017

Time Sampled: 07:34

Date Received: 03/27/2017

Report Date: 04/13/2017

Location Description:

Desert Sun Academy- Bldg300 RM306- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017

A handwritten signature in black ink, appearing to read "Cheryl", is written over a horizontal line.

Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0569

Location ID: Lead in Schools

Lab # AB73908

Date Sampled: 03/27/2017

Time Sampled: 07:36

Date Received: 03/27/2017

Report Date: 04/13/2017

Location Description:

Desert Sun Academy- Bldg400 RR- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.6		1.00	ug/L	1.0	04/07/2017

A handwritten signature in black ink, appearing to read "C. H. Zah", is written over a horizontal line.

Authorized Signature  
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: SW17-0570

Location ID: Lead in Schools

Lab # AB73909

Date Sampled: 03/27/2017

Time Sampled: 07:38


Date Received: 03/27/2017

Report Date: 04/13/2017

Location Description:

Desert Sun Academy- Bldg500 RM508- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017

  
\_\_\_\_\_  
Authorized Signature  
License #AZ0424





Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

**- CERTIFICATE OF ANALYSIS -**

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

**Sample ID:** SW17-0571

**Location ID:** Lead in Schools

**Lab #** AB73910

**Date Sampled:** 03/27/2017

**Time Sampled:** 07:40

**Date Received:** 03/27/2017

**Report Date:** 04/13/2017

**Location Description:**

Desert Sun Academy- Bldg600 RR- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/07/2017

A handwritten signature in black ink, appearing to read "C. Heyer", is written over a horizontal line.

**Authorized Signature**  
**License #AZ0424**



Water Quality Laboratory

8787 E. Hualapai Dr.  
PO Box 25089  
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Lab # AB73911

Date Sampled: 03/27/2017

Time Sampled: 07:42

Date Received: 03/27/2017

Report Date: 04/13/2017

Sample ID: SW17-0572

Location Description:

Location ID: Lead in Schools

Desert Sun Academy- B700 Kitchen Prep-G

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	2.3		1.00	ug/L	1.0	04/07/2017

A handwritten signature in black ink, appearing to read "C. Lopez", is written over a horizontal line.

Authorized Signature  
License #AZ0424