

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Lone Mountain

Reported:
04/26/17 14:14

Analyte

003743 (7042235-01) Drinking Water (Grab) Sampled: 04/20/17 06:45 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 16:02	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003791 (7042235-02) Drinking Water (Grab) Sampled: 04/20/17 06:45 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 16:04	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003930 (7042235-03) Drinking Water (Grab) Sampled: 04/20/17 06:45 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 16:07	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003896 (7042235-04) Drinking Water (Grab) Sampled: 04/20/17 06:45 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 16:09	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003796 (7042235-05) Drinking Water (Grab) Sampled: 04/20/17 06:45 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 16:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042235

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek Unified 93
School Name	Lone Mountain
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Adjacent to base w. side of Multipurpose
Sample Identification Number (Write this number on the sample container and on this sheet)	003743 -01
Date of Collection	4/20/17
Time of Collection	6:45 AM
Printed Name of Sample Collector	Mike Santana
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Picked up
from City of PHX
4/24/17 @lab 114
Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


Collection Log

for experienced sample collectors

7042235

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek Unified 93
School Name	Lone Mountain
Building (name/number)	1001 1001
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	East side of multi-purpose library
Sample Identification Number (Write this number on the sample container and on this sheet)	003791 -02
Date of Collection	4/20/17
Time of Collection	6:45 AM
Printed Name of Sample Collector	Mike Santino
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance

<http://www.azdeq.gov/LeadScreeningProg>

Picked up
from city of
PHX 4/24/17
@ lab 1145
Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042235

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Lone Mountain
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	lower floor by restrooms
Sample Identification Number (Write this number on the sample container and on this sheet)	603930 -03
Date of Collection	4-20-17
Time of Collection	6:45 Am
Printed Name of Sample Collector	M. G. Santina
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from
City of PHX
4/24/17 @ 1a
1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


Collection Log
for experienced sample collectors

7042235

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Cave Creek USD 93	
Lone Mountain	
1004	
Fountain	
kgarden	
003896	-04
4-20-17	
6:45 AM	
Mike Santina	
	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up
from City of PH
4/24/17 @ lab
1145

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


Collection Log
for experienced sample collectors

7042235

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Cave Creek USD 93	
Lone Mountain	
1005	
Fountain	
Admin Lobby	
003796	-05
4-20-17	
6:45 AM	
M. S. Atkins	
	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
70.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from
City of PHX 4/24
@ lab 1145