

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Horseshoe Trails

Reported:
04/27/17 15:51

Analyte

003798 (7042239-01) Drinking Water (Grab) Sampled: 04/21/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 13:19	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003832 (7042239-02) Drinking Water (Grab) Sampled: 04/21/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 13:23	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003792 (7042239-03) Drinking Water (Grab) Sampled: 04/21/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 13:27	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003902 (7042239-04) Drinking Water (Grab) Sampled: 04/21/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 13:31	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003866 (7042239-05) Drinking Water (Grab) Sampled: 04/21/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 13:35	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

003764 (7042239-06) Drinking Water (Grab) Sampled: 04/21/17 07:00 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1657	04/25/17 10:40	04/25/17 13:38	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 8

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


704 2239

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Horseshoe Trails
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	K4
Sample Identification Number (Write this number on the sample container and on this sheet)	003832 02
Date of Collection	4.21.17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Mike Santias
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from
City of PHX 4/24/17
@lab 1145


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

70422391

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Horseshoe Trails
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Hallway Southern
Sample Identification Number (Write this number on the sample container and on this sheet)	003792 -03
Date of Collection	4.21.17
Time of Collection	7:00
Printed Name of Sample Collector	Mike Santina
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from
City of PHX 4/24/17
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042239

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Horseshoe Trails
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Library
Sample Identification Number (Write this number on the sample container and on this sheet)	003902 -04
Date of Collection	4.21.17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Melissa Santine
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from
City of PHX 4/24/17
@ Lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

70422391

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Horseshoe Trails
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	Multipurpose
Location of Fixture (example, room number)	Fountain
Sample Identification Number (Write this number on the sample container and on this sheet)	003866
Date of Collection	4.21.17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Nicole Santiago
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
20.0°C	

For relinquishing samples upon delivery to labs only
Relinquished date and signature

picked up from
City of PHX 4/24/17
@ 10:15 AM

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


Collection Log

for experienced sample collectors

70422381

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	Horseshoe Trails
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Central Plant
Sample Identification Number (Write this number on the sample container and on this sheet)	003764 -06
Date of Collection	4.21.17
Time of Collection	7:45 AM
Printed Name of Sample Collector	Mike Sattina
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from
City of PHX 4/24/17
@ 10:11:45

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042239

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Cave Creek USD 93
School Name	HTE Horseshoe Trails
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Administration
Sample Identification Number (Write this number on the sample container and on this sheet)	003798 -01
Date of Collection	4-21-17
Time of Collection	7:00 AM
Printed Name of Sample Collector	M. S. Santos
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from
City of PHX 4/24/17
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2