

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Paseo Hills Elementary

Reported:  
05/01/17 10:17

Analyte

**PH-1 (7042290-01) Drinking Water (Grab) Sampled: 04/21/17 04:00 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 16:29	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-2 (7042290-02) Drinking Water (Grab) Sampled: 04/21/17 04:03 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:00	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-3 (7042290-03) Drinking Water (Grab) Sampled: 04/21/17 04:05 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:04	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-4 (7042290-04) Drinking Water (Grab) Sampled: 04/21/17 04:08 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:07	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-5 (7042290-05) Drinking Water (Grab) Sampled: 04/21/17 04:11 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:11	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-6 (7042290-06) Drinking Water (Grab) Sampled: 04/21/17 04:15 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:15	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-7 (7042290-07) Drinking Water (Grab) Sampled: 04/20/17 04:16 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Legend Technical Services of Arizona, Inc.



Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

**PH-7 (7042290-07) Drinking Water (Grab) Sampled: 04/20/17 04:16 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:26	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**PH-8 (7042290-08) Drinking Water (Grab) Sampled: 04/21/17 04:20 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1725	04/26/17 13:05	04/26/17 17:30	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**Sample Condition Upon Receipt:**

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted. All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

**Notes and Definitions**

7042290-01

ADEQ Public School Drinking Water Lead Screening Program  
 Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1001 Admin/Meeting/CR
Type of Fixture (tap, drinking fountain etc.)	Fountain Tap
Location of Fixture (example, room number)	Lounge
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-1
Date of Collection	4/21/17
Time of Collection	4:00 am
Printed Name of Sample Collector	Daniel Miller
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C      Received @ lab      4/24/17      1600	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

✓      Presented @ Lab      4/25/17      1410

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042290-02

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1002 Class room
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	122
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-2
Date of Collection	4/21/17
Time of Collection	4:03 pm
Printed Name of Sample Collector	Daniel Merlin
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ lab 4/24/17 1600

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ lab 4/25/17  
1410

7042290-03

ADEQ Public School Drinking Water Lead Screening Program  
 Sampling Plan & Collection Log

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1003 Class room 3
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	218
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-3
Date of Collection	4/21/17
Time of Collection	4:05
Printed Name of Sample Collector	Daniel Mart
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C Received @ lab 4/24/17 1600

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

*Presented @ Lab 4/25/17 1410*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042290-04

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1001 Classroom 3
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Breakway
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-4
Date of Collection	4/21/17
Time of Collection	4:08 AM
Printed Name of Sample Collector	Daniel Martin
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C Received @ lab 4/24/17 1400

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

Presw-D @ Lab 4/25/17 1410

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042290-05

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1005 CLASS ROOM 4
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	300
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-5
Date of Collection	4/21/17
Time of Collection	4:11
Printed Name of Sample Collector	Daniel Math
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ lab 4/24/17 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

*Resend @ lab 4/25/17 1410*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042290-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1006 Cafe / Kit
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Cafe
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-6
Date of Collection	4/2/17
Time of Collection	4:15
Printed Name of Sample Collector	Daniel Mox
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ lab 4/24/17 1600
20.0 °C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

Reserved @ lab 4/25/17 1410

ADEQ Public School Drinking Water Lead Screening Program  
 Sampling Plan & Collection Log

7042290-07

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1007 Classroom 5
Type of Fixture (tap, drinking fountain etc.)	Tap
Location of Fixture (example, room number)	30500
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-7
Date of Collection	4/20/17
Time of Collection	4:10pm
Printed Name of Sample Collector	Daniel
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ lab 4/24/17 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

Present @ lab 4/25/17 1410

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042290-08

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Deer Valley Unified District
School Name	Paseo Hills Elementary
Building (name/number)	1008 Classrooms
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	1261a
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	PH-8
Date of Collection	4/11/17
Time of Collection	4:20 am
Printed Name of Sample Collector	Daniel Maito
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ lab 4/25/17 1400
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented @ lab 4/25/17  
1410

7042290

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Deer Valley Unified District	Paseo Hills Elementary	1001	Admin/Media/CR	Admin/Media/CR	1998	PH1 1
Deer Valley Unified District	Paseo Hills Elementary	1002	Classroom	Classroom	1998	PH-2 1
Deer Valley Unified District	Paseo Hills Elementary	1003	Classroom 2	Classroom 2 <sup>2,3</sup>	1998	PH-3 1
Deer Valley Unified District	Paseo Hills Elementary	1004	Classroom 3	Classroom 3	1998	PH-4 1
Deer Valley Unified District	Paseo Hills Elementary	1005	Classroom 4	Classroom 4	1998	PH-5 1
Deer Valley Unified District	Paseo Hills Elementary	1006	Cafe/Kit	Cafe/Kit	1998	PH-6 1
Deer Valley Unified District	Paseo Hills Elementary	1007	Classroom 5 (new DC space)	Classrooms	2003	PH-7 1
Deer Valley Unified District	Paseo Hills Elementary	1008	Classroom 5 (Replacement space)	Classrooms	2003	PH-8 1
Deer Valley Unified District	Paseo Hills Elementary	1009	Classroom 6 (Replacement space)	Classrooms	2003	? 6 1
Address:					Number of Bottles Per Kit:	9



