

David A. Burchard  
Arizona Department of Environmental Quality,  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Alta Butler Elementary

Reported:  
04/26/17 14:03

## Analyte

**Butler 1001-05 (7042224-01) Drinking Water (Grab) Sampled: 04/13/17 04:33 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1001-06 (7042224-02) Drinking Water (Grab) Sampled: 04/13/17 04:35 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1002-03 (7042224-03) Drinking Water (Grab) Sampled: 04/13/17 04:27 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1002-04 (7042224-04) Drinking Water (Grab) Sampled: 04/13/17 04:29 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	6.3	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:23	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**Butler 1003-01 (7042224-05) Drinking Water (Grab) Sampled: 04/13/17 04:19 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	15	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:25	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**Butler 1003-02 (7042224-06) Drinking Water (Grab) Sampled: 04/13/17 04:22 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	14	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:28	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**Butler 1004-07 (7042224-07) Drinking Water (Grab) Sampled: 04/13/17 04:38 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

**Butler 1004-07 (7042224-07) Drinking Water (Grab) Sampled: 04/13/17 04:38 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1004-08 (7042224-08) Drinking Water (Grab) Sampled: 04/13/17 04:40 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:33	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1005-09 (7042224-09) Drinking Water (Grab) Sampled: 04/13/17 04:43 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1640	04/24/17 17:00	04/25/17 13:35	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1005-10 (7042224-10) Drinking Water (Grab) Sampled: 04/13/17 04:47 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 13:55	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1006-11 (7042224-11) Drinking Water (Grab) Sampled: 04/13/17 04:50 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 13:57	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1006-12 (7042224-12) Drinking Water (Grab) Sampled: 04/13/17 04:54 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	9.4	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:00	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**Butler 1007-14 (7042224-13) Drinking Water (Grab) Sampled: 04/13/17 05:04 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	7.6	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:02	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**Butler 1007-15 (7042224-14) Drinking Water (Grab) Sampled: 04/13/17 05:06 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard  
Arizona Department of Environmental Quality,  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Alta Butler Elementary

Reported:  
04/26/17 14:03

**Butler 1007-15 (7042224-14) Drinking Water (Grab) Sampled: 04/13/17 05:06 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:05	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1008-16 (7042224-15) Drinking Water (Grab) Sampled: 04/13/17 05:08 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	16	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:07	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**Butler 1008-17 (7042224-16) Drinking Water (Grab) Sampled: 04/13/17 05:11 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1009-19 (7042224-17) Drinking Water (Grab) Sampled: 04/13/17 05:20 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1009-21 (7042224-18) Drinking Water (Grab) Sampled: 04/13/17 05:27 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1010-13 (7042224-19) Drinking Water (Grab) Sampled: 04/13/17 05:00 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:22	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1011-18 (7042224-20) Drinking Water (Grab) Sampled: 04/13/17 05:16 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1012-20 (7042224-21) Drinking Water (Grab) Sampled: 04/13/17 05:25 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard  
Arizona Department of Environmental Quality,  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Alta Butler Elementary

Reported:  
04/26/17 14:03

**Butler 1012-20 (7042224-21) Drinking Water (Grab) Sampled: 04/13/17 05:25 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Butler 1016-22 (7042224-22) Drinking Water (Grab) Sampled: 04/13/17 05:33 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:35	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Sample Condition Upon Receipt:**

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted. All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

**Notes and Definitions**

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1001 - Kitchen/Cafe
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Kitchen - food prep area
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1001 - 05
Date of Collection	4/13/17
Time of Collection	4:33 AM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

4/13/17  
picked up from City  
of Phx 4124117  
@ lab 1145  
Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

2

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1001 - Kitchen/Cafe
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	cafeteria-east
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1001 - 06
Date of Collection	4/13/17
Time of Collection	4:35 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

102

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*[Signature]* 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from City  
of PHX 4/24/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

3

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1002 - Bldg B - Classrooms
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Rm 503
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1002 - 03
Date of Collection	4/13/17
Time of Collection	4:27 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	Krista Wahnefried

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from  
city of PHX 4/24/17  
@lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1002 - Bldg B - Classrooms
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Rm 603
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1002
Date of Collection	4/13/17
Time of Collection	4:29 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

5

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1003 - Bldg C - offices/class
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Nurse office
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1003 - 01 - 05
Date of Collection	4/13/17
Time of Collection	4:19 am
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from  
City of BtX 4/24/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1003 - Bldg C - offices/class
Type of Fixture (tap, drinking fountain etc.)	SVLK
Location of Fixture (example, room number)	Rm 1
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1003 - 02 - 06
Date of Collection	4/13/17
Time of Collection	4:22
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

4/13/17  
Picked up from  
City of PHX 4/24/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1004 - Bldg D - class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	outside in 200 extension
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1004 - 07
Date of Collection	4/13/17
Time of Collection	4:30 AM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

4/13/17  
Picked up from  
city of PHX 4/24/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

8

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1004 - Bldg D - class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain spigot in sink
Location of Fixture (example, room number)	Rm 104
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1004 - 08
Date of Collection	4/13/17
Time of Collection	4:40 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

4/13/17  
4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4/24/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

9

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1005 - Bldg E - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain spigot in sink
Location of Fixture (example, room number)	Rm 13
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1005 - 09 -09
Date of Collection	4/13/17
Time of Collection	4:45
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead

Date and Time Lab received

Signature

Notes:

20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4124117  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

10

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1005 - Bldg E - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain spigot in sink
Location of Fixture (example, room number)	Rm 12
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1005 - 10 -10
Date of Collection	4/13/17
Time of Collection	4:47
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from  
City of PHX 4/24/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

11

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1006 - Bldg F - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	exterior outside Rm 10
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1006 - 11 - 11
Date of Collection	4/13/17
Time of Collection	4:50
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from  
city of PHX 4124117  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

12

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1006 - Bldg F - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Rm 5
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1006 - 12
Date of Collection	4/13/17
Time of Collection	4:54
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead

Date and Time Lab received

Signature

Notes:

20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4124/17  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

13

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1007 - Bldg G - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain 3rd floor in sink
Location of Fixture (example, room number)	Rm 210
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1007 -14
Date of Collection	4/13/17
Time of Collection	2:00 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

-13

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead
Date and Time Lab received
Signature
Notes: 20.0 °C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*[Signature]* 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4124117  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

14

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1007 - Bldg G - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	exterior - outside room 24
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1007 - 15 -14
Date of Collection	4/13/17
Time of Collection	5:00 AM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*[Signature]* 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4124117  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

15

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1008 - Bldg H - Class
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm 27
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1008 - 16 -15
Date of Collection	4/13/17
Time of Collection	5:00 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0 °C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*[Signature]* 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 424117  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

16

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1008 - Bldg H - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	exterior outside rm 30
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1008 - 17
Date of Collection	4/13/17
Time of Collection	5:11 AM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*[Signature]* 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4/24/17  
@ lab 1145

<http://www.azdeg.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1009 - Bldg 1 - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain spigot in sink
Location of Fixture (example, room number)	Rm 32
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1009 - 19
Date of Collection	4/13/17
Time of Collection	5:20 AM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeg.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1009 - Bldg 1 - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	exterior outside rm 3
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1009 - 21 - 18
Date of Collection	4/13/17
Time of Collection	5:27
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1010 - Bldg J - Portable
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Portable Rm 43
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1010 - 13
Date of Collection	4/13/17
Time of Collection	5:00 AM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead

Date and Time Lab received

Signature

Notes:

20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Picked up from  
city of PHX 4124117  
@ lab 145

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1011 - Bldg K - Portable
Type of Fixture (tap, drinking fountain etc.)	3rd K
Location of Fixture (example, room number)	2nd K
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1011 - 18 -20
Date of Collection	4/13/17
Time of Collection	5:10
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from  
City of PHX 4/24/17  
@ lab 1145

<http://www.azdeg.gov/LeadScreeningProg>

Page 2 of 2



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042224

21

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1012 - Bldg L - Class
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Rm 39
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1012 - 20 - 21
Date of Collection	4/13/17
Time of Collection	5:25 am
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PHX 4124117  
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Alta Butler Elementary School
Building (name/number)	1016 - MPR
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	north entrance
Sample Identification Number (ensure this number is also on the sample container)	Butler - 1016 - 22 - 22
Date of Collection	4/13/17
Time of Collection	5:23 AM
Printed Name of Sample Collector	Krista Wannefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wannefried</i>

Notes Sample collector:

taller of the 2 fountains

For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature *[Signature]* 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from  
City of PTH 4/24/17  
@ lab 1145