

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: PT Coe Elementary School

Reported:
06/07/17 16:35

Analyte

1 Confirmation- First Draw (7060124-01) Drinking Water (Grab) Sampled: 05/31/17 04:43 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	26	5.0	ug/L	1	B7F1054	06/06/17 14:00	06/06/17 18:46	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

2 Confirmation - Flush (7060124-02) Drinking Water (Grab) Sampled: 05/21/17 04:46 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	9.7	5.0	ug/L	1	B7F1054	06/06/17 14:00	06/06/17 18:50	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

3 Confirmation - First Draw Day Two (7060124-03) Drinking Water (Grab) Sampled: 06/01/17 05:20 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	19	5.0	ug/L	1	B7F1054	06/06/17 14:00	06/06/17 18:53	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

4 Screening (7060124-04) Drinking Water (Grab) Sampled: 05/31/17 04:33 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	14	5.0	ug/L	1	B7F1054	06/06/17 14:00	06/06/17 18:57	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

5 Screening (7060124-05) Drinking Water (Grab) Sampled: 05/31/17 04:35 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1054	06/06/17 14:00	06/06/17 19:01	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

6 Screening (7060124-06) Drinking Water (Grab) Sampled: 05/31/17 04:36 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	13	5.0	ug/L	1	B7F1054	06/06/17 14:00	06/06/17 19:05	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

7 Screening (7060124-07) Drinking Water (Grab) Sampled: 05/31/17 04:39 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 4

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: PT Coe Elementary School

Reported:
06/07/17 16:35

7 Screening (7060124-07) Drinking Water (Grab) Sampled: 05/31/17 04:39 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	12	5.0	ug/L	1	B7F1055	06/06/17 14:03	06/06/17 19:35	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

8 Screening (7060124-08) Drinking Water (Grab) Sampled: 05/31/17 04:41 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.2	5.0	ug/L	1	B7F1055	06/06/17 14:03	06/06/17 19:39	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

9 Screening (7060124-09) Drinking Water (Grab) Sampled: 05/31/17 04:47 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	11	5.0	ug/L	1	B7F1055	06/06/17 14:03	06/06/17 19:43	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 25.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.

All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

7060124

Lead In Schools Confirmation Sampling Log					
School District: Isaac Elementary District					
School Name: P T Coe Elementary School					
Building Name/Number/Year Built: Building O					
Sample Collector Name and Phone Number: Krista Wannefried, Dominion - 628-510-1415					
Sample ID # (must appear on bottle)	Bottle Size	Fixture Type/ Make and model #	Fixture location	Collection Time	Collection Date
1 Confirmation - First Draw	250 ml	fountain	Rm 48	4:43 AM	5/31/17
2 Confirmation - Flush	250 ml	fountain	Rm 48	4:46	5/31/17
3 Confirmation - First Draw Day Two	1 Liter	fountain	Rm 48	5:20	6/1/17
4 Screening	250 ml	Fountain	Outside custodian closet	4:33	5/31/17
5 Screening	250 ml	Bubbler	Rm 44	4:35	5/31/17
6 Screening	250 ml	Bubbler	Rm 45	4:36	5/31/17
7 Screening	250 ml	Bubbler	Rm 46	4:39	5/31/17
8 Screening	250 ml	Bubbler	Rm 47	4:41	5/31/17
9 Screening	250 ml	Bubbler	Rm 49	4:47	5/31/17
<h1>RUSH</h1> <p>6/8/17</p>					
✓					

These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	6/11/17
RELINQUISHING AGENT SIGNATURE:	<i>Krista Wannafried</i>
SIGNATORY NAME PRINTED:	Krista Wannafried

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	6/11/17
TIME LAB RECEIVED:	16:00
LAB SIGNATURE:	<i>M. Shalby</i>
LAB SIGNATORY NAME PRINTED:	M. Shalby
NOTES:	25.00C RUSH