

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Moya Elementary School

Reported:
04/26/17 14:50

Analyte

Moya 1001-01 (7042229-01) Drinking Water (Grab) Sampled: 04/13/17 04:04 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 15:37	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

Moya 1002-02 (7042229-02) Drinking Water (Grab) Sampled: 04/13/17 04:06 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1653	04/25/17 09:34	04/25/17 15:40	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

Sample Condition Upon Receipt:

Temperature: 20.00 °C
All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.
QA/QC Criteria: All analyses met method requirements unless otherwise qualified.
Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.
Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

7042229


23

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Moya Elementary School
Building (name/number)	Building 1001
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Office restroom
Sample Identification Number (ensure this number is also on the sample container)	Moya - 1001 - 01 - 01
Date of Collection	4/13/17
Time of Collection	4:04 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature  4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

Picked up from
City of PHX 4/24/17
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042229

24

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Isaac School District
School Name	Moya Elementary School
Building (name/number)	Building 1002
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Outside Rm 17C
Sample Identification Number (ensure this number is also on the sample container)	Moya - 1002 - 02
Date of Collection	4/13/17
Time of Collection	4:00 PM
Printed Name of Sample Collector	Krista Wahnefried, Dominion Environmental
Signature Sample Collector	<i>Krista Wahnefried</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

[Signature] 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

picked up from
city of PHX 4/24/17
@ lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2