

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Desert View

Reported:
04/27/17 16:57

Analyte

D1004-01 (7042274-01) Drinking Water (Composite) Sampled: 04/13/17 05:10 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 20:45	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

D1004-02 (7042274-02) Drinking Water (Composite) Sampled: 04/13/17 05:12 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 20:49	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

F1006-03 (7042274-03) Drinking Water (Composite) Sampled: 04/13/17 05:16 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 20:53	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

F1006-04 (7042274-04) Drinking Water (Composite) Sampled: 04/13/17 05:22 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	19	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:04	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

H1008-05 (7042274-05) Drinking Water (Composite) Sampled: 04/13/17 05:25 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

H1008-06 (7042274-06) Drinking Water (Composite) Sampled: 04/13/17 05:30 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

G1007-07 (7042274-07) Drinking Water (Composite) Sampled: 04/13/17 05:32 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 22

G1007-07 (7042274-07) Drinking Water (Composite) Sampled: 04/13/17 05:32 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:16	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

G1007-08 (7042274-08) Drinking Water (Composite) Sampled: 04/13/17 05:35 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:20	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

I1009-09 (7042274-09) Drinking Water (Composite) Sampled: 04/13/17 05:40 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:23	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

I1009-10 (7042274-10) Drinking Water (Composite) Sampled: 04/13/17 05:42 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:27	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

E1005-11 (7042274-11) Drinking Water (Composite) Sampled: 04/13/17 05:46 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:39	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

E1005-12 (7042274-12) Drinking Water (Composite) Sampled: 04/13/17 05:47 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:50	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

A1001-13 (7042274-13) Drinking Water (Composite) Sampled: 04/13/17 05:50 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:54	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

A1001-14 (7042274-14) Drinking Water (Composite) Sampled: 04/13/17 05:51 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Desert View

Reported:
04/27/17 16:57

A1001-14 (7042274-14) Drinking Water (Composite) Sampled: 04/13/17 05:51 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 21:58	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

B1002-15 (7042274-15) Drinking Water (Composite) Sampled: 04/13/17 05:58 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 22:01	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

B1002-16 (7042274-16) Drinking Water (Composite) Sampled: 04/13/17 06:05 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 22:05	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-17 (7042274-17) Drinking Water (Composite) Sampled: 04/13/17 06:10 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.5	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 22:09	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1010-18 (7042274-18) Drinking Water (Composite) Sampled: 04/13/17 06:12 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1680	04/25/17 15:20	04/25/17 22:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.


Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling


Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	NORTH DOOR TO OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	D1004-01
Date of Collection	4-13-17
Time of Collection	0510
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C Picked up from City of PHX 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

 4-13-17
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042274-02


24

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	HEALTH TECH OFFICE NORTH WING
Sample Identification Number (Write this number on the sample container and on this sheet)	D1004-02
Date of Collection	4-13-17
Time of Collection	0512
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C Picked up from City of PHX 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

 4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7022274-03

25

Collection Log
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	F1006
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NORTH WALL RM 400A
Sample Identification Number (Write this number on the sample container and on this sheet)	F1006-03
Date of Collection	4-13-17
Time of Collection	0516
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ Lab 1145

For relinquishing samples upon delivery to labs only
Relinquished date and signature  4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	F1006
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NORTHEAST CORNER RM. 402
Sample Identification Number (Write this number on the sample container and on this sheet)	F1006-04
Date of Collection	4-13-17
Time of Collection	0522
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C PICKED UP FROM CITY OF PHX 4/24/17 @ Lab 1145	

For relinquishing samples upon delivery to labs only
Relinquished date and signature  4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	H1008
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NORTHWALL RM. 500
Sample Identification Number (Write this number on the sample container and on this sheet)	H1008-05
Date of Collection	4-13-17
Time of Collection	0525
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00C Picked up from city of Phx 4/24/17 @ lab 11415	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling


Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	H1008
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. 502 WEST WALL
Sample Identification Number (Write this number on the sample container and on this sheet)	H1008-06
Date of Collection	4-13-17
Time of Collection	0530
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C picked up from City of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

 4-13-17
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	61007
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 504 SOUTHEAST CORNER
Sample Identification Number (Write this number on the sample container and on this sheet)	61007-07
Date of Collection	4-13-17
Time of Collection	0532
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00C Picked up from City of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only
Relinquished date and signature  4-13-17
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	61007
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. 508 SOUTHEAST CORNER
Sample Identification Number (Write this number on the sample container and on this sheet)	61007-08
Date of Collection	4-13-17
Time of Collection	0535
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C Picked up from City of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature 4/13/17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling


Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF RM. 509 WEST
Sample Identification Number (Write this number on the sample container and on this sheet)	I1009-09
Date of Collection	4-13-17
Time of Collection	0540
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C Picked up from city of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature


 4/13/17
These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	EXTERIOR OF RM. 509 EAST
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-10
Date of Collection	4-13-17
Time of Collection	0542
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C Picked up from City of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only
Relinquished date and signature  4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	E1005
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF GIRLS RESTROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	E1005-11
Date of Collection	4-13-17
Time of Collection	0546
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.0°C Picked up from city of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

[Signature] 4-13-17
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	E1005
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF GIRLS RESTROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	E1005-12
Date of Collection	4-13-17
Time of Collection	0547
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ Lab 1145

For relinquishing samples upon delivery to labs only
Relinquished date and signature *[Signature]* 4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042274-13

35

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling


Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	KITCHEN CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	A1001-13
Date of Collection	4-13-17
Time of Collection	0550
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00C Picked up from G75 of Phx 4/24/17 @ lab 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

 4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CARE SOUTHEAST WEST
Sample Identification Number (Write this number on the sample container and on this sheet)	A1001-14
Date of Collection	4-13-17
Time of Collection	0551
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ lab 1145

For relinquishing samples upon delivery to labs only
Relinquished date and signature  4/13-17
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. 203 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet)	B1002-15
Date of Collection	4-13-17
Time of Collection	0958
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
20.0°C	Picked up from City of Phx 4/24/17 @ Lab 1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.


☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM 204 SOUTHEAST CORNER
Sample Identification Number (Write this number on the sample container and on this sheet)	B1002-16
Date of Collection	4-13-17
Time of Collection	0605
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	picked up from city of phx 4/24/17 @ lab:1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature  4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District WASHINGTON ELEMENTARY DISTRICT
School Name DESERT VIEW
Building (name/number) 1010
Type of Fixture (tap, drinking fountain etc.) DRINKING FOUNTAIN
Location of Fixture (example, room number) RM. 104 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet) 1010-17
Date of Collection 4-13-17
Time of Collection 0610
Printed Name of Sample Collector ANDRE ROBLES
Signature Sample Collector [Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: <u>20.0°C</u> <u>Picked up from City of Phx 4/24/17 @ lab 1145</u>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature [Signature] 4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	DESERT VIEW
Building (name/number)	1010
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 104 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-18
Date of Collection	4-13-17
Time of Collection	0612
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ lab 1145

For relinquishing samples upon delivery to labs only
Relinquished date and signature *[Signature]* 4-13-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2