

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Ironwood

Reported:
05/01/17 10:07

Analyte

A1001-01 (7042284-01) Drinking Water (Grab) Sampled: 04/18/17 05:05 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:00	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

A1001-02 (7042284-02) Drinking Water (Grab) Sampled: 04/18/17 05:10 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:17	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

B1002-03 (7042284-03) Drinking Water (Grab) Sampled: 04/18/17 05:15 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	9.3	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:21	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

B1002-04 (7042284-04) Drinking Water (Grab) Sampled: 04/18/17 05:20 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:25	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

C1003-05 (7042284-05) Drinking Water (Grab) Sampled: 04/18/17 05:22 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:28	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

C1003-06 (7042284-06) Drinking Water (Grab) Sampled: 04/18/17 05:25 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:32	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

D1004-07 (7042284-07) Drinking Water (Grab) Sampled: 04/18/17 05:30 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 16

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Ironwood

Reported:
05/01/17 10:07

D1004-07 (7042284-07) Drinking Water (Grab) Sampled: 04/18/17 05:30 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:36	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

D1004-08 (7042284-08) Drinking Water (Grab) Sampled: 04/18/17 05:33 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:55	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

P1006-09 (7042284-09) Drinking Water (Grab) Sampled: 04/18/17 05:39 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 15:59	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

P1006-10 (7042284-10) Drinking Water (Grab) Sampled: 04/18/17 05:40 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 16:03	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

P1008-11 (7042284-11) Drinking Water (Grab) Sampled: 04/18/17 05:47 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 16:06	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

P1008-12 (7042284-12) Drinking Water (Grab) Sampled: 04/18/17 05:49 Received: 04/24/17 11:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1723	04/26/17 08:01	04/26/17 16:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	WEST WALL IN HEALTH TECH OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	A1001-01
Date of Collection	4-18-17
Time of Collection	0505
Printed Name of Sample Collector	ANDRE DOBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
20.0°C	Picked up from City of PHX 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Preserved @ lab 4/24/17 1400

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	WEST WALL ROOM 102
Sample Identification Number (Write this number on the sample container and on this sheet)	A1001-02
Date of Collection	4-18-17
Time of Collection	0510
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of PHX 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/24/17 1400

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


704 2284-03

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. 215 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet)	B1002-03
Date of Collection	4-18-17
Time of Collection	0515
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

Preserved @ lab 4/24/17 1400

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR BETWEEN RM. 201 & RM. 207
Sample Identification Number (Write this number on the sample container and on this sheet)	B1002-04
Date of Collection	4-18-17
Time of Collection	0520
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17 JH

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Preserved @ lab 4/24/17 1400

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-05

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	C1003
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR BETWEEN RM. 307 & RM. 308
Sample Identification Number (Write this number on the sample container and on this sheet)	C1003-05
Date of Collection	4-18-17
Time of Collection	0522
Printed Name of Sample Collector	ANDRE DOBLES

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of PHX 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042284-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	C1003
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. 302 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet)	C1003-06
Date of Collection	4-18-17
Time of Collection	0525
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

Preserved @ lab 4/24/17 1400


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042284-07

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CAFÉ NORTHWEST
Sample Identification Number (Write this number on the sample container and on this sheet)	D1004-07
Date of Collection	4-18-17
Time of Collection	0530
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of Phx 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/24/17 1400

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042284-08

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	KITCHEN CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	D1004-08
Date of Collection	4-18-17
Time of Collection	0533
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	picked up from City of PHX 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	P1006
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN SINK
Location of Fixture (example, room number)	RM. P1006 EAST WALL
Sample Identification Number (Write this number on the sample container and on this sheet)	P1006-09
Date of Collection	4-18-17
Time of Collection	0539
Printed Name of Sample Collector	ANDRE DOBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of PHX 4/24/17 @ 1061145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/24/17 1400

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-10

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	P1006
Type of Fixture (tap, drinking fountain etc.)	STINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. P1006 EAST WALL
Sample Identification Number (Write this number on the sample container and on this sheet)	P1006-10
Date of Collection	4-18-17
Time of Collection	0540
Printed Name of Sample Collector	ANDRE DOBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Picked up from City of PHX 4/24/17 @ Lab 1145 Preserved @ Lab 1400 4/24/17

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-11

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	P1008
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM P104 CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	P1008-11
Date of Collection	4-18-17
Time of Collection	0547
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00C	Picked up from city of PHX 4/24/17 @ lab 1145 Preserved @ lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/24/17

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042284-12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	IRONWOOD
Building (name/number)	P1008
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	BALL P104 CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	P1008-12
Date of Collection	4-18-17
Time of Collection	0549
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	PICKED UP FROM CITY OF PHX 4/24/17 @ Lab 1145 PRESERVED @ Lab 1400 4/24/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Preserved @ Lab 4/24/17 1400

Page 2 of 2

