

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Manzanita

Reported:
05/05/17 14:49

Analyte

E1005-01 (7042657-01) Drinking Water (Grab) Sampled: 04/24/17 05:10 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:14	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

E1005-02 (7042657-02) Drinking Water (Grab) Sampled: 04/24/17 05:13 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

I1009-03 (7042657-03) Drinking Water (Grab) Sampled: 04/24/17 05:18 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

I1009-04 (7042657-04) Drinking Water (Grab) Sampled: 04/24/17 05:20 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:34	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

A1001-05 (7042657-05) Drinking Water (Grab) Sampled: 04/24/17 05:25 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:37	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

A1001-06 (7042657-06) Drinking Water (Grab) Sampled: 04/24/17 05:26 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:41	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

H1008-07 (7042657-07) Drinking Water (Grab) Sampled: 04/24/17 05:30 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.



Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 20

H1008-07 (7042657-07) Drinking Water (Grab) Sampled: 04/24/17 05:30 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:45	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

H1008-08 (7042657-08) Drinking Water (Grab) Sampled: 04/24/17 05:32 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 22:56	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

B1002-09 (7042657-09) Drinking Water (Grab) Sampled: 04/24/17 05:36 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 23:00	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

B1002-10 (7042657-10) Drinking Water (Grab) Sampled: 04/24/17 05:40 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 23:04	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

C1003-11 (7042657-11) Drinking Water (Grab) Sampled: 04/24/17 05:43 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0958	05/01/17 16:57	05/01/17 23:08	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

C1003-12 (7042657-12) Drinking Water (Grab) Sampled: 04/24/17 05:47 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0959	05/01/17 16:59	05/01/17 23:31	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

D1004-13 (7042657-13) Drinking Water (Grab) Sampled: 04/24/17 05:53 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0959	05/01/17 16:59	05/01/17 23:42	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

D1004-14 (7042657-14) Drinking Water (Grab) Sampled: 04/24/17 05:58 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

D1004-14 (7042657-14) Drinking Water (Grab) Sampled: 04/24/17 05:58 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7E0959	05/01/17 16:59	05/01/17 23:46	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

F1006-15 (7042657-15) Drinking Water (Grab) Sampled: 04/24/17 06:00 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0959	05/01/17 16:59	05/01/17 23:50	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

F1006-16 (7042657-16) Drinking Water (Grab) Sampled: 04/24/17 06:03 Received: 04/27/17 10:20

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0959	05/01/17 16:59	05/01/17 23:53	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 18.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042657-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	E1005
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	HEALT TECH OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	E1005-01
Date of Collection	4-24-17
Time of Collection	0510
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042057

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	E1005
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	HALL BETWEEN HEALTH TECH AND OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	E1005-02
Date of Collection	4-24-17
Time of Collection	0513
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	REC'D @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-03

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	I 1009
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 902 KIDSPACE
Sample Identification Number (Write this number on the sample container and on this sheet)	I 1009-03
Date of Collection	4-24-17
Time of Collection	0518
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042657-04

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	I 1009
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 402 KIDSPACE
Sample Identification Number (Write this number on the sample container and on this sheet)	I 1009-04
Date of Collection	4-24-17
Time of Collection	0520
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-05

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 119
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	A1001-05
Date of Collection	4-29-17
Time of Collection	0525
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-06

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF RM. 115
Sample Identification Number (Write this number on the sample container and on this sheet)	A1001-06
Date of Collection	4-24-17
Time of Collection	0526
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Prescribed @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042657-07


Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

WASHINGTON ELEMENTARY DISTRICT
MANZANITA
H1008
DRINKING FOUNTAIN
EXTERIOR OF RM. 801
H1008-07
4-24-17
0530
ANDBE ROBLES


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.0°C	REC'd @ lab 4/27/17 1020 PRESERVED @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-08

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	H1008
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF RM. 802
Sample Identification Number (Write this number on the sample container and on this sheet)	H1008-08
Date of Collection	4-24-17
Time of Collection	0532
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042657-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LIBRARY N.W. (RM 211)
Sample Identification Number (Write this number on the sample container and on this sheet)	B1002-09
Date of Collection	4-29-17
Time of Collection	0936
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.0°C	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042657-10

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF RM. 204
Sample Identification Number (Write this number on the sample container and on this sheet)	B1002-10
Date of Collection	4-24-17
Time of Collection	0540
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.0°C	REC'D @ lab 4/27/17 1020 PRESERVED @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042057-11

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	C1003
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF RM. 304
Sample Identification Number (Write this number on the sample container and on this sheet)	C1003-11
Date of Collection	4-29-17
Time of Collection	0543
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.0°C	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-12

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	C1003
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 308 WEST WALL
Sample Identification Number (Write this number on the sample container and on this sheet)	C1003-12
Date of Collection	4-24-17
Time of Collection	0547
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-13

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	RM. 404 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet)	D1004-13
Date of Collection	4-24-17
Time of Collection	0553
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042657-14

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	RM. 404 SOUTHEAST
Sample Identification Number (Write this number on the sample container and on this sheet)	D1004-14
Date of Collection	4-24-17
Time of Collection	0558
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____
These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042657-15

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	F1006
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR NORTHWEST OF KITCHEN
Sample Identification Number (Write this number on the sample container and on this sheet)	F1006-15
Date of Collection	4-24-17
Time of Collection	0600
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Read @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only
Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


704205216

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MANZANITA
Building (name/number)	F1006
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CAFETERIA NORTH WALL
Sample Identification Number (Write this number on the sample container and on this sheet)	F1006-16
Date of Collection	4-24-17
Time of Collection	0603
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

