

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Mountain Sky

Reported:  
05/05/17 14:29

## Analyte

**E1001-01 (7042654-01) Drinking Water (Grab) Sampled: 04/27/17 05:02 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0956	05/01/17 16:49	05/01/17 18:41	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**E1001-02 (7042654-02) Drinking Water (Grab) Sampled: 04/27/17 05:05 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0956	05/01/17 16:49	05/01/17 18:45	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**F1001-03 (7042654-03) Drinking Water (Grab) Sampled: 04/27/17 05:20 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0956	05/01/17 16:49	05/01/17 18:49	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**F1001-04 (7042654-04) Drinking Water (Grab) Sampled: 04/27/17 05:21 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0956	05/01/17 16:49	05/01/17 18:53	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1006-05 (7042654-05) Drinking Water (Grab) Sampled: 04/27/17 05:24 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	66	5.0	ug/L	1	B7E0956	05/01/17 16:49	05/01/17 18:57	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**B1001-06 (7042654-06) Drinking Water (Grab) Sampled: 04/27/17 05:30 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:27	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**B1001-07 (7042654-07) Drinking Water (Grab) Sampled: 04/27/17 05:32 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 17

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Mountain Sky

Reported:  
05/05/17 14:29

**B1001-07 (7042654-07) Drinking Water (Grab) Sampled: 04/27/17 05:32 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	10	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:31	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**A1001-08 (7042654-08) Drinking Water (Grab) Sampled: 04/27/17 05:35 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	10	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:35	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**A1001-09 (7042654-09) Drinking Water (Grab) Sampled: 04/27/17 05:39 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:39	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**A1002-10 (7042654-10) Drinking Water (Grab) Sampled: 04/27/17 05:46 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**A1002-11 (7042654-11) Drinking Water (Grab) Sampled: 04/27/17 05:50 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**C1001-12 (7042654-12) Drinking Water (Grab) Sampled: 04/27/17 05:53 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 19:58	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**C1001-13 (7042654-13) Drinking Water (Grab) Sampled: 04/27/17 05:54 Received: 04/27/17 10:20**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E0957	05/01/17 16:55	05/01/17 20:01	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**Sample Condition Upon Receipt:**

Temperature: 18.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

---

**Notes and Definitions**

7042654 - 01

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	E1001
Type of Fixture (tap, drinking fountain etc.)	NURSE SINK
Location of Fixture (example, room number)	NURSE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	E1001-01
Date of Collection	4-27-17
Time of Collection	0902
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100
18.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042654 -02

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	E1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ADMIN HALLWAY
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	E1001-02
Date of Collection	4-27-17
Time of Collection	0505
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector: *COULD ONLY FILL 250ML CONTAINER  
HALF WAY DUE TO REDUCED WATER  
PRESSURE.*

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100
18.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


7042054-03

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	F1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR OF RM. 107
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	F1001-03
Date of Collection	4-27-17
Time of Collection	0520
Printed Name of Sample Collector	ANDRE BOBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.00C	Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

7042654 -04

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	51001
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Exterior of Rm 107
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	51001-04
Date of Collection	4-27-17
Time of Collection	0521
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

18.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042654-05

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NE interior #301
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	1006-05
Date of Collection	4-27-17
Time of Collection	0524
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.0°C	Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	131001
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	East wall #305
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	131001 - 06
Date of Collection	4-27-17
Time of Collection	0530
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

70426407

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	13109-0
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Center E. wall # 303
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	131001-07
Date of Collection	4-27-17
Time of Collection	0532
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only  
Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042634-08

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	2nd fl #402
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	A1001-08
Date of Collection	4-27-17
Time of Collection	0535
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	REC'D @ lab 4/27/17 1020 PRESERVED @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

704 2654-09

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	11001
Type of Fixture (tap, drinking fountain etc.)	External Drinking Fountain
Location of Fixture (example, room number)	External West
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	11001-09
Date of Collection	4-27-17
Time of Collection	0539
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
18.0°C	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042654-10

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Est. Drinking
Location of Fixture (example, room number)	E. wall by Boys
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1102-10
Date of Collection	4-27-17
Time of Collection	0546
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only  
Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042654-11

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	1-1002
Type of Fixture (tap, drinking fountain etc.)	Int. Drinking Fountain
Location of Fixture (example, room number)	Int. East wall Gym
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	11002-11
Date of Collection	4-27-17
Time of Collection	0650
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 18.0°C	
Recvd @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042654-12

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	C100
Type of Fixture (tap, drinking fountain etc.)	Ext. Drinking Fountain
Location of Fixture (example, room number)	Exterior Wall SW corner
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	C1001-12
Date of Collection	4-27-17
Time of Collection	0553
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	RECD @ lab 4/27/17 1020 PRESERVED @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only  
Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042654-13

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	MOUNTAIN SKY
Building (name/number)	C1001-
Type of Fixture (tap, drinking fountain etc.)	Ext. Drinking Fountain
Location of Fixture (example, room number)	Ext. South wall by restrooms
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	C1001-13
Date of Collection	4-27-17
Time of Collection	0554
Printed Name of Sample Collector	ANDRE ROBLES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Read @ lab 4/27/17 1020 Preserved @ lab 4/27/17 1100

For relinquishing samples upon delivery to labs only  
Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2



