

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Richard E Miller

Reported:  
06/13/17 09:25

## Analyte

**B1002-01 (7052645-01) Drinking Water (Grab) Sampled: 05/18/17 05:10 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 19:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**B1002-02 (7052645-02) Drinking Water (Grab) Sampled: 05/18/17 05:13 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 19:58	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**A1001-03 (7052645-03) Drinking Water (Grab) Sampled: 05/18/17 05:17 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	8.4	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:02	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**A1001-04 (7052645-04) Drinking Water (Grab) Sampled: 05/18/17 05:20 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:06	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1007-05 (7052645-05) Drinking Water (Grab) Sampled: 05/18/17 05:25 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:17	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1007-06 (7052645-06) Drinking Water (Grab) Sampled: 05/18/17 05:26 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:28	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1007-07 (7052645-07) Drinking Water (Grab) Sampled: 05/18/17 05:30 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 20

**1007-07 (7052645-07) Drinking Water (Grab) Sampled: 05/18/17 05:30 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	7.4	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:32	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**1007-08 (7052645-08) Drinking Water (Grab) Sampled: 05/18/17 05:31 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:36	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**C1003-09 (7052645-09) Drinking Water (Grab) Sampled: 05/18/17 05:37 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	6.6	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:40	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**C1003-10 (7052645-10) Drinking Water (Grab) Sampled: 05/18/17 05:40 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:44	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1006-11 (7052645-11) Drinking Water (Grab) Sampled: 05/18/17 05:44 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	8.2	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:47	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**1006-12 (7052645-12) Drinking Water (Grab) Sampled: 05/18/17 05:45 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	5.6	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:51	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**D1004-13 (7052645-13) Drinking Water (Grab) Sampled: 05/18/17 05:52 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:55	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**D1004-14 (7052645-14) Drinking Water (Grab) Sampled: 05/18/17 05:55 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Richard E Miller

Reported:  
06/13/17 09:25

**D1004-14 (7052645-14) Drinking Water (Grab) Sampled: 05/18/17 05:55 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1276	06/08/17 11:19	06/09/17 20:59	EPA 200.8	M1
------	------	-----	------	---	---------	----------------	----------------	-----------	----

**1009-15 (7052645-15) Drinking Water (Grab) Sampled: 05/18/17 06:00 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1277	06/08/17 11:21	06/09/17 21:29	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1009-16 (7052645-16) Drinking Water (Grab) Sampled: 05/18/17 06:03 Received: 05/26/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1277	06/08/17 11:21	06/09/17 21:33	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**Sample Condition Upon Receipt:**

Temperature: 25.00 °C  
All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.  
**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.  
**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.  
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.  
**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".  
  
*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

**Notes and Definitions**

M1 Matrix spike recovery was high; the method control sample recovery was acceptable.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052649-01  
uw 5127117  
S

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NURSE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	B1002-01
TIME Date of Collection	0510
DATE Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received@lab 5/26/17 1600 25.0°C ptn	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052645-02

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	B1002
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CATERIA
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	B1002-02
<del>TIME</del> Date of Collection	0913
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	<i>Alex Henriquez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052045-0

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E MILLER
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	EXTERIOR OF RM 113
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	A1001-03
<del>TIME</del> Date of Collection	0517
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E MILLER
Building (name/number)	A1001
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	EXTERIOR OF RM. 110
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	A1001-04
<del>TIME</del> Date of Collection	0520
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	<i>Alex Henriquez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	INTERIOR OF RM. 125
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-05
DATE Time of Collection	0525
DATE Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E MILLER
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	INTERIOR OF RM. 125
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-06
Date of Collection	0526
Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

#### For Lab use only

Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

#### For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	EASTWALL RM. 123
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-07
TIME Date of Collection	0530
DATE Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052445-1

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E MILLER
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	EAST WALL RM. 123
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1007-08
<del>TIME</del> Date of Collection	0531
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

70526457  
0

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	C1003
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LIBRARY WORK ROOM
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	C1003-09
<del>TIME</del> Date of Collection	0537
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052645

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	C1003
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LIBRARY WORK ROOM
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	C1003-10
<del>TIME</del> Date of Collection	0540
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052045

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E MILLER
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	LOUNGE
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-11
TIME Date of Collection	0544
DATE Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052645

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	BURBLES
Location of Fixture (example, room number)	LOUNGE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1006-12
<del>TIME</del> Date of Collection	0545
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	<i>Alex Henriquez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052645

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	INTERIOR HALLWAY OF 300 BLDG.
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	D1004-13
<del>TIME</del> Date of Collection	0552
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

70524451

### Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E MILLER
Building (name/number)	D1004
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	EXTERIOR OF RM. 301
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	D1004-K
DATE <sup>TIME</sup> Date of Collection	0555
DATE <sup>TIME</sup> Date of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex H

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7052645-15

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	S.E. CLASSROOM
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1009-15
TIME Date of Collection	0600
DATE Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henry

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705264571

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	WASHINGTON ELEMENTARY DISTRICT
School Name	RICHARD E. MILLER
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	BUBBLER
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write this number on the sample container and on this sheet</u> )	1009-16
<del>TIME</del> Date of Collection	0603
<del>DATE</del> Time of Collection	5-18-2017
Printed Name of Sample Collector	ALEX HENRIQUEZ
Signature Sample Collector	Alex Henriquez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

