

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Jack L Kuban Elementary School

Reported:
06/07/17 16:47

Analyte

1 Confirmation- First Draw (7060225-01) Drinking Water (Grab) Sampled: 05/31/17 06:00 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	45	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 23:12	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

2-Confirmation - Flush (7060225-02) Drinking Water (Grab) Sampled: 05/31/17 06:02 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	230	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 23:16	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

3 Confirmation - First Draw Day Two (7060225-03) Drinking Water (Grab) Sampled: 05/31/17 06:02 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	66	5.0	ug/L	1	B7F1060	06/06/17 14:21	06/06/17 23:39	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

4 Screening (7060225-04) Drinking Water (Grab) Sampled: 05/31/17 06:03 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	12	5.0	ug/L	1	B7F1060	06/06/17 14:21	06/06/17 23:43	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

5 Screening (7060225-05) Drinking Water (Grab) Sampled: 05/31/17 06:05 Received: 06/01/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.5	5.0	ug/L	1	B7F1060	06/06/17 14:21	06/06/17 23:54	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.

All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

7060225

Lead In Schools Confirmation Sampling Log					
School District: Murphy Elementary District					
School Name: Jack L Kuban Elementary School					
Building Name/Number/Year Built: A					
Sample Collector Name and Phone Number: MUSTAFA MEHMOVIC					
Sample ID # (must appear on bottle)	Bottle Size	Fixture Type/ Make and model #	Fixture location	Collection Time	Collection Date
1 Confirmation – First Draw	250 ml	Sink	Library	6:00 AM	5-31-17
2 Confirmation – Flush	250 ml	Sink	Library	6:02 AM	5-31-17
3 Confirmation – First Draw Day Two	1 Liter	Sink	Library	6:02 AM	5-31-17
4 Screening	250 ml	Drinking fountain	Outside Library	6:03 AM	5-31-17
5 Screening	250 ml	Drinking fountain	Cafeteria	6:03 AM	5-31-17
RUSH 10/8/17					
✓					

These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	5-31-2017
RELINQUISHING AGENT SIGNATURE:	[Signature]
SIGNATORY NAME PRINTED:	MUSTAFA MEHMOUDI

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	6/1/17
TIME LAB RECEIVED:	1600
LAB SIGNATURE:	[Signature]
LAB SIGNATORY NAME PRINTED:	MUSTAFA MEHMOUDI
NOTES:	20.00C