

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Jack L Kuban Elementary School

Reported:  
06/07/17 16:46

## Analyte

**1 Confirmation- First Draw (7060224-01) Drinking Water (Grab) Sampled: 05/31/17 06:35 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	48	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:34	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**2-Confirmation - Flush (7060224-02) Drinking Water (Grab) Sampled: 05/31/17 06:37 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	74	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:38	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**3 Confirmation - First Draw Day Two (7060224-03) Drinking Water (Grab) Sampled: 05/31/17 06:38 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	5.6	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:42	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**4 Screening (7060224-04) Drinking Water (Grab) Sampled: 05/31/17 06:40 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**5 Screening (7060224-05) Drinking Water (Grab) Sampled: 05/31/17 06:42 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	13	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:49	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**6 Screening (7060224-06) Drinking Water (Grab) Sampled: 05/31/17 06:44 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	34	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:53	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**7 Screening (7060224-07) Drinking Water (Grab) Sampled: 05/31/17 06:47 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 4

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Jack L Kuban Elementary School

Reported:  
06/07/17 16:46

**7 Screening (7060224-07) Drinking Water (Grab) Sampled: 05/31/17 06:47 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 22:57	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**8 Screening (7060224-08) Drinking Water (Grab) Sampled: 05/31/17 06:50 Received: 06/01/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	9.7	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 23:08	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**Sample Condition Upon Receipt:**

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

**Notes and Definitions**

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

7060224

Lead In Schools Confirmation Sampling Log					
School District: Murphy Elementary District					
School Name: Jack L Kuban Elementary School					
Building Name/Number/Year Built: B					
Sample Collector Name and Phone Number:					
Sample ID # (must appear on bottle)	Bottle Size	Fixture Type/ Make and model #	Fixture location	Collection Time	Collection Date
1 Confirmation – First Draw	250 ml	Sink	Science Rm	6:35Am	5-31-17
2 Confirmation – Flush	250 ml	Sink	Science Rm	6:37Am	5-31-17
3 Confirmation – First Draw Day Two	1 Liter	Sink	Science Rm	6:38Am	5-31-17
4 Screening	250 ml	Drinking fountain	Rm 25	6:40Am	5-31-17
5 Screening	250 ml	Drinking fountain	Rm 26	6:42Am	5-31-17
6 Screening	250 ml	Drinking fountain	Rm 27	6:44Am	5-31-17
7 Screening	250 ml	Drinking fountain	Outside restrooms	6:47Am	5-31-17
8 Screening	250 ml	Drinking fountain	Rm 29	6:50Am	5-31-17
<h1>RUSH</h1> <p>6/8/17</p>					
✓					

These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	5-31-2017
RELINQUISHING AGENT SIGNATURE:	<i>Mustafa Helwan</i>
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	6/1/17
TIME LAB RECEIVED:	11:00
LAB SIGNATURE:	<i>[Signature]</i>
LAB SIGNATORY NAME PRINTED:	Mustafa Helwan
NOTES:	20.00 RUSH