

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Alfred F Garcia School

Reported:
06/07/17 16:51

Analyte

1 Confirmation- First Draw (7060230-01) Drinking Water (Grab) Sampled: 05/30/17 07:30 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1061	06/06/17 14:23	06/07/17 03:01	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

2-Confirmation - Flush (7060230-02) Drinking Water (Grab) Sampled: 05/30/17 07:30 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1061	06/06/17 14:23	06/07/17 03:05	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

3 Confirmation - First Draw Day Two (7060230-03) Drinking Water (Grab) Sampled: 05/31/17 06:45 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1061	06/06/17 14:23	06/07/17 03:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 20.00 °C
All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.
QA/QC Criteria: All analyses met method requirements unless otherwise qualified.
Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.
Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

7060230

Murphy Elementary District
Alfred F Garcia School
Building J

- 1 Confirmation First Draw Drinking Fountain/ 5/30/17 73
Cafeteria
- 2 Confirmation - Flush Drinking Fountain/Cafeteria 5/30/17 730
- 3 Confirmation - First Draw Day 2 Drinking Fountain/ 5/31/17 64
Cafeteria

RUSH

Received @ Lab 5/31/17 1600
mwhaley
20.00c



Information taken from bottles mw 6/3/17