



# AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106  
P.O. Box 1510  
Tempe, Arizona 85281  
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

## LABORATORY REPORT

**Client:** ADEQ  
Lead in Drinking Water School Proj.  
1110 W. Washington Street  
Phoenix, AZ 85007  
**Attn:** David Burchard

**Date Submitted:** 03/13/17  
**Date Reported:** 04/07/17

**Project:** Eliseo C. Felix

## RESULTS

**Client ID:** 100-01  
**ACT Lab No.:** BZ03242

**Sample Type:** Drinking Water  
**Sample Time:** 03/06/17 07:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

**Client ID:** 100-02  
**ACT Lab No.:** BZ03243

**Sample Type:** Drinking Water  
**Sample Time:** 03/06/17 07:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

**Client ID:** 400-03  
**ACT Lab No.:** BZ03244

**Sample Type:** Drinking Water  
**Sample Time:** 03/06/17 07:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

**Client ID:** 400-04  
**ACT Lab No.:** BZ03245

**Sample Type:** Drinking Water  
**Sample Time:** 03/06/17 07:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	5.20	ug/L	SLM

## RESULTS

Client ID: 600-02  
ACT Lab No.: BZ03246

Sample Type: Drinking Water  
Sample Time: 03/06/17 07:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 500-01  
ACT Lab No.: BZ03247

Sample Type: Drinking Water  
Sample Time: 03/03/17 10:15

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	5.66	ug/L	SLM

Client ID: 500-02  
ACT Lab No.: BZ03248

Sample Type: Drinking Water  
Sample Time: 03/03/17 10:15

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	11.5	ug/L	SLM

Client ID: 500-03  
ACT Lab No.: BZ03249

Sample Type: Drinking Water  
Sample Time: 03/03/17 10:15

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	13.3	ug/L	SLM

Client ID: 400-01  
ACT Lab No.: BZ03250

Sample Type: Drinking Water  
Sample Time: 03/03/17 10:30

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 400-02  
ACT Lab No.: BZ03251

Sample Type: Drinking Water  
Sample Time: 03/03/17 10:30

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

## RESULTS

---

<b>Client ID:</b> 600-01 <b>ACT Lab No.:</b> BZ03252		<b>Sample Type:</b> Drinking Water <b>Sample Time:</b> 03/03/17 10:45					
<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
Lead	<u>Start</u>	<u>End</u>					
	03/28/17	03/28/17	200.8	1.0	4.84	ug/L	SLM

---

<b>Client ID:</b> 300-01 <b>ACT Lab No.:</b> BZ03253		<b>Sample Type:</b> Drinking Water <b>Sample Time:</b> 03/03/17 10:50					
<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
Lead	<u>Start</u>	<u>End</u>					
	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

---

<b>Client ID:</b> 300-02 <b>ACT Lab No.:</b> BZ03254		<b>Sample Type:</b> Drinking Water <b>Sample Time:</b> 03/03/17 10:50					
<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
Lead	<u>Start</u>	<u>End</u>					
	03/28/17	03/28/17	200.8	1.0	3.92	ug/L	SLM

---

<b>Client ID:</b> 000-01 <b>ACT Lab No.:</b> BZ03255		<b>Sample Type:</b> Drinking Water <b>Sample Time:</b> 03/06/17 10:55					
<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
Lead	<u>Start</u>	<u>End</u>					
	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

---

<b>Client ID:</b> 000-02 <b>ACT Lab No.:</b> BZ03256		<b>Sample Type:</b> Drinking Water <b>Sample Time:</b> 03/06/17 10:55					
<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
Lead	<u>Start</u>	<u>End</u>					
	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

---

<b>Client ID:</b> 000-006 <b>ACT Lab No.:</b> BZ03257		<b>Sample Type:</b> Drinking Water <b>Sample Time:</b> 03/06/17 11:00					
<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
Lead	<u>Start</u>	<u>End</u>					
	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

---

## RESULTS

Client ID: 000-005  
ACT Lab No.: BZ03258

Sample Type: Drinking Water  
Sample Time: 03/06/17 11:00

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 000-004  
ACT Lab No.: BZ03259

Sample Type: Drinking Water  
Sample Time: 03/06/17 11:00

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 000-003  
ACT Lab No.: BZ03260

Sample Type: Drinking Water  
Sample Time: 03/06/17 11:00

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 200-01  
ACT Lab No.: BZ03261

Sample Type: Drinking Water  
Sample Time: 03/03/17 14:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: 200-02  
ACT Lab No.: BZ03262

Sample Type: Drinking Water  
Sample Time: 03/03/17 14:45

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	1.03	ug/L	SLM

Reviewed by: \_\_\_\_\_

  
Frederick A. Amalfi, Ph.D.

Laboratory Director

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 100 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 101
Sample Identification Number (ensure this number is also on the sample container)	100-01
Date of Collection	3.6.17
Time of Collection	7:45 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03242</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature *F. Johnson* ACT 23<sup>rd</sup>  
MAR 13 2017  
15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 100 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 106
Sample Identification Number (ensure this number is also on the sample container)	100-02
Date of Collection	3.6.17
Time of Collection	7:45 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03243</b></p>	

Relinquished date and signature \_\_\_\_\_ 
 For relinquishing samples upon delivery to labs only  
 23°C  
**MAR 13 2017**  
 15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 400 WEST BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 401
Sample Identification Number (ensure this number is also on the sample container)	400 - 03
Date of Collection	3.6.17
Time of Collection	7:45 AM
Name of Sample Collector	Brian Sullivan
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03244</b></p>	

Relinquished date and signature \_\_\_\_\_ For relinquishing samples upon delivery to labs only

*239*  
**MAR 13 2017**  
*15:10*

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 400 WEST BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	#409
Sample Identification Number (ensure this number is also on the sample container)	400-04
Date of Collection	3.6.17
Time of Collection	7:45 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03245</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_ 23<sup>00</sup>  
MAR 13 2017

15:00

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 600 BUILDING (PE ROOM)
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	PE ROOM (#604)
Sample Identification Number (ensure this number is also on the sample container)	600-02
Date of Collection	3.6.17
Time of Collection	7:45 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03246</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*230*  
**MAR 13 2017**  
*15:10*

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 500 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 501
Sample Identification Number (ensure this number is also on the sample container)	500 - 01
Date of Collection	3-3-17
Time of Collection	10:15 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03247</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_ MAR 13 2017  
15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	BUILDING # 500
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 502
Sample Identification Number (ensure this number is also on the sample container)	500 - 02
Date of Collection	3-3-17
Time of Collection	10:15 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03248</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23°C  
**MAR 13 2017**  
 15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 500 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 503
Sample Identification Number (ensure this number is also on the sample container)	500-03
Date of Collection	3-3-17
Time of Collection	10:15 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03249</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23°C  
MAR 13 2017

15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 400 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 406
Sample Identification Number (ensure this number is also on the sample container)	400-01
Date of Collection	3.3.17
Time of Collection	10:30 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03250</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_ 
23<sup>rd</sup>  
**MAR 13 2017**  
15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	#400 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 408
Sample Identification Number (ensure this number is also on the sample container)	400-02
Date of Collection	3.3.17
Time of Collection	10:30 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03251</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

MAR 13 2017

23°C  
15:10

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 600 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 605
Sample Identification Number (ensure this number is also on the sample container)	600-01
Date of Collection	3.3.17
Time of Collection	10:45 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03252</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*230*  
**MAR 13 2017**

*15:10*

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 300 BUILDING 4
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 306
Sample Identification Number (ensure this number is also on the sample container)	300-01
Date of Collection	3.3.17
Time of Collection	10:50 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03253</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23<sup>rd</sup>  
**MAR 13 2017**  
15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 300 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 307
Sample Identification Number (ensure this number is also on the sample container)	300-02
Date of Collection	3.3.17
Time of Collection	10:50 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03254</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23°C  
MAR 13 2017

15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (ensure this number is also on the sample container)	000-01
Date of Collection	3.6.17
Time of Collection	10:55 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03255</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_ 23°C  
MAR 13 2017

15:10

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	KITCHEN
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	KITCHEN
Sample Identification Number (ensure this number is also on the sample container)	000-02
Date of Collection	3-6-17
Time of Collection	10:55 am
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03256</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_ MAR 13 2017

23°C

15:10

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	TEACHER <del>WORK ROOM</del> LOUNGE
Sample Identification Number (ensure this number is also on the sample container)	000 - 006
Date of Collection	3.6.17
Time of Collection	11:00 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03257</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_ 23<sup>rd</sup>  
MAR 13 2017  
15:10

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	WORKROOM
Sample Identification Number (ensure this number is also on the sample container)	600-005
Date of Collection	3.6.17
Time of Collection	11:00 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03258</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*23<sup>rd</sup>*  
**MAR 13 2017**  
*15:10*

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	NURSE'S OFFICE
Type of Fixture (tap, drinking fountain etc.)	SINK (RESTROOM)
Location of Fixture (example, room number)	NURSE'S OFFICE
Sample Identification Number (ensure this number is also on the sample container)	000-004
Date of Collection	3.6.17
Time of Collection	11:00 AM
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03259</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*23<sup>rd</sup>*  
**MAR 13 2017**

*15.10*

## Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	ADMINISTRATION BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	FRONT OFFICE
Sample Identification Number (ensure this number is also on the sample container)	000-003
Date of Collection	3.6.17
Time of Collection	11:00 am
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03260</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23°C  
MAR 13 2017  
15:10

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 200 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 205
Sample Identification Number (ensure this number is also on the sample container)	200-01
Date of Collection	3-3-17
Time of Collection	2:45 P
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E. Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03261</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*23°C*  
**MAR 13 2017**

*15:10*

# Sample Collection Record

To be completed by the sample collector

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Avondale Elementary District
Name of School	Eliseo C. Felix (formerly Pioneer School)
Building (name/number)	# 200 BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	# 207
Sample Identification Number (ensure this number is also on the sample container)	200-02
Date of Collection	3.3.17
Time of Collection	2:45 pm
Name of Sample Collector	BRIAN SULLIVAN
Signature Sample Collector	<i>Brian E Sullivan</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p><b>BZ-03262</b></p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

23<sup>rd</sup>  
**MAR 13 2017**  
 15:10

-024