



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ

Lead in Drinking Water School Proj.

1110 W. Washington Street

Phoenix, AZ 85007

Attn: David Burchard

Date Submitted: 01/12/17

Date Reported: 02/06/17

Project: Tuscano Elementary

RESULTS

Client ID: TES-1

ACT Lab No.: BZ00383

Sample Type: Surface Water

Sample Time: 01/12/17 06:55

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	01/19/17	01/19/17	200.8	0.0010	<0.0010	mg/L	SLM

Client ID: TES-2

ACT Lab No.: BZ00384

Sample Type: Surface Water

Sample Time: 01/12/17 06:56

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	01/19/17	01/19/17	200.8	0.0010	<0.0010	mg/L	SLM

Client ID: TES-3

ACT Lab No.: BZ00385

Sample Type: Surface Water

Sample Time: 01/12/17 07:05

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	01/19/17	01/19/17	200.8	0.0010	<0.0010	mg/L	SLM

Reviewed by:


Frederick A. Amalfi, Ph.D.

Laboratory Director

Sample Recordkeeping Form

For initial lead drinking water samples

To be completed by the sample collector

Name of School District	Fowler Elementary School District
Name of School	TUSCANO Elementary
Name (or number) of Building	Bldg # 100 300
Type of Fixture (tap, drinking fountain etc..)	drinking fountain
Location of Fixture (example, room number)	Cafeteria - south end
Sample Identification Number (ensure this number is also on the sample container)	TES - 1
Date of Collection	1/12/17
Time of Collection	6:55 AM
Name of Sample Collector	VICTOR SCHERER / DAVID BURCHARD
Signature Sample Collector	<i>Victor Sch</i>

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling ☒

Notes	Cafeteria S. end of Bldg/as facing fountains (2) pulled sample from <u>left</u> fountain Bld # 300	BZ-00383
-------	---	-----------------

One Sample Recordkeeping form should be complete for each sample collected. Copies should be sent to the lab with the samples.

For Lab use only	
Date and Time Lab received	JAN 12 2017 @ 14:59
Signature <i>[Signature]</i>	

24°C
No Ice

Sample Recordkeeping Form **For initial lead drinking water samples**

To be completed by the sample collector

Name of School District	Fowler Elementary School District
Name of School	TUSCANO Elementary
Name (or number) of Building	Bldg # 200
Type of Fixture (tap, drinking fountain etc..)	drinking water
Location of Fixture (example, room number)	next to 254/258 Rooms
Sample Identification Number (ensure this number is also on the sample container)	TES-2
Date of Collection	1/12/17
Time of Collection	6:56 AM
Name of Sample Collector	Victor Scherer / David Burdick
Signature Sample Collector	Victor Sch

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling ☒

BZ-00384

Notes	<p>2 fountains in between rooms 254 & 258 - took sample from left fountain</p> <p>these were <u>outside</u> fountains - North side of Bld.</p>
-------	--

One Sample Recordkeeping form should be complete for each sample collected. Copies should be sent to the lab with the samples.

For Lab use only	
Date and Time Lab received	
Signature	JAN 12 2017 @ 14:59

24°C
No Ice

Sample Recordkeeping Form

For initial lead drinking water samples

To be completed by the sample collector

Name of School District	Fowler Elementary School District
Name of School	TUSCANO Elementary
Name (or number) of Building	Bld #100
Type of Fixture (tap, drinking fountain etc..)	Drinking water fountain
Location of Fixture (example, room number)	Drinking water fountain Bld #100
Sample Identification Number (ensure this number is also on the sample container)	TES-3
Date of Collection	11/2/17
Time of Collection	7:05 AM
Name of Sample Collector	VICTOR Scherer
Signature Sample Collector	<i>Victor Sch</i>

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling ☒

Notes
<p>Bld # 100</p> <p>BZ-00385</p> <p>INSIDE Fountain - next to Room 117</p> <p>collected from drinking water fountain (single fountain)</p>

One Sample Recordkeeping form should be complete for each sample collected. Copies should be sent to the lab with the samples.

For Lab use only	
Date and Time Lab received	
Signature <i>D. Johnson</i>	JAN 12 2017 @ 14:59

24°C
No Ice