

# TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

## ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Phoenix

4625 East Cotton Ctr Blvd

Suite 189

Phoenix, AZ 85040

Tel: (602)437-3340

TestAmerica Job ID: 550-80539-1

TestAmerica Sample Delivery Group: Union Elementary School

Client Project/Site: Pb in DW/Union Elementary District

For:

Arizona Dept of Environmental Quality

1110 W. Washington St., MC5415B-1

Phoenix, Arizona 85007

Attn: David A Burchard



Authorized for release by:

4/24/2017 3:12:24 PM

Jannel Franklin, Project Manager I

(732)593-2551

[jannel.franklin@testamericainc.com](mailto:jannel.franklin@testamericainc.com)

Designee for

Susan Armijo, Project Manager II

(602)659-7664

[susan.armijo@testamericainc.com](mailto:susan.armijo@testamericainc.com)

### LINKS

Review your project  
results through

TotalAccess

Have a Question?



Visit us at:

[www.testamericainc.com](http://www.testamericainc.com)

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the items tested and the sample(s) as received by the laboratory.*

# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Definitions/Glossary . . . . .	3
Case Narrative . . . . .	4
Sample Summary . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
QC Sample Results . . . . .	8
QC Association Summary . . . . .	9
Lab Chronicle . . . . .	10
Certification Summary . . . . .	12
Method Summary . . . . .	13
Chain of Custody . . . . .	14
Receipt Checklists . . . . .	22



## Definitions/Glossary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

### Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

## Case Narrative

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

**Job ID: 550-80539-1**

**Laboratory: TestAmerica Phoenix**

### Narrative

#### Job Narrative 550-80539-1

### Comments

No additional comments.

### Receipt

The samples were received on 4/6/2017 2:15 PM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 23.1° C.

### Receipt Exceptions

The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: Kitchen (550-80539-1), Administration (550-80539-2), Classroom (550-80539-3), Exterior/Interior (550-80539-4), Classroom (550-80539-5), Interior (550-80539-6) and Outdoor/Exterior (550-80539-7). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

### Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

## Sample Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-80539-1	Kitchen	Drinking Water	03/30/17 06:00	04/06/17 14:15
550-80539-2	Administration	Drinking Water	03/30/17 05:55	04/06/17 14:15
550-80539-3	Classroom	Drinking Water	03/30/17 06:05	04/06/17 14:15
550-80539-4	Exterior/Interior	Drinking Water	03/30/17 06:15	04/06/17 14:15
550-80539-5	Classroom	Drinking Water	03/30/17 06:10	04/06/17 14:15
550-80539-6	Interior	Drinking Water	03/30/17 05:50	04/06/17 14:15
550-80539-7	Outdoor/Exterior	Drinking Water	03/30/17 05:45	04/06/17 14:15

## Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

### Client Sample ID: Kitchen

Lab Sample ID: 550-80539-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.1		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: Administration

Lab Sample ID: 550-80539-2

No Detections.

### Client Sample ID: Classroom

Lab Sample ID: 550-80539-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: Exterior/Interior

Lab Sample ID: 550-80539-4

No Detections.

### Client Sample ID: Classroom

Lab Sample ID: 550-80539-5

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: Interior

Lab Sample ID: 550-80539-6

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.8		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: Outdoor/Exterior

Lab Sample ID: 550-80539-7

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.76		0.50	ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

## Client Sample ID: Kitchen

Date Collected: 03/30/17 06:00

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-1

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.1		0.50	ppb		04/11/17 20:09	04/22/17 14:07	1

## Client Sample ID: Administration

Date Collected: 03/30/17 05:55

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-2

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/11/17 20:09	04/22/17 14:09	1

## Client Sample ID: Classroom

Date Collected: 03/30/17 06:05

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-3

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50	ppb		04/11/17 20:09	04/22/17 14:11	1

## Client Sample ID: Exterior/Interior

Date Collected: 03/30/17 06:15

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-4

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/11/17 20:09	04/22/17 14:17	1

## Client Sample ID: Classroom

Date Collected: 03/30/17 06:10

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-5

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50	ppb		04/11/17 20:09	04/22/17 14:19	1

## Client Sample ID: Interior

Date Collected: 03/30/17 05:50

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-6

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.8		0.50	ppb		04/11/17 20:09	04/22/17 14:21	1

## Client Sample ID: Outdoor/Exterior

Date Collected: 03/30/17 05:45

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-7

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.76		0.50	ppb		04/11/17 20:09	04/22/17 14:22	1

TestAmerica Phoenix

# QC Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

## Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 550-114627/1-A

Matrix: Water

Analysis Batch: 115508

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 114627

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/11/17 20:09	04/22/17 13:43	1

Lab Sample ID: LCS 550-114627/3-A

Matrix: Water

Analysis Batch: 115508

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 114627

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	87.8		ppb		88	85 - 115

Lab Sample ID: LCSD 550-114627/4-A

Matrix: Water

Analysis Batch: 115508

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 114627

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	89.8		ppb		90	85 - 115	2	20

Lab Sample ID: 550-80536-A-2-B MS

Matrix: Water

Analysis Batch: 115508

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 114627

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	1.3		100	86.0		ppb		85	70 - 130

Lab Sample ID: 550-80536-A-2-C MSD

Matrix: Water

Analysis Batch: 115508

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 114627

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	1.3		100	95.4		ppb		94	70 - 130	10	20



## QC Association Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

### Metals

#### Prep Batch: 114627

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80539-1	Kitchen	Total/NA	Drinking Water	200.8	
550-80539-2	Administration	Total/NA	Drinking Water	200.8	
550-80539-3	Classroom	Total/NA	Drinking Water	200.8	
550-80539-4	Exterior/Interior	Total/NA	Drinking Water	200.8	
550-80539-5	Classroom	Total/NA	Drinking Water	200.8	
550-80539-6	Interior	Total/NA	Drinking Water	200.8	
550-80539-7	Outdoor/Exterior	Total/NA	Drinking Water	200.8	
MB 550-114627/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-114627/3-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-114627/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-80536-A-2-B MS	Matrix Spike	Total/NA	Water	200.8	
550-80536-A-2-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

#### Analysis Batch: 115508

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80539-1	Kitchen	Total/NA	Drinking Water	200.8	114627
550-80539-2	Administration	Total/NA	Drinking Water	200.8	114627
550-80539-3	Classroom	Total/NA	Drinking Water	200.8	114627
550-80539-4	Exterior/Interior	Total/NA	Drinking Water	200.8	114627
550-80539-5	Classroom	Total/NA	Drinking Water	200.8	114627
550-80539-6	Interior	Total/NA	Drinking Water	200.8	114627
550-80539-7	Outdoor/Exterior	Total/NA	Drinking Water	200.8	114627
MB 550-114627/1-A	Method Blank	Total/NA	Water	200.8	114627
LCS 550-114627/3-A	Lab Control Sample	Total/NA	Water	200.8	114627
LCSD 550-114627/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	114627
550-80536-A-2-B MS	Matrix Spike	Total/NA	Water	200.8	114627
550-80536-A-2-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	114627

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

## Client Sample ID: Kitchen

Date Collected: 03/30/17 06:00

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:07	TEK	TAL PHX

## Client Sample ID: Administration

Date Collected: 03/30/17 05:55

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-2

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:09	TEK	TAL PHX

## Client Sample ID: Classroom

Date Collected: 03/30/17 06:05

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-3

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:11	TEK	TAL PHX

## Client Sample ID: Exterior/Interior

Date Collected: 03/30/17 06:15

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-4

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:17	TEK	TAL PHX

## Client Sample ID: Classroom

Date Collected: 03/30/17 06:10

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-5

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:19	TEK	TAL PHX

## Client Sample ID: Interior

Date Collected: 03/30/17 05:50

Date Received: 04/06/17 14:15

## Lab Sample ID: 550-80539-6

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:21	TEK	TAL PHX

TestAmerica Phoenix

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

**Client Sample ID: Outdoor/Exterior**

**Date Collected: 03/30/17 05:45**

**Date Received: 04/06/17 14:15**

**Lab Sample ID: 550-80539-7**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114627	04/11/17 20:09	SLS	TAL PHX
Total/NA	Analysis	200.8		1	115508	04/22/17 14:22	TEK	TAL PHX

## Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

## Accreditation/Certification Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

### Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	EPA Region	Identification Number	Expiration Date
Arizona	State Program	9	AZ0728	06-09-17

Analysis Method	Prep Method	Matrix	Analyte
-----------------	-------------	--------	---------

## Method Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW/Union Elementary District

TestAmerica Job ID: 550-80539-1  
SDG: Union Elementary School

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX

### Protocol References:

EPA = US Environmental Protection Agency

### Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

80539

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	BUILDING A
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	KITCHEN
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	
Date of Collection	3/30/17
Time of Collection	6:00 AM
Printed Name of Sample Collector	MIKE HOPPE
Signature Sample Collector	<i>Mike Hoppe</i>

550-80539 Chain of Custody



Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

①

*U. Leith*

23.1

4/6/17

14.15

no ice

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	BUILDING A
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ADMINISTRATION
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	
Date of Collection	3/30/17
Time of Collection	5:55 AM
Printed Name of Sample Collector	MIKE HOGGE
Signature Sample Collector	<i>Mike Hogge</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

(2)

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	BUILDING B
Type of Fixture (tap, drinking fountain etc.)	C SINK
Location of Fixture (example, room number)	CLASSROOM
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	
Date of Collection	3/30/17
Time of Collection	6:05 AM
Printed Name of Sample Collector	MIKE HARRIS
Signature Sample Collector	<i>Mike Harris</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

3



## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	BUILDING C
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR/INTERIOR
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	
Date of Collection	3/30/17
Time of Collection	6:15 AM
Printed Name of Sample Collector	MIKE HARRIS
Signature Sample Collector	<i>Mike Harris</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

4

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	BUILDING C
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	CLASSROOM
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	1
Date of Collection	3/30/17
Time of Collection	6:10 AM
Printed Name of Sample Collector	MIKE HAYDE
Signature Sample Collector	<i>Mike Hayde</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


5

## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	DISTRICT OFFICE
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	INTERIOR
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	
Date of Collection	3/30/17
Time of Collection	5:50 AM
Printed Name of Sample Collector	MIKE HOGGE
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

6

## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Union Elementary District
School Name	Union Elementary School
Building (name/number)	DISTRICT OFFICE
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	OUTDOOR/EXTERIOR
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	
Date of Collection	3/30/17
Time of Collection	5:45 AM
Printed Name of Sample Collector	MIKE HOPPE
Signature Sample Collector	<i>Mike Hoppe</i>

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

7

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Union Elementary District	Union Elementary School	1002	Building B-4	Cafeteria and Classrooms	1970	2
Union Elementary District	Union Elementary School	1005	Building E	Old school	1928	2
Union Elementary District	Union Elementary School	1006	New School - main building	Classrooms	2002	1
Union Elementary District	Union Elementary School	1007	Building C	Classrooms	2004	2
Union Elementary District	Union Elementary School	1008	Building D	Classrooms	2004	1
Union Elementary District	Union Elementary School	1009	Addition to Building A-B	Classrooms	2004	1
Address:						Bottles Per Kit: 8

## Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-80539-1

SDG Number: Union Elementary School

**Login Number: 80539**

**List Number: 1**

**Creator: Vilaboy, Monica**

**List Source: TestAmerica Phoenix**

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	Check done at department level as required.