



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ
Lead in Drinking Water School Proj.
1110 W. Washington Street
Phoenix, AZ 85007

Date Submitted: 03/23/17
Date Reported: 04/07/17

Attn: David Burchard

Project: Underdown J HS

RESULTS

Client ID: Hallway
ACT Lab No.: BZ03893

Sample Type: Drinking Water
Sample Time: 03/21/17 09:40

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/30/17	03/30/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: District Main Office
ACT Lab No.: BZ03894

Sample Type: Drinking Water
Sample Time: 03/21/17 09:34

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/30/17	03/30/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: RM 4
ACT Lab No.: BZ03895

Sample Type: Drinking Water
Sample Time: 03/21/17 09:24

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/30/17	03/30/17	200.8	1.0	4.38	ug/L	SLM

Client ID: Work Room
ACT Lab No.: BZ03896

Sample Type: Drinking Water
Sample Time: 03/21/17 09:19

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/30/17	03/30/17	200.8	1.0	<1.00	ug/L	SLM

RESULTS


Client ID: RR Sink
ACT Lab No.: BZ03897

Sample Type: Drinking Water
Sample Time: 03/21/17 09:16

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/30/17	03/30/17	200.8	1.0	<1.00	ug/L	SLM

isa

Reviewed by:



Frederick A. Amalfi, Ph.D.
Laboratory Director

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Littleton Elementary District
	Underdown Junior High School
Building (name/number)	B-1007
Type of Fixture (tap, drinking fountain etc.)	Drinking Ftn
Location of Fixture (example, room number)	Hallway
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	
Date of Collection	3/21/17
Time of Collection	9:40am
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03893</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature F. Johnson ACT MAR 23 2017 20C

15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Littleton Elementary District
	Underdown Junior High School
Building (name/number)	ULC A - 1008
Type of Fixture (tap, drinking fountain etc.)	Drinking Ftn
Location of Fixture (example, room number)	District main office
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	
Date of Collection	3/21/17
Time of Collection	9:34 am
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
<p>BZ-03894</p>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ MAR 23 2017 20°C

15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Littleton Elementary District
	Underdown Junior High School
Building (name/number)	G-1000 Rm 4
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Rm 4
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	
Date of Collection	3/21/17
Time of Collection	9:24am
Printed Name of Sample Collector	Angelica Suarez
Signature Sample Collector	<i>Angelica Suarez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
BZ-03895	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ MAR 23 2017 ^{20°C}
15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Littleton Elementary District
	Underdown Junior High School
Building (name/number)	A-1001
Type of Fixture (tap, drinking fountain etc.)	WORK ROOM SINK
Location of Fixture (example, room number)	WORK ROOM
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	
Date of Collection	3/21/17
Time of Collection	9:19am
Printed Name of Sample Collector	Angelica Suarez
Signature Sample Collector	<i>Angelica Suarez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03896	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

MAR 23 2017 ^{20°C}
15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Littleton Elementary District
Building (name/number)	Underdown Junior High School
Type of Fixture (tap, drinking fountain etc.)	A
Location of Fixture (example, room number)	*per bottle - triact sink DB BR
Sample Identification Number (Write this number on the sample container and on this sheet)	DB white used
Date of Collection	3/21/17
Time of Collection	9:16 am
Printed Name of Sample Collector	Angelica Suarez
Signature Sample Collector	<i>Angelica Suarez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
BZ-03897	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ MAR 23 2017 ^{20°C}
 15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.