



Results Report



Submitter: Water Services Department
200 W. Washington
Phoenix, AZ

Type of Project: Water

Lab Number: **2017010424**

Sample ID : 1009-H-803-DF-16
Sampling Date/Time: 02/08/2017 04:59
Approval Date : 02/17/2017 11:39
Received Date/Time: 02/10/2017 07:00
Sample Type : GRAB

Project Link Code : Pb AZ Schools
Account Number : N/C
Sampled by : Client Representative
Delivered : Water Inspector

| Test | Method* | Result Units | Dil. Fact. | Data Qualifiers | MDL | Report Limit | Analyst | Analysis Date |
|------------------|--------------------|---------------|------------|-----------------|---------|--------------|---------|------------------|
| Lead - Total | EPA 200.8 | <0.00055 mg/L | 5 | D1;E8 | 0.00055 | 0.0050 | YL | 02/16/2017 00:00 |
| Turbidity | EPA 180.1 § | 0.05 NTU | 1 | | | | GA | 02/14/2017 11:00 |
| pH<2Verification | pH <2 Verification | COMPLETE | | | | | JS | 02/13/2017 11:38 |

Sample Condition: Received at ambient temperature.