



**Results Report**



Submitter: Water Services Department  
 200 W. Washington  
 Phoenix, AZ

Type of Project: Water

Lab Number: **2017010415**

Sample ID : 1004-D-1-401-DF-07  
 Sampling Date/Time: 02/08/2017 04:55  
 Approval Date : 02/16/2017 11:27  
 Received Date/Time: 02/10/2017 07:00  
 Sample Type : GRAB

Project Link Code : Pb AZ Schools  
 Account Number : N/C  
 Sampled by : Client Representative  
 Delivered : Water Inspector

Test	Method*	Result Units	Dil. Fact.	Data Qualifiers	MDL	Report Limit	Analyst	Analysis Date
Lead - Total	EPA 200.8	<0.00055 mg/L	5	D1;E8	0.00055	0.0050	YL	02/15/2017 00:00
Turbidity	EPA 180.1 §	0.10 NTU	1				GA	02/14/2017 11:00
pH<2Verification	pH <2 Verification	COMPLETE					JS	02/13/2017 11:38

Sample Condition: Received at ambient temperature.

\* SM20 = Standard Methods 20<sup>th</sup> Edition SM21 = Standard Methods 21<sup>st</sup> Edition SM22 = Standard Methods 22<sup>nd</sup> Edition

§ = Not licensed by ADHS

☒ = Non nelac accredited