



Results Report



Submitter: Water Services Department
200 W. Washington
Phoenix, AZ

Type of Project: Water

Lab Number: **2017007840**

Sample ID : 1020-T-30-34	Project Link Code : Pb AZ Schools
Sampling Date/Time: 01/24/2017 06:29	Account Number : N/C
Approval Date : 02/06/2017 15:36	Sampled by : Client Representative
Received Date/Time: 01/31/2017 11:05	Delivered : M. Vega
Sample Type : GRAB	Receipt Temperature (°C) : 3.0

Test	Method*	Result Units	Dil. Fact.	Data Qualifiers	MDL	Report Limit	Analyst	Analysis Date
Lead - Total	EPA 200.8	<0.00055 mg/L	5	D1;E8	0.00055	0.0050	YL	02/03/2017 00:00
Turbidity	EPA 180.1 § Turbidity Case Narrative: 2017007523, RPD=20.3%, repeat 29.4% (Acceptance criteria <= 20%)	0.05 NTU	1	N1			TH	02/02/2017 12:48
pH<2Verification	pH <2 Verification	COMPLETE					JS	02/02/2017 10:30

Sample Condition: Samples received cool to the touch. Custody seals were not in place. Temperature Blank also received.