



Results Report



Submitter: Water Services Department
200 W. Washington
Phoenix, AZ

Type of Project: Water

Lab Number: **2017007838**

| | | | |
|--------------------|--------------------|--------------------------|-------------------------|
| Sample ID | : 1020-T-31-07 | Project Link Code | : Pb AZ Schools |
| Sampling Date/Time | : 01/24/2017 04:53 | Account Number | : N/C |
| Approval Date | : 02/06/2017 15:36 | Sampled by | : Client Representative |
| Received Date/Time | : 01/31/2017 11:05 | Delivered | : M. Vega |
| Sample Type | : GRAB | Receipt Temperature (°C) | : 3.0 |

| Test | Method* | Result | Units | Dil. Fact. | Data Qualifiers | MDL | Report Limit | Analyst | Analysis Date |
|------------------|---|----------|-------|------------|-----------------|---------|--------------|---------|------------------|
| Lead - Total | EPA 200.8 | <0.00055 | mg/L | 5 | D1;E8 | 0.00055 | 0.0050 | YL | 02/03/2017 00:00 |
| Turbidity | EPA 180.1 § Turbidity Case Narrative: 2017006714, RPD=51.4%, repeat 61.4% (Acceptance criteria <= 20%) | 0.05 | NTU | 1 | N1 | | | TH | 02/02/2017 12:48 |
| pH<2Verification | pH <2 Verification | COMPLETE | | | | | | JS | 02/02/2017 10:30 |

Sample Condition: Samples received cool to the touch. Custody seals were not in place. Temperature Blank also received.