



## Results Report



Submitter: Water Services Department  
200 W. Washington  
Phoenix, AZ

Type of Project: Water

Lab Number: **2017007816**

Sample ID	: 1010-I-49-10	Project Link Code	: Pb AZ Schools
Sampling Date/Time	: 01/24/2017 04:59	Account Number	: N/C
Approval Date	: 02/06/2017 15:36	Sampled by	: Client Representative
Received Date/Time	: 01/31/2017 11:05	Delivered	: M. Vega
Sample Type	: GRAB	Receipt Temperature (°C)	: 3.0

Test	Method*	Result Units	Dil. Fact.	Data Qualifiers	MDL	Report Limit	Analyst	Analysis Date
Lead - Total	EPA 200.8	<0.00055 mg/L	5	D1;E8	0.00055	0.0050	YL	02/03/2017 00:00
Turbidity	EPA 180.1 §	0.05 NTU	1				TH	02/02/2017 11:16
pH<2Verification	pH <2 Verification	COMPLETE					JS	02/01/2017 15:00

Sample Condition: Samples received cool to the touch. Custody seals were not in place. Temperature Blank also received.