



**Results Report**



Submitter: Water Services Department  
 200 W. Washington  
 Phoenix, AZ

Type of Project: Water

Lab Number: **2017007781**

Sample ID : 1012-Z-DF-014  
 Sampling Date/Time: 01/25/2017 05:05  
 Approval Date : 02/06/2017 15:36  
 Received Date/Time: 01/31/2017 11:05  
 Sample Type : GRAB

Project Link Code : Pb AZ Schools  
 Account Number : N/C  
 Sampled by : Client Representative  
 Delivered : M. Vega  
 Receipt Temperature (°C) : 3.0

Test	Method*	Result Units	Dil. Fact.	Data Qualifiers	MDL	Report Limit	Analyst	Analysis Date
Lead - Total	EPA 200.8	0.00057 mg/L	5	D1;E4	0.00055	0.0050	YL	02/02/2017 00:00
Turbidity	EPA 180.1 §	0.05 NTU	1				TH	02/02/2017 09:30
pH<2Verification	pH <2 Verification	COMPLETE					JS	02/01/2017 15:00

Sample Condition: Samples received cool to the touch. Custody seals were not in place. Temperature Blank also received.

\* SM20 = Standard Methods 20<sup>th</sup> Edition SM21 = Standard Methods 21<sup>st</sup> Edition SM22 = Standard Methods 22<sup>nd</sup> Edition

§ = Not licensed by ADHS

☒ = Non nelac accredited