



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ

Lead in Drinking Water School Proj.

1110 W. Washington Street

Phoenix, AZ 85007

Attn: David Burchard

Date Submitted: 03/17/17

Date Reported: 04/07/17

Project: L Thomas Heck MS

RESULTS

Client ID: H1
ACT Lab No.: BZ03564

Sample Type: Drinking Water
Sample Time: 03/10/17 06:20

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: H2
ACT Lab No.: BZ03565

Sample Type: Drinking Water
Sample Time: 03/10/17 06:32

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: H3
ACT Lab No.: BZ03566

Sample Type: Drinking Water
Sample Time: 03/10/17 05:48

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: H4
ACT Lab No.: BZ03567

Sample Type: Drinking Water
Sample Time: 03/10/17 05:56

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

RESULTS

Client ID: H5
ACT Lab No.: BZ03568

Sample Type: Drinking Water
Sample Time: 03/10/17 06:03

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM


Client ID: H6
ACT Lab No.: BZ03569

Sample Type: Drinking Water
Sample Time: 03/10/17 06:12

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

ba

Reviewed by: _____



Frederick A. Amalfi, Ph.D.
Laboratory Director

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	L. Thomas Heck Middle School
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	123
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	11
Date of Collection	03/10/17
Time of Collection	0620
Printed Name of Sample Collector	Thomas M Rooney
Signature Sample Collector	Thomas M Rooney

Notes Sample collector:

BZ-03564

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature T. Johnson ACT **MAR 17 2017**

15:30

These samples were collected for lead screening purposes only and cannot be used for compliance.

24°C

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	L. Thomas Heck Middle School
Building (name/number)	200 Media
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Restrooms
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	H 2
Date of Collection	03/10/17
Time of Collection	0632
Printed Name of Sample Collector	Thomas M. Reoney
Signature Sample Collector	<i>Thomas M. Reoney</i>

Notes Sample collector:

BZ-03565

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

MAR 17 2017

15:30
2400

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	L. Thomas Heck Middle School
Building (name/number)	300 / 400
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Gym Hallway
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	H3
Date of Collection	03/10/17
Time of Collection	0548
Printed Name of Sample Collector	Thomas M. Rooney
Signature Sample Collector	Thomas M. Rooney

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03566	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 17 2017

15:30
24°C

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	L. Thomas Heck Middle School
Building (name/number)	500 508
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	By 508
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	H4
Date of Collection	03/10/17
Time of Collection	05:36
Printed Name of Sample Collector	Thomas M. Rooney
Signature Sample Collector	<i>Thomas M. Rooney</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
BZ-03567	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

MAR 17 2017

15:30
24°C

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	L. Thomas Heck Middle School
Building (name/number)	500/600P By 608
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	608 / 610
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	#5
Date of Collection	03/10/17
Time of Collection	0603
Printed Name of Sample Collector	Thomas M. Rooney
Signature Sample Collector	<i>Thomas M. Rooney</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
BZ-03568	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

MAR 17 2017

15:30
24°C

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	L. Thomas Heck Middle School
Building (name/number)	600/700
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	By 708
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	H6
Date of Collection	03/10/17
Time of Collection	0612
Printed Name of Sample Collector	Thomas M. Rooney
Signature Sample Collector	<i>Thomas M. Rooney</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03569	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 17 2017

15:30
24th

These samples were collected for lead screening purposes only and cannot be used for compliance.