



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ

Lead in Drinking Water School Proj.

1110 W. Washington Street

Phoenix, AZ 85007

Attn: David Burchard

Date Submitted: 03/17/17

Date Reported: 04/07/17

Project: Mabel Padgett Elementary

RESULTS

Client ID: MPE 1
ACT Lab No.: BZ03526

Sample Type: Drinking Water
Sample Time: 03/03/17 06:20

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: MPE 2
ACT Lab No.: BZ03527

Sample Type: Drinking Water
Sample Time: 03/03/17 06:23

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: MPE 3
ACT Lab No.: BZ03528

Sample Type: Drinking Water
Sample Time: 03/03/17 06:26

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: MPE 4
ACT Lab No.: BZ03529

Sample Type: Drinking Water
Sample Time: 03/03/17 06:30

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

RESULTS

Client ID: MPE 5
ACT Lab No.: BZ03530

Sample Type: Drinking Water
Sample Time: 03/03/17 06:32


<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/28/17	03/28/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: MPE 6
ACT Lab No.: BZ03531

Sample Type: Drinking Water
Sample Time: 03/03/17 06:43

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Reviewed by: _____



Frederick A. Amalfi, Ph.D.
Laboratory Director

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.


- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	Mabel Padgett Elementary
Building (name/number)	Admin
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	813
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	MPE 1
Date of Collection	3-3-17
Time of Collection	0620
Printed Name of Sample Collector	Nate Remington
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03526	

For relinquishing samples upon delivery to labs only

Relinquished date and signature  ACT MAR 17 2017


15:30
24°C

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	Mabel Padgett Elementary
Building (name/number)	Cafeteria
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	MPE 2
Date of Collection	3-13-17
Time of Collection	0623
Printed Name of Sample Collector	Nate Bunn
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03527	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ **MAR 17 2017**

These samples were collected for lead screening purposes only and cannot be used for compliance.


15:30
24°C

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	Mabel Padgett Elementary
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Gym
Sample Identification Number (Write this number on the sample container and on this sheet)	MPE 3
Date of Collection	3-13-17
Time of Collection	0626
Printed Name of Sample Collector	Nick Romm
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03528	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 17 2017


15:30
24°C

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	Mabel Padgett Elementary
Building (name/number)	200
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	203
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	MPEY
Date of Collection	3-13-17
Time of Collection	0630
Printed Name of Sample Collector	Nate Pemas
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03529	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ **MAR 17 2017**


15:30
249

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	Mabel Padgett Elementary
Building (name/number)	Media
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Library
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	MBES
Date of Collection	3-13-17
Time of Collection	0632
Printed Name of Sample Collector	Nick Boring
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03530	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ **MAR 17 2017**


These samples were collected for lead screening purposes only and cannot be used for compliance.

15:30
24°C

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Litchfield Elementary District
School Name	Mabel Padgett Elementary
Building (name/number)	700
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	705
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	MPE 6
Date of Collection	3-13-17
Time of Collection	0643
Printed Name of Sample Collector	Nick Rumon
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03531	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____ **MAR 17 2017**

These samples were collected for lead screening purposes only and cannot be used for compliance.

15:30
24°C