

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Sonoran Sky Elementary

Reported:  
04/26/17 14:06

## Analyte

**SSGYM (7042225-01) Drinking Water (Grab) Sampled: 04/18/17 05:59 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:37	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**SS100 (7042225-02) Drinking Water (Grab) Sampled: 04/18/17 05:35 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:40	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**SS400 (7042225-03) Drinking Water (Grab) Sampled: 04/18/17 05:48 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**SS200 (7042225-04) Drinking Water (Grab) Sampled: 04/18/17 05:39 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:45	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**SS500 (7042225-05) Drinking Water (Grab) Sampled: 04/18/17 05:52 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:52	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**SS300 (7042225-06) Drinking Water (Grab) Sampled: 04/18/17 05:43 Received: 04/24/17 11:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1652	04/25/17 09:32	04/25/17 14:55	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Sample Condition Upon Receipt:**

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

---

**Notes and Definitions**

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Pendleburg School Dist #22
School Name	Sonoran Sky Elementary
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Hallway
Sample Identification Number (ensure this number is also on the sample container)	55GYM
Date of Collection	4-18-17
Time of Collection	5:59
Printed Name of Sample Collector	Marjo Murrieta
Signature Sample Collector	Marjo Murrieta

Notes Sample collector:

20.00

For Lab use only

Analyze this drinking water sample for lead
Date and Time Lab received
Signature
Notes:

20.00

For relinquishing samples upon delivery to labs only

Relinquished date and signature

4-19-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Picked up at City  
of PHX 4/24/17 @  
lab 11E

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Pendergast School Dist #72
School Name	Sonoran Sky Elementary
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Hall
Sample Identification Number (ensure this number is also on the sample container)	SS100
Date of Collection	4-18-17
Time of Collection	5:35
Printed Name of Sample Collector	Mario Murrieta
Signature Sample Collector	<i>Mario Murrieta</i>

Notes Sample collector:

20.0°C

For Lab use only

Analyze this drinking water sample for lead
Date and Time Lab received
Signature
Notes:

For relinquishing samples upon delivery to labs only

Relinquished date and signature *[Signature]* 4-19-17

These samples were collected for lead screening purposes only and cannot be used for compliance. Picked up at City of Phx 412917 2 Lab 1145

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Pendogenast School Dist #92
School Name	Sonoran Sky Elementary
Building (name/number)	400
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Hallway
Sample Identification Number (ensure this number is also on the sample container)	SS400
Date of Collection	4-18-17
Time of Collection	5:48
Printed Name of Sample Collector	Phyllis Murnighan
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00	

For relinquishing samples upon delivery to labs only

Relinquished date and signature 4-19-17 [Signature]

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Pendleburg School Dist #22
School Name	Sonoran Sky Elementary
Building (name/number)	200
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Hallway
Sample Identification Number (ensure this number is also on the sample container)	SS200
Date of Collection	4-18-17
Time of Collection	5:39
Printed Name of Sample Collector	David Burchard
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00L	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Pendergast School Dist #92
School Name	Sonoran Sky Elementary
Building (name/number)	500
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Hall way
Sample Identification Number (ensure this number is also on the sample container)	SS500
Date of Collection	4-18-17
Time of Collection	5:52
Printed Name of Sample Collector	Maricela Muniz
Signature Sample Collector	<i>Maricela Muniz</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: 20.00	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Picked up from  
City of PHX 4/24/17  
@ Lab 114  
Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Pendegast School Dist #92
School Name	Sonoran Sky Elementary
Building (name/number)	300
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Hallway
Sample Identification Number (ensure this number is also on the sample container)	SS300
Date of Collection	4-18-17
Time of Collection	8:43
Printed Name of Sample Collector	Mario Alvarez
Signature Sample Collector	<i>Mario Alvarez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	20.0

For relinquishing samples upon delivery to labs only

Relinquished date and signature *[Signature]* 4-19-17

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Picked up from  
City of PHX 4/24/17  
2 Lab  
Page 2 of 2 1145