

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Bostrom Alternative Center

Reported:  
05/23/17 16:25

## Analyte

**1 Confirmation- First Draw (7051872-01) Drinking Water (Grab) Sampled: 05/15/17 05:45 Received: 05/17/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	33	5.0	ug/L	1	B7E1596	05/18/17 15:04	05/19/17 02:33	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**2 Confirmation - Flush (7051872-02) Drinking Water (Grab) Sampled: 05/15/17 05:47 Received: 05/17/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	5.1	5.0	ug/L	1	B7E1596	05/18/17 15:04	05/19/17 02:37	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**3 Confirmation - First Draw Day Two (7051872-03) Drinking Water (Grab) Sampled: 05/16/17 06:28 Received: 05/17/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	19	5.0	ug/L	1	B7E1596	05/18/17 15:04	05/19/17 02:40	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**4 Screening (7051872-04) Drinking Water (Grab) Sampled: 05/16/17 06:30 Received: 05/17/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	14	5.0	ug/L	1	B7E1596	05/18/17 15:04	05/19/17 02:44	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

## Sample Condition Upon Receipt:

Temperature: 22.10 °C  
All samples were received in acceptable condition unless noted otherwise in the case narrative.

## Case Narrative:

**Holding Times:** All holding times were met unless otherwise qualified.  
**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.  
**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.  
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.  
**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

Legend Technical Services of Arizona, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

*Anna Teter*

Client Services Representative

Phone Number: (602) 324-6100

Page 1 of 4

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Bostrom Alternative Center

**Reported:**  
05/23/17 16:25

---

**Notes and Definitions**

7051872

Lead In Schools Confirmation Sampling Log					
School District: Phoenix Union High School District					
School Name: Bostrom Alternative Center					
Building Name/Number/Year Built: 900					
Sample Collector Name and Phone Number: Chris Montenegro 602-768-8051					
Sample ID # (must appear on bottle)	Bottle Size	Fixture Type/ Make and model #	Fixture location	Collection Time	Collection Date
1 Confirmation - First Draw	250 ml	Sink	Yard Shack 900	5:45 AM	5-15-17
2 Confirmation - Flush	250 ml	Sink	Yard Shack 900	5:47 AM	5-15-17
3 Confirmation - First Draw Day Two	1 Liter	Sink	Yard Shack 900	6:28 AM	5-16-17
4 Screening	250 ml	Drinking Fountain	Yard Shack 900	6:30 AM	5-16-17
<h1>RUSH</h1> <p>5/23/17 20 W 5/18/17</p>					
✓					

These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	5/17/17
TIME LAB RECEIVED:	1600
LAB SIGNATURE:	<i>Victoria Neuman</i>
LAB SIGNATORY NAME PRINTED:	Victoria Neuman
NOTES:	22.1°C pHr