



AQUATIC CONSULTING & TESTING, INC.

1525 W. University Drive, Suite 106
P.O. Box 1510
Tempe, Arizona 85281
Phone: (480) 921-8044 • Fax: (480) 921-0049

Lic. No. AZ0003

LABORATORY REPORT

Client: ADEQ

Lead in Drinking Water School Proj.

1110 W. Washington Street

Phoenix, AZ 85007

Attn: David Burchard

Date Submitted: 03/23/17

Date Reported: 04/07/17

Project: Cesar Chavez HS

RESULTS

Client ID: Bldg. 0000-01
ACT Lab No.: BZ03883

Sample Type: Drinking Water
Sample Time: 03/21/17 06:50

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: Bldg. 9000-01
ACT Lab No.: BZ03884

Sample Type: Drinking Water
Sample Time: 03/21/17 06:57

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	2.28	ug/L	SLM

Client ID: Bldg. 8000-01
ACT Lab No.: BZ03885

Sample Type: Drinking Water
Sample Time: 03/21/17 06:47

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: Bldg. 7000-01
ACT Lab No.: BZ03886

Sample Type: Drinking Water
Sample Time: 03/21/17 06:37

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

RESULTS

Client ID: Bldg. 6000-01
ACT Lab No.: BZ03887

Sample Type: Drinking Water
Sample Time: 03/21/17 06:33

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: Bldg. 5000-01
ACT Lab No.: BZ03888

Sample Type: Drinking Water
Sample Time: 03/21/17 06:34

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: Bldg. 4000-01
ACT Lab No.: BZ03889

Sample Type: Drinking Water
Sample Time: 03/21/17 06:31

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	<1.00	ug/L	SLM

Client ID: Bldg. 3000-01
ACT Lab No.: BZ03890

Sample Type: Drinking Water
Sample Time: 03/21/17 06:29

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	2.38	ug/L	SLM

Client ID: Bldg. 2000-01
ACT Lab No.: BZ03891

Sample Type: Drinking Water
Sample Time: 03/21/17 06:43

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	7.86	ug/L	SLM

Client ID: Bldg. 1000-01
ACT Lab No.: BZ03892

Sample Type: Drinking Water
Sample Time: 03/21/17 06:26

<u>Parameter</u>	<u>Analysis Date</u>		<u>Method No.</u>	<u>MDL</u>	<u>Result</u>	<u>Unit</u>	<u>Analyst</u>
	<u>Start</u>	<u>End</u>					
Lead	03/29/17	03/29/17	200.8	1.0	1.61	ug/L	SLM

RESULTS

ha

Reviewed by: _____

Frederick A. Amalfi


Frederick A. Amalfi, Ph.D.
Laboratory Director

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling


Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	0000 Stadium
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Near 0015, outside
Sample Identification Number (Write this number on the sample container and on this sheet)	Bldg. 0000-01
Date of Collection	6:50 AM
Time of Collection	3/21/17
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03883	

For relinquishing samples upon delivery to labs only

Relinquished date and signature



ACT

MAR 23 2017

20°C

15:45


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	9000 Rote/Central Plant
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Between Rm 9007 + 9008
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg 9000-01
Date of Collection	3/21/17
Time of Collection	6:57 AM
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03884	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 23 2017 20°C

15:45


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	8000 Gym/Kitchen
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	Hallway near 8021
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg. 8000-01
Date of Collection	3/24/17
Time of Collection	6:47 A.M.
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03885	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 23 2017 20°C
15:45


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	7000 ART/FOODS/Library
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Hallway near 7008
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg. 7000 - 01
Date of Collection	3/21/17
Time of Collection	6:37 AM
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03886	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

MAR 23 2017


15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	0000 CLASSROOMS
Type of Fixture (tap, drinking fountain etc.)	Teacher Center Sink
Location of Fixture (example, room number)	6121
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg 0000-01
Date of Collection	3/21/17
Time of Collection	6:33 A.M.
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03887	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 23 2017

15:45


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	5000 classrooms
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Outside Building near S/37 Storage Rm
Sample Identification Number (Write this number on the sample container and on this sheet)	Bldg 5000 - 01
Date of Collection	3/21/17
Time of Collection	6:34 A.M.
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03888	

For relinquishing samples upon delivery to labs only

Relinquished date and signature


MAR 23 2017 20°C
15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	4000 classrooms
Type of Fixture (tap, drinking fountain etc.)	Teacher Center Sink
Location of Fixture (example, room number)	4119
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg 4000 - 01
Date of Collection	3/21/17
Time of Collection	6:31 A.M.
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

BZ-03889

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 23 2017


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	3000 Classrooms
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Outside Building near 3224
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	3000-01
Date of Collection	3/21/17
Time of Collection	6:29 AM
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03890	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 23 2017


20°C
15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	2000 PERforming Arts
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	2001
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg. 2000 - 01
Date of Collection	3/21/17
Time of Collection	6:43 A.M.
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03891	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

20C
MAR 23 2017

15:45


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Phoenix Union High School District
School Name	Cesar Chavez High School
Building (name/number)	ADMIN 1000
Type of Fixture (tap, drinking fountain etc.)	DRINKING QUICK fountain
Location of Fixture (example, room number)	NEAR Restroom 1023
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Bldg 1000-01
Date of Collection	3/21/17
Time of Collection	6:26 AM
Printed Name of Sample Collector	Gilbert Sanchez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
BZ-03892	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

MAR 23 2017

15:45

These samples were collected for lead screening purposes only and cannot be used for compliance.