

**STATE OF ARIZONA**  
**AQUIFER PROTECTION PERMIT NO. P-101324**  
**PLACE ID 1378, LTF 72203**  
**SIGNIFICANT AMENDMENT**

**1.0 AUTHORIZATION**

In compliance with the provisions of Arizona Revised Statutes (A.R.S.) Title 49, Chapter 2, Articles 1, 2, and 3, Arizona Administrative Code (A.A.C.) Title 18, Chapter 9, Articles 1 and 2, A.A.C. Title 18, Chapter 11, Article 4 and amendments thereto, and the conditions set forth in this permit, the Arizona Department of Environmental Quality (ADEQ) hereby authorizes the City of Goodyear to operate the City of Goodyear 157<sup>th</sup> Avenue Water Reclamation Facility, located in Goodyear, Arizona, in Maricopa County, over groundwater of the Phoenix Active Management Area in Township 1N, Range 1W, Section 30, SW<sup>1</sup>/<sub>4</sub>, NE<sup>1</sup>/<sub>4</sub>, of the Gila and Salt River Baseline and Meridian.

This permit becomes effective on the date of the Water Quality Division Director's signature and shall be valid for the life of the facility (operational, closure, and post-closure periods) unless suspended or revoked pursuant to A.A.C. R18-9-A213. The permittee shall construct, operate and maintain the permitted facilities:

1. Following all the conditions of this permit including the design and operational information documented or referenced below, and
2. Such that Aquifer Water Quality Standards (AWQS) are not violated at the applicable point(s) of compliance (POC) set forth below or if an AWQS for a pollutant has been exceeded in an aquifer at the time of permit issuance, that no additional degradation of the aquifer relative to that pollutant and as determined at the applicable POC occurs as a result of the discharge from the facility.

**1.1 PERMITTEE INFORMATION**

**Facility Name:** City of Goodyear – 157<sup>th</sup> Avenue Water Reclamation Facility (WRF)  
**Facility Address:** 5424 S 157<sup>th</sup> Ave  
Goodyear, Arizona, 85338  
**County:** Maricopa  
**Permitted Flow Rate:** 6,000,000 gallons per day (gpd)  
**Permittee:** City of Goodyear  
**Permittee Address:** P.O. Box 5100  
Goodyear, Arizona 85338  
**Facility Contact:** Todd Carpenter  
**Emergency Phone No.:** (623) 882-7643  
**Latitude/Longitude:** 33° 23' 59" N/ 112° 23' 51" W  
**Legal Description:** Township 1N, Range 1W, Section 30, SW<sup>1</sup>/<sub>4</sub>, NE<sup>1</sup>/<sub>4</sub> of the Gila and Salt River Baseline and Meridian

**1.2 AUTHORIZING SIGNATURE**

\_\_\_\_\_  
**Trevor Baggione, Director**  
Water Quality Division  
Arizona Department of Environmental Quality

Signed this \_\_\_\_\_ day of \_\_\_\_\_, 2019

**THIS AMENDED PERMIT SUPERCEDES ALL PREVIOUS PERMITS**

## 2.0 SPECIFIC CONDITIONS [A.R.S. §§ 49-203(4), 49-241(A)]

### 2.1 Facility / Site Description [A.R.S. § 49-243(K)(8)]

The permittee is authorized to operate the City of Goodyear - 157<sup>th</sup> Avenue Water Reclamation Facility (WRF) with a maximum average monthly flow of 6 million gallons per day (mgd) upon upgrades at the WRF. The existing train at WRF is rated to treat flow up to 4 mgd.

**4 mgd WRF:** The 4 mgd WRF process consists of an influent pump station, two mechanical fine screens, a grit chamber, three (3) aeration basins with anoxic zones, five (5) clarifiers, three (3) cloth media disc filters, a new chlorine contact basin for chlorination, a de-chlorination system, an reuse pump station, an emergency effluent storage basin, a 1,000,000 gallon reclaimed water storage tank, and a reuse booster pump station. De-chlorination is only required for effluent which will be discharged under Arizona Pollutant Discharge Elimination System (AZPDES) Permit #AZ0022357. Sludge is digested in two (2) aerobic digesters, thickened using a gravity thickener, and dewatered using two (2) centrifuges. Dewatered and/or dried sludge is hauled off-site for management and disposal in accordance with state and federal regulations. The WRF is classified to produce Class A+ reclaimed water according to A.A.C. R18-11, Article 3.

**6 mgd WRF:** The WRF will have capacity to treat 6 mgd of flow upon upgrades at WRF. The treatment process consists of a new influent pump station with three pumps, headwork with two mechanical fine screens, a grit chamber, three (3) aeration basins with anoxic zones and with new diffusers, five (5) clarifiers, three (3) cloth media disc filters and two (2) sand filters, a chlorine contact basin for chlorination with spray aeration system, a de-chlorination system, a new effluent pump station with three pumps and an emergency effluent storage basin. Sludge is digested in two (2) aerobic digesters, thickened using a gravity thickener, and dewatered using three (3) centrifuges. The WRF may receive the waste activated sludge from City of Goodyear – Corgett Wash WRF #102424 for treatment and dewatering. Dewatered and/or dried sludge is hauled off-site for management and disposal in accordance with state and federal regulations. The WRF is classified to produce Class A+ reclaimed water according to A.A.C. R18-11, Article 3.

Effluent may be discharged to the Gila River under the AZPDES permit, delivered to the Buckeye Irrigation District (BID) canal, directed to the Palo Verde pipeline for delivery to Palo Verde Nuclear Generating Station, sent to Palm Valley WRF (APP No. P-100310) via pipeline, recharged at the City of Goodyear Soil Aquifer Treatment (SAT) Site (APP No. P-511420), or recharged at the City of Goodyear – Vadose Injection Project (VIP) (APP No. P-511440).

City of Goodyear 157<sup>th</sup> Avenue WRF may accept reclaimed water from Palm Valley WRF for distribution to reclaimed water customers. Class A+ reclaimed water from City of Goodyear 157<sup>th</sup> Avenue WRF and Palm Valley WRF may be beneficially reused under a valid reclaimed water permit, as per A.A.C. R18-9, Articles 6 and 7.

The outfall to the BID canal is exempt from APP requirements as per A.R.S. § 49-250.B.6. It is not considered to be a discharging facility. Therefore, a Point of Compliance (POC) has not been designated for this outfall.

In the event that a discharge to the Gila River at Outfall 003 exceeds 250,000 gallons per day (gpd) for at least three (3) consecutive months, a well shall be installed at POC No. 3, as specified Section 3.0, items #3 through #6. The well shall be monitored for eight (8) months, and then the permittee shall submit an APP Amendment application to set Alert Levels (ALs) and Aquifer Quality Limits (AQLs) for POC No. 3.

The depth to groundwater is approximately 20 feet below ground surface (bgs), and the direction of groundwater flow is to the west. The WRF was designed and constructed according to plans approved by ADEQ.

ADEQ reviewed and approved the following changes to the permit:

- Re-rating of the treatment plant from 4 mgd to 6 mgd
- Addition of a new influent pump station with a new wet well, three pumps and odor control system
- Replacement of diffusers in aeration basins and aerobic digesters
- Addition of two new Waste Activated Sludge pumps and removal of two Return Activated Sludge pumps (RAS)
- Addition of a new effluent pump station with three new pumps
- Abandonment of existing influent pump station, existing reuse pump station, reclaimed water reservoir and reclaimed water booster pump station
- Addition of one new larger centrifuge for dewatering

All industrial hookups and other non-residential hookups to the treatment system shall be authorized according to the applicable federal, state or local regulations.

The site includes the following permitted discharging facilities:

Facility	Latitude	Longitude
City of Goodyear 157th Avenue WRF	33° 23' 59" N	112° 23' 51" W
Gila River Outfall 001	33° 23' 42" N	112° 23' 30" W
Gila River Outfall 003	33° 23' 41" N	112° 24' 3.9" W
Emergency Effluent Storage Basin	33° 24' 2.56" N	112° 23' 59.49" W

**Annual Registration Fee [A.R.S. § 49-242 and A.A.C. R18-14-104]**

The annual registration fee for this permit is payable to ADEQ each year. The annual registration fee flow rate is established in permit Section 1.1. If the facility is not constructed or is incapable of discharge, the permittee may be eligible for reduced fees under the rule. Send all correspondence requesting reduced fees to the Groundwater Protection Value Stream. Please reference the permit number, LTF number, and the reason for requesting reduced fees under the rule.

**Financial Capability [A.R.S. § 49-243(N) and A.A.C. R18-9-A203 ]**

The permittee has demonstrated financial capability under A.R.S. § 49-243(N) and A.A.C. R18-9-A203. The estimated dollar amount for facility closure is \$1,100,650. The financial capability was demonstrated through A.A.C. R18-9-A203(B)(1)and(2).

**2.2 Best Available Demonstrated Control Technology (BADCT)  
[A.R.S. § 49-243(B) and A.A.C. R18-9-A202(A)(5)]**

The treatment facility shall be designed, constructed, operated, and maintained to meet the treatment performance criteria for new facilities as specified in A.A.C. R18-9-B204. The facility shall meet the performance requirement for industrial pre-treatment as per A.A.C. R18-9-B204(B)(6)(b).

The treatment facility shall not exceed a maximum seepage rate of 550 gallons per day per acre for all containment structures within the treatment works.

**2.2.1 Engineering Design**

The WRF was designed as per the design report prepared and stamped, dated, and signed (sealed) by James P. Albu, P.E. (Professional Engineer), of Malcolm Pirnie, Inc., dated September 13, 2005, and subsequent sealed submittals that served as additions to the design report.

The effluent management facilities included in the 2011 permit amendment were designed as per the design report prepared and sealed by Jessica Anne Dresang, P.E., of Malcolm Pirnie, Inc., dated May 2009. Subsequent submittals that served as additions to the design report were also sealed by Ms. Dresang.

The modification of the filtration system under this amendment was designed as per the design report prepared and sealed by John Matta, P.E., of Water Works Engineers, LLC, dated June 23, 2014. Subsequent submittals that served as additions to the design report were also sealed by Mr. Matta.

The new units at the WRF were designed as per the design report prepared and sealed by Rob Bryan, P.E., Water Works Engineers dated December 11, 2015.

The upgrades at the WRP was designed as per the design report prepared and stamped, dated, and signed (sealed) by Rob Bryant, P.E., Waterworks Engineers dated March 15, 2018 and subsequent sealed submittals that served as additions to the design report.

#### **2.2.2 Site-specific Characteristics**

Site specific characteristics were not used to determine BADCT.

#### **2.2.3 Pre-operational Requirements**

Prior to initiating use of the chlorine contact basin, new influent pump station, an effluent pump station and new waste activated sludge pumps, the permittee shall submit a signed, dated, and sealed Engineer's Certificate of Completion in a format approved by the Department per the compliance schedule in Section 3.0. The certificate shall be submitted to the Groundwater Protection Value Stream.

#### **2.2.4 Operational Requirements**

1. The permittee shall maintain a copy of the up-to-date operations and maintenance manual at the treatment facility site at all times; the manual shall be available upon request during inspections by ADEQ personnel.
2. The pollution control structures shall be inspected for the items listed in Section 4.2, Table III - Facility Inspection (Operational Monitoring).
3. If any damage of the pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and materials used shall be documented in the facility log book as per Section 2.7.2 and reported to ADEQ in the event of a violation or exceedance as per Section 2.7.3.

#### **2.2.5 Reclaimed Water Classification**

**[A.A.C. R18-9-703(C)(2)(a), A.A.C. R18-11-303 through 307]**

The treatment facility is rated as producing reclaimed water meeting the Class A+ Reclaimed Water Quality Standards (A.A.C. R18-11, Article 3) which may be used for any allowable Class A, B, or C use under a valid reclaimed water permit (A.A.C. R18-9, Article 7).

#### **2.2.6 Certified Areawide Water Quality Management Plan Conformance**

**[A.A.C. R18-9-A201(B)(6)(a)]**

Facility operations must conform to the approved Certified Areawide Water Quality Management Plan according to the 208 consistency determination in place at the time of permit issuance.

**2.3 Discharge Limitations [A.R.S. §§ 49-201(14), 49-243 and A.A.C. R18-9-A205(B)]**

1. The permittee is authorized to operate the treatment facility with a maximum average monthly flow of 4.0 mgd per Table IA-I and 6.0 mgd per Table IA-II.
2. The permittee shall notify all users that the materials authorized to be disposed of through the treatment facility are typical household sewage and pre-treated commercial wastewater and shall not include motor oil, gasoline, paints, varnishes, hazardous wastes, solvents, pesticides, fertilizers or other materials not generally associated with toilet flushing, food preparation, laundry facilities and personal hygiene.
3. The permittee shall operate and maintain all permitted facilities to prevent unauthorized discharges pursuant to A.R.S. § 49-201(12) resulting from failure or bypassing of applicable BADCT.
4. Specific discharge limitations are listed in Section 4.2, Tables IA and IB.

**2.4 Point of Compliance (POC) [A.R.S. § 49-244]**

The Points of Compliance (POCs) have been established at the following locations:

POC #	POC Location	Latitude	Longitude
1 (conceptual)	MW-1, located at the southwest boundary of the WRF site	33° 23' 59" N	112° 24' 00" W
2	Approximately 1,300 feet southwest of Gila River Outfall 001	33° 23' 33.2" N	112° 23' 49.4" W
3 (contingency)	Approximately 800 feet west of Gila River Outfall 003	33° 23' 41.3" N	112° 24' 12.7" W

Groundwater monitoring is not required at POC No. 1 at the time of permit issuance. Groundwater monitoring is required at POC No. 2. In the event that discharge to the Gila River at Outfall 003 exceeds 250,000 gpd for at least three (3) consecutive months, the permittee shall install a monitor well at POC No. 3 and begin monitoring as per Section 3.0, Compliance Schedule. The Director may amend this permit to designate additional points of compliance if information on groundwater gradients or groundwater usage indicates the need.

The Director may amend this permit to designate additional points of compliance if information on groundwater gradients or groundwater usage indicates the need.

**2.5 Monitoring Requirements [A.R.S. § 49-243(K)(1), A.A.C. R18-9-A206(A)]**

Unless otherwise specified in this permit, all monitoring required in this permit shall continue for the duration of the permit, regardless of the status of the facility. Unless otherwise provided, monitoring shall commence the first full monitoring period following permit issuance. All sampling, preservation and holding times shall be in accordance with currently accepted standards of professional practice. Trip blanks, equipment blanks and duplicate samples shall also be obtained, and Chain-of-Custody procedures shall be followed, in accordance with currently accepted standards of professional practice. Copies of laboratory analyses and Chain-of-Custody forms shall be maintained at the permitted facility. Upon request, these documents shall be made immediately available for review by ADEQ personnel.

**2.5.1 Pre-Operational Monitoring**

Not applicable

**2.5.2 Routine Discharge Monitoring**

The permittee shall monitor the effluent according to the Routine Discharge Monitoring Table in Section 4.2, Table IA-I and IA-II. Representative samples shall be collected downstream of the reuse booster pump

station for 4 mgd WRF per Table IA-I and representative samples of the effluent shall be collected at the effluent pump station for 6 mgd WRF per Table IA-II.

### **2.5.3 Reclaimed Water Monitoring**

The permittee shall monitor the reclaimed water according to the Class A+ Reclaimed Water Monitoring Table in Section 4.2, Table IB-I and IB-II in addition to the routine discharge monitoring parameters listed in Table IA-I and IA-II. Representative samples of the reclaimed water shall be collected downstream of the reuse booster pump station for 4 mgd WRF per Table IB-I and representative samples of the reclaimed water shall be collected at the effluent pump station for 6 mgd WRF per Table IB-II.

### **2.5.4 Facility / Operational Monitoring**

Operational monitoring inspections shall be conducted according to Section 4.2, Table III.

If any damage of the pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and materials used shall be documented in the facility log book as per Section 2.7.2 and reported to ADEQ in case of a violation or exceedance as per Section 2.7.3.

### **2.5.5 Groundwater Monitoring and Sampling Protocols**

Static water levels shall be measured and recorded prior to sampling. Wells shall be purged of at least three borehole volumes (as calculated using the static water level) or until field parameters (pH, temperature, conductivity) are stable, whichever represents the greater volume. If evacuation results in the well going dry, the well shall be allowed to recover to 80 percent of the original borehole volume, or for 24 hours, whichever is shorter, prior to sampling. If after 24 hours there is not sufficient water for sampling, the well shall be recorded as "dry" for the monitoring event. An explanation for reduced pumping volumes, a record of the volume pumped, and modified sampling procedures shall be reported and submitted with the SMRF.

The permittee may conduct the sampling using the low-flow purging method as described in the Arizona Water Resources Research Center, March 1995 *Field Manual for Water Quality Sampling*. The well must be purged until indicator parameters stabilize. Indicator parameters shall include dissolved oxygen, turbidity, pH, temperature, and conductivity.

#### **2.5.5.1 POC Well Replacement**

In the event that one or more of the designated POC wells should become unusable or inaccessible due to damage, exceedance of an alert level (AL) for water level as required by Section 2.6.2.3.4(3), or any other event, a replacement POC well shall be constructed and installed upon approval by ADEQ. If the replacement well is fifty feet or less from the original well, the ALs and/or aquifer quality limits (AQLs) calculated for the designated POC well shall apply to the replacement well.

### **2.5.6 Surface Water Monitoring and Sampling Protocols**

Routine surface water monitoring is not required under the terms of this permit.

### **2.5.7 Analytical Methodology**

All samples collected for compliance monitoring shall be analyzed using Arizona state-approved methods. If no state-approved method exists, then any appropriate EPA-approved method shall be used. Regardless of the method used, the detection limits must be sufficient to determine compliance with the regulatory limits of the parameters specified in this permit. If all methods have detection limits higher than the applicable limit, the permittee shall follow the applicable contingency requirements of Section 2.6 and may propose "other actions" including amending the permit to set higher limits. Analyses shall be performed by

a laboratory licensed by the Arizona Department of Health Services, Office of Laboratory Licensure and Certification. For results to be considered valid, all analytical work shall meet quality control standards specified in the approved methods. A list of state-certified laboratories in Arizona can be obtained at the address below:

Arizona Department of Health Services  
Office of Laboratory Licensure and Certification  
250 North 17<sup>th</sup> Avenue  
Phoenix, Arizona 85007  
Phone: (602) 364-0720

### **2.5.8 Installation and Maintenance of Monitoring Equipment**

Monitoring equipment required by this permit shall be installed and maintained so that representative samples required by the permit can be collected. If new groundwater wells are determined to be necessary, the construction details shall be submitted to the Groundwater Protection Value Stream for approval prior to installation and the permit shall be amended to include any new monitoring points.

## **2.6 Contingency Plan Requirements**

[A.R.S. § 49-243(K)(3), (K)(7) and A.A.C. R18-9-A204 and R18-9-A205]

### **2.6.1 General Contingency Plan Requirements**

At least one copy of this permit and the approved contingency and emergency response plan submitted in the application shall be maintained at the location where day-to-day decisions regarding the operation of the facility are made. The permittee shall be aware of and follow the contingency and emergency plans.

Any AL exceedance, or violation of an AQL, DL, or other permit condition shall be reported to ADEQ following the reporting requirements in Section 2.7.3, unless more specific reporting requirements are set forth in Section 2.6.2 through 2.6.5.

Some contingency actions involve verification sampling. Verification sampling shall consist of the first follow-up sample collected from a location that previously indicated a violation or the exceedance of an AL. Collection and analysis of the verification sample shall use the same protocols and test methods to analyze for the pollutant or pollutants that exceeded an AL or violated an AQL or DL. Where verification sampling is specified in this permit, it is the option of the permittee to perform such sampling. If verification sampling is not conducted within the timeframe allotted, ADEQ and the permittee shall presume the initial sampling result to be confirmed as if verification sampling had been conducted. The permittee is responsible for compliance with contingency plans relating to the exceedance of an AL or violation of a DL, AQL or any other permit condition. The permittee is subject to enforcement action for the failure to comply with any contingency actions in this permit.

### **2.6.2 Exceeding of Alert Levels and Performance Levels**

#### **2.6.2.1 Exceeding of Performance Levels Set for Operational Conditions**

1. For freeboard operational performance levels, the permittee shall comply with the requirements as specified in Section 4.2, Table III (Facility Inspections) to prevent the overtopping of an emergency storage basin. If an emergency storage basin is overtopped, the permittee shall follow the requirements in Section 2.6.5.3 and the reporting requirements of Section 2.7.3.
2. If an operational performance level set in Section 4.2, Table III has been exceeded the permittee shall:

- a. Notify the Groundwater Protection Value Stream within five (5) days of becoming aware of the exceedance.
- b. Submit a written report to the Groundwater Protection Value Stream within 30 days after becoming aware of the exceedance. The report shall document all of the following:
  - (1) A description of the exceedance and the cause of the exceedance;
  - (2) The period of the exceedance, including exact date(s) and time(s), if known, and the anticipated time period during which the exceedance is expected to continue;
  - (3) Any action taken or planned to mitigate the effects of the exceedance or spill, or to eliminate or prevent recurrence of the exceedance or spill;
  - (4) Any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an AWQS; and
  - (5) Any malfunction or failure of pollution control devices or other equipment or process.
3. The facility is no longer on alert status once the operational indicator no longer indicates that a performance level is being exceeded. The permittee shall, however, complete all tasks necessary to return the facility to its pre-alert operating condition.

#### **2.6.2.2 Exceeding of Alert Levels (ALs) Set for Discharge Monitoring**

1. If an AL set in Section 4.2, Table IA-I and IA-II has been exceeded, the permittee shall immediately investigate to determine the cause. The investigation shall include the following:
  - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the exceedance;
  - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences; and
  - c. If the investigation procedures indicated in (a) and (b) above fail to reveal the cause of the exceedance, the permittee shall sample individual waste streams composing the wastewater for the parameter(s) in question, if necessary to identify the cause of the exceedance.
2. The permittee shall initiate actions identified in the approved contingency plan referenced in Section 5.0 and specific contingency measures identified in Section 2.6 to resolve any problems identified by the investigation which may have led to the AL exceedance. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6.
3. Within thirty days of an AL exceedance, the permittee shall submit the laboratory results to the Groundwater Protection Value Stream along with a summary of the findings of the investigation, the cause of the exceedance, and actions taken to resolve the problem.
4. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

##### **2.6.2.2.1 Exceeding Permit Flow Limit**

If the AL for average monthly flow in Section 4.2, Table IA-II has been exceeded, the permittee shall submit an application to the Groundwater Protection Value Stream for a permit amendment to expand the treatment facility, or submit a report detailing the reasons an expansion is not necessary. Acceptance of the report instead of an application for amendment requires ADEQ approval.



**2.6.2.3 Exceeding of Alert Levels in Groundwater Monitoring**

**2.6.2.3.1 Alert Levels for Indicator Parameters**

No ALs have been established for indicator parameters.

**2.6.2.3.2 Alert Levels for Pollutants with Numeric Aquifer Water Quality Standards**

1. In the case of an exceedance of an AL for a pollutant set in Section 4.2, Table II, the permittee may conduct verification sampling within five (5) days of becoming aware of the exceedance. The permittee may use results of another sample taken between the date of the last sampling event and the date of receiving the result as verification.
2. If verification sampling confirms the AL exceedance or if the permittee opts not to perform verification sampling, then the permittee shall increase the frequency of monitoring for the pollutants set in Section 4.2, Table II as follows:

Specified Monitoring Frequency (Section 4.2, Table II)	Monitoring Frequency for AL Exceedance
Daily	Daily
Weekly	Daily
Monthly	Weekly
Quarterly	Monthly
Semi-annually	Quarterly
Annually	Quarterly

In addition, the permittee shall immediately initiate an investigation of the cause of the AL exceedance, including inspection of all discharging units and all related pollution control devices, review of any operational and maintenance practices that might have resulted in an unexpected discharge, and hydrologic review of groundwater conditions including upgradient water quality.

3. The permittee shall initiate actions identified in the approved contingency plan referenced in Section 5.0 and specific contingency measures identified in Section 2.6 to resolve any problems identified by the investigation which may have led to an AL exceedance. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6. Alternatively, the permittee may submit a technical demonstration, subject to written approval by the Groundwater Protection Value Stream, that although an AL has been exceeded, pollutants are not reasonably expected to cause a violation of an AQL. The demonstration may propose a revised AL or monitoring frequency for approval in writing by the Groundwater Protection Value Stream.
4. Within 30 days after confirmation of an AL exceedance, the permittee shall submit the laboratory results to the Groundwater Protection Value Stream along with a summary of the findings of the investigation, the cause of the exceedance, and actions taken to resolve the problem.
5. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

6. The increased monitoring required as a result of an AL exceedance may be reduced to the monitoring frequency in Section 4.2, Table II if the results of four sequential sampling events demonstrate that no parameters exceed the AL.
7. If the increased monitoring required as a result of an AL exceedance continues for more than six (6) sequential sampling events, the permittee shall submit a second report documenting an investigation of the continued AL exceedance within 30 days of the receipt of laboratory results of the sixth sampling event.

**2.6.2.3.3 Alert Levels to Protect Downgradient Users from Pollutants Without Numeric Aquifer Water Quality Standards**

Not required at time of issuance

**2.6.2.3.4 Alert Level for Groundwater Level**

1. If monitoring indicates the groundwater level is not within the allowable range established by the Alert Level (AL) in Section 4.2, Table IIB, the permittee shall submit a written report to the Groundwater Protection Value Stream within 30 days after becoming aware of the exceedance. The report shall document the following:
  - a. the as-built configuration of the well including the screened interval;
  - b. all groundwater level measurements available for the well;
  - c. a discussion and analysis of any trends or seasonal variations in the groundwater level measurements;
  - d. information on groundwater recharge, withdrawal, or other hydrologic conditions in the vicinity of the well, and;
  - e. any other pertinent information obtained by the permittee.
2. If monitoring indicates the groundwater level is not within the allowable range established by the Alert Level (AL) in Section 4.2, Table IIB for more than six sequential sampling events, the permittee shall submit a second report which evaluates the cause(s) of the exceedance and recommends whether the well should be replaced pursuant to Section 2.5.5.1. The report shall discuss and demonstrate whether samples representative of the water quality of the relevant aquifer can be practicably obtained from the well.
3. Upon review of the submitted report, the Department may amend the permit to require replacement of the well, require additional permit conditions, or other actions.

**2.6.3 Discharge Limit Violation**

1. If a DL set in Section 4.2, Tables IA-I, IA-II or IB-I and IB-II has been violated, the permittee shall immediately investigate to determine the cause. The investigation shall include the following:
  - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the violation;
  - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences;
  - c. If the investigation procedures indicated in (a) and (b) above fail to reveal the cause of the violation, the permittee shall sample individual waste streams composing the wastewater for the parameters in violation, as necessary to identify the cause of the violation.

The permittee shall submit a report to the Groundwater Protection Value Stream according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. The permittee shall consider and ADEQ may require corrective

action that may include control of the source of discharge, cleanup of affected soil, surface water or groundwater, notification of downstream or downgradient users who may be directly affected by the discharge, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ-approved contingency plan, or separately approved according to Section 2.6.6.

2. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions, or other actions.

**2.6.4 Aquifer Quality Limit Violation**

1. If an AQL set in Section 4.2, Table II has been exceeded, the permittee may conduct verification sampling within five (5) days of becoming aware of the exceedance. The permittee may use results of another sample taken between the date of the last sampling event and the date of receiving the result as verification.
2. If the verification sample does not confirm an AQL violation, no further action is needed under this Section.
3. If verification sampling confirms that an AQL was violated for any parameter or if the permittee opts not to perform verification sampling, then, the permittee shall increase the frequency of monitoring as follows:

Specified Monitoring Frequency (Section 4.2, Table II)	Monitoring Frequency for AQL Exceedance
Daily	Daily
Weekly	Daily
Monthly	Weekly
Quarterly	Monthly
Semi-annually	Quarterly
Annually	Quarterly

In addition, the permittee shall immediately initiate an evaluation for the cause of the violation, including inspection of all discharging units and all related pollution control devices, and review of any operational and maintenance practices that might have resulted in unexpected discharge.

The permittee also shall submit a report according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. A verified exceedance of an AQL will be considered a violation unless the permittee demonstrates within 30 days that the exceedance was not caused or contributed to by pollutants discharged from the facility. Unless the permittee has demonstrated that the exceedance was not caused or contributed to by pollutants discharged from the facility, the permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected soil, surface water, or groundwater, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ approved contingency plan, or separately approved according to Section 2.6.6.

4. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

**2.6.5 Emergency Response and Contingency Requirements for Unauthorized Discharges pursuant to A.R.S. § 49-201(12) and pursuant to A.R.S. § 49-241**

**2.6.5.1 Duty to Respond**

The permittee shall act immediately to correct any condition resulting from a discharge pursuant to A.R.S. § 49-201(12) if that condition could pose an imminent and substantial endangerment to public health or the environment.

**2.6.5.2 Discharge of Hazardous Substances or Toxic Pollutants**

In the event of any unauthorized discharge pursuant to A.R.S. § 49-201(12) of suspected hazardous substances (A.R.S. § 49-201(19)) or toxic pollutants (A.R.S. § 49-243(I)) on the facility site, the permittee shall promptly isolate the area and attempt to identify the discharged material. The permittee shall record information, including name, nature of exposure and follow-up medical treatment, if necessary, on persons who may have been exposed during the incident. The permittee shall notify the Groundwater Protection Value Stream within 24 hours of discovering the discharge of hazardous material which (a) has the potential to cause an AWQS or AQL exceedance, or (b) could pose an endangerment to public health or the environment.

**2.6.5.3 Discharge of Non-hazardous Materials**

In the event of any unauthorized discharge pursuant to A.R.S. § 49-201(12) of non-hazardous materials from the facility, the permittee shall promptly attempt to cease the discharge and isolate the discharged material. Discharged material shall be removed and the site cleaned up as soon as possible. The permittee shall notify the Groundwater Protection Value Stream within 24 hours of discovering the discharge of non-hazardous material which has the potential to cause an AQL exceedance, or could pose an endangerment to public health or the environment.

**2.6.5.4 Reporting Requirements**

The permittee shall submit a written report for any unauthorized discharges reported under Sections 2.6.5.2 and 2.6.5.3 to the Groundwater Protection Value Stream within 30 days of the discharge or as required by subsequent ADEQ action. The report shall summarize the event, including any human exposure, and facility response activities and include all information specified in Section 2.7.3. If a notice is issued by ADEQ subsequent to the discharge notification, any additional information requested in the notice shall also be submitted within the time frame specified in the notice. Upon review of the submitted report, ADEQ may require additional monitoring or corrective actions.

**2.6.6 Corrective Actions**

Specific contingency measures identified in Section 2.6 have already been approved by ADEQ and do not require written approval to implement.

With the exception of emergency response actions taken under Section 2.6.5, the permittee shall obtain written approval from the Groundwater Protection Value Stream prior to implementing a corrective action to accomplish any of the following goals in response to exceedance of an AL or violation of an AQL, DL, or other permit condition:

1. Control of the source of an unauthorized discharge;
2. Soil cleanup;
3. Cleanup of affected surface waters;
4. Cleanup of affected parts of the aquifer;
5. Mitigation to limit the impact of pollutants on existing uses of the aquifer.

Within 30 days of completion of any corrective action, the operator shall submit to the Groundwater Protection Value Stream, a written report describing the causes, impacts, and actions taken to resolve the problem.

## **2.7 Reporting and Recordkeeping Requirements**

**[A.R.S. § 49-243(K)(2) and A.A.C. R18-9-A206(B) and R18-9-A207]**

### **2.7.1 Self-Monitoring Report Form**

1. The permittee shall complete the Self-Monitoring Reporting Forms (SMRFs) provided by ADEQ, and submit the completed report through the myDEQ online reporting system. The permittee shall use the format devised by ADEQ.
2. The permittee shall complete the SMRF to the extent that the information reported may be entered on the form. If no information is required during a reporting period, the permittee shall enter “not required” on the form, include an explanation, and submit the form to the Groundwater Protection Value Stream.
3. The tables contained in Section 4.0 list the monitoring parameters and the frequencies for reporting results on the SMRF:
  - Table IA-I, Discharge Monitoring for 4 mgd WRF
  - Table IA-II, Discharge Monitoring for 6 mgd WRF
  - Table IB-I, Reclaimed Water Monitoring for 4 mgd WRF
  - Table IB-II, Reclaimed Water Monitoring for 6 mgd WRF
  - Table II, Groundwater Quality Monitoring

The parameters listed in the above-identified tables from Section 4.0 are the only parameters for which SMRF reporting is required.

### **2.7.2 Operation Inspection / Log Book Recordkeeping**

A signed copy of this permit shall be maintained at all times at the location where day-to-day decisions regarding the operation of the facility are made. A log book (paper copies, forms, or electronic data) of the inspections and measurements required by this permit shall be maintained at the location where day-to-day decisions are made regarding the operation of the facility. The log book shall be retained for ten years from the date of each inspection, and upon request, the permit and the log book shall be made immediately available for review by ADEQ personnel. The information in the log book shall include, but not be limited to, the following information as applicable:

1. Name of inspector;
2. Date and shift inspection was conducted;
3. Condition of applicable facility components;
4. Any damage or malfunction, and the date and time any repairs were performed;
5. Documentation of sampling date and time; and
6. Any other information required by this permit to be entered in the log book.

Monitoring records for each measurement shall comply with A.A.C. R18-9-A206(B)(2).

### **2.7.3 Permit Violation and Alert Level Status Reporting**

1. The permittee shall notify the Groundwater Protection Value Stream in writing (by mail or by fax - see Section 2.7.5) within five (5) days (except as provided in Section 2.6.5) of becoming aware of an AL exceedance, or violation of any permit condition, AQL, or DL for which notification requirements are not specified in Sections 2.6.2 through 2.6.5.

2. The permittee shall submit a written report to the Groundwater Protection Value Stream within 30 days of becoming aware of the violation of any permit condition, AQL, or DL. The report shall document all of the following:
  - a. Identification and description of the permit condition for which there has been a violation and a description of the cause;
  - b. The period of violation including exact date(s) and time(s), if known, and the anticipated time period during which the violation is expected to continue;
  - c. Any corrective action taken or planned to mitigate the effects of the violation, or to eliminate or prevent a recurrence of the violation;
  - d. Any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an AWQS;
  - e. Proposed changes to the monitoring which include changes in constituents or increased frequency of monitoring; and
  - f. Description of any malfunction or failure of pollution control devices or other equipment or processes.

#### **2.7.4 Operational, Other or Miscellaneous Reporting**

The permittee shall record the information as required in Section 4.2, Table III in the facility log book as per Section 2.7.2, and report to the Groundwater Protection Value Stream any violations or exceedances as per Section 2.7.3.

If the treatment facility is classified for reclaimed water under this permit, the permittee shall submit the reclaimed water monitoring results and flow volumes to any of the following in accordance with A.A.C. R18-9-703(C)(2)(c):

1. Any reclaimed water agent who has contracted for delivery of reclaimed water from the permittee; and
2. Any end user who has not waived interest in receiving this information.

#### **2.7.5 Reporting Location**

All Self-Monitoring Report Forms (SMRFs) shall be submitted to:

Arizona Department of Environmental Quality  
Groundwater Protection Value Stream  
Mail Code 5415B-3  
1110 West Washington Street  
Phoenix, Arizona 85007  
Phone (602) 771-4571

Or

Through the myDEQ portal accessible on the ADEQ website at:  
<http://www.azdeq.gov/welcome-mydeq>

All other documents required by this permit to be submitted to the Groundwater Protection Value Stream shall be directed to:

Arizona Department of Environmental Quality  
Groundwater Protection Value Stream  
Mail Code 5415B-3  
1110 West Washington Street  
Phoenix, Arizona 85007  
Phone (602) 771-4999

**2.7.6 Reporting Deadline**

The following table lists the quarterly report due dates:

<b>Monitoring conducted during quarter:</b>	<b>Quarterly Report due by:</b>
January-March	April 30
April-June	July 30
July-September	October 30
October-December	January 30

The following table lists the semi-annual and annual report due dates:

<b>Monitoring conducted:</b>	<b>Report due by:</b>
Semi-annual: January-June	July 30
Semi-annual: July-December	January 30
Annual: January-December	January 30

**2.7.7 Changes to Facility Information in Section 1.0**

The Groundwater Protection Value Stream shall be notified within ten days of any change of facility information including Facility Name, Permittee Name, Mailing or Street Address, Facility Contact Person, or Emergency Telephone Number.

**2.8 Temporary Cessation [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A209(A)]**

The permittee shall give written notice to the Groundwater Protection Value Stream before ceasing operation of the facility for a period of 60 days or greater. The permittee shall take the following measures upon temporary cessation:

1. If applicable, direct the wastewater flows from the facility to another state-approved wastewater treatment facility;
2. Correct the problem that caused the temporary cessation of the facility; and
3. Notify the Groundwater Protection Value Stream with a monthly facility status report describing the activities conducted on the treatment facility to correct the problem.
4. Submittal of Self-Monitoring Report Forms (SMRFs) is still required; report “temporary cessation” in the comment section.

At the time of notification the permittee shall submit for ADEQ approval a plan for maintenance of discharge control systems and for monitoring during the period of temporary cessation. Immediately following ADEQ approval, the permittee shall implement the approved plan. If necessary, ADEQ shall amend permit conditions to incorporate conditions to address temporary cessation. During the period of temporary cessation, the permittee shall provide written notice to the Groundwater Protection Value Stream of the operational status of the facility every three years. If the permittee intends to permanently cease operation of any facility, the permittee shall submit closure notification, as set forth in Section 2.9 below.

**2.9 Closure [A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9-A209(B)]**

For a facility addressed under this permit, the permittee shall give written notice of closure to the Groundwater Protection Value Stream of the intent to cease operation without resuming activity for which the facility was designed or operated. Submittal of SMRFs is still required; report “closure in process” in the comment section.

### **2.9.1 Closure Plan**

Within 90 days following notification of closure, the permittee shall submit for approval to the Groundwater Protection Value Stream, a closure plan which meets the requirements of A.R.S. § 49-252 and A.A.C. R18-9-A209(B)(3).

If the closure plan achieves clean-closure immediately, ADEQ shall issue a letter of approval to the permittee. If the closure plan contains a schedule for bringing the facility to a clean-closure configuration at a future date, ADEQ may incorporate any part of the schedule as an amendment to this permit.

### **2.9.2 Closure Completion**

Upon completion of closure activities, the permittee shall give written notice to the Groundwater Protection Value Stream indicating that the approved closure plan has been implemented fully and providing supporting documentation to demonstrate that clean-closure has been achieved (soil sample results, verification sampling results, groundwater data, as applicable). If clean-closure has been achieved, ADEQ shall issue a letter of approval to the permittee at that time. If any of the following conditions apply, the permittee shall follow the terms of post-closure stated in this permit:

1. Clean-closure cannot be achieved at the time of closure notification or within one year thereafter under a diligent schedule of closure actions;
2. Further action is necessary to keep the facility in compliance with the AWQS at the applicable POC or, for any pollutant for which the AWQS was exceeded at the time this permit was issued, further action is necessary to prevent the facility from further degrading the aquifer at the applicable POC with respect to that pollutant;
3. Remedial, mitigative or corrective actions or controls are necessary to comply with A.R.S. § 49-201(30) and Title 49, Chapter 2, Article 3;
4. Further action is necessary to meet property use restrictions.
5. SMRF submittals are still required until Clean Closure is issued.

### **2.10 Post-closure [A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9 A209(C)]**

Post-closure requirements shall be established based on a review of facility closure actions and will be subject to review and approval by the Groundwater Protection Value Stream.

In the event clean-closure cannot be achieved pursuant to A.R.S. § 49-252, the permittee shall submit for approval to the Groundwater Protection Value Stream a post-closure plan that addresses post-closure maintenance and monitoring actions at the facility. The post-closure plan shall meet all requirements of A.R.S. §§ 49-201(30) and 49-252 and A.A.C. R18-9-A209(C). Upon approval of the post-closure plan, this permit shall be amended or a new permit shall be issued to incorporate all post-closure controls and monitoring activities of the post-closure plan.

#### **2.10.1 Post-Closure Plan**

A specific post-closure plan may be required upon the review of the closure plan.

#### **2.10.2 Post-Closure Completion**

Not required at the time of permit issuance.



**3.0 COMPLIANCE SCHEDULE [A.R.S. § 49-243(K)(5) and A.A.C. R18-9-A208]**

Unless otherwise indicated, for each compliance schedule item listed below, the permittee shall submit the required information to the Groundwater Protection Value Stream.

No.	Description	Due by:	Permit Amendment Required?
<b>Engineer's Certificate of Completion</b>			
1	The permittee shall submit a signed, dated and sealed Engineer's Certificate of Completion, in a format approved by the Department, which confirms that the new chlorine contact basin have been constructed according to the Department-approved design report or plans and specifications, as applicable.	Prior to use of the new chlorine contact basin and within 90 days of completion of construction.	No
2	The permittee shall submit a signed, dated and sealed Engineer's Certificate of Completion, in a format approved by the Department, which confirms that the a new influent pump station, an effluent pump station and new waste activated sludge pumps have been constructed according to the Department-approved design report or plans and specifications, as applicable.	Prior to use of a new influent pump station, an effluent pump station and new waste activated sludge pumps and within 90 days of completion of construction.	No
<b>Groundwater Monitoring at POC No. 3</b>			
3	The permittee shall submit a groundwater monitoring well design, sealed by an Arizona Registered Geologist or other qualified registrant, for ADEQ approval. The well design shall include a screened interval suitable to monitor the top of the aquifer/water table, with no more than 30 feet of screen located beneath the top of the water table and no more than 10 feet located above the top of the water table.	Within 30 days after the 3rd consecutive month during which the monthly average discharge to Gila River Outfall 003 exceeds 250,000 gpd.	No
4	The permittee shall install a groundwater monitoring well at POC No. 3 according to the ADEQ-approved design. Appropriate measures, such as field and downhole geophysical logging shall be used to determine the top of the aquifer. The permittee shall ensure that no more than 30 feet of the screen is installed beneath the top of the water table and no more than 10 feet is installed above the top of the water table.	Within 90 days after the date of submittal of the well design, unless otherwise directed by ADEQ.	No
5	The permittee shall begin initial groundwater sampling of the well at POC No. 3 in accordance with A.A.C. R18-9-A202(A)(6) for all parameters listed in Section 4.2, Table IIA, at the listed sampling frequencies.	Within 30 days after completion of well construction.	No

No.	Description	Due by:	Permit Amendment Required?
6	<p>The permittee shall submit an APP amendment application with a report summarizing the results from the first 8 months of monitoring at POC #3, and propose ALs and AQLs for all the pollutants listed in Section 4.2, Tables IIA and IIB, in accordance with A.A.C. R18-9-A202(A)(6) and A.A.C. R18-9-A205. The permittee shall submit a well completion report, sealed by an Arizona Registered Geologist or other qualified registrant, which includes detailed geologic and well construction logs for the well at POC #3 to the ADEQ Water Permits Section, APP and Reuse Unit. Where identification is possible, the logs should note moisture and the depth at which groundwater is first encountered. The ADWR Registry ID (55 No.) shall be submitted to ADEQ.</p>	<p>Within 15 months after the completion of well construction.</p>	<p>Yes</p>

DRAFT

**4.0 TABLES OF MONITORING REQUIREMENTS**

**4.1 PRE-OPERATIONAL MONITORING (OR CONSTRUCTION REQUIREMENTS)**

Not applicable

DRAFT

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-I (4 mgd WRF)  
ROUTINE DISCHARGE MONITORING**

Sampling Point Number	Sampling Point Identification		Latitude		Longitude
1	Downstream of the reuse booster pump station		33° 23' 59.1" N		112° 24' 1.13" W
Parameter	AL <sup>1</sup>	DL <sup>2</sup>	Units	Sampling Frequency	Reporting Frequency
Total Flow <sup>3</sup> : Daily <sup>4</sup>	NE <sup>5</sup>	NE	mgd <sup>6</sup>	Daily	Quarterly
Total Flow: Monthly Average <sup>7</sup>	3.8	4.0	mgd	Monthly Calculation	Quarterly
Flow: Reuse Daily	NE	NE	mgd	Daily	Quarterly
Flow: Reuse Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: Gila River Outfall 001 Daily	NE	NE	mgd	Daily	Quarterly
Flow: Gila River Outfall 001 Monthly Average	3.8	4.0	mgd	Monthly Calculation	Quarterly
Flow: Gila River Outfall 003 Daily	NE	NE	mgd	Daily	Quarterly
Flow: Gila River Outfall 003 Monthly Average	0.25	NE	mgd	Monthly Calculation	Quarterly
Flow: BID Canal Daily	NE	NE	mgd	Daily	Quarterly
Flow: BID Canal Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: Palo Verde Pipeline Daily	NE	NE	mgd	Daily	Quarterly
Flow: Palo Verde Pipeline Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: SAT Site Daily	NE	NE	mgd	Daily	Quarterly
Flow: SAT Site Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: VIP Daily	NE	NE	mgd	Daily	Quarterly
Flow: VIP Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly

<sup>1</sup> AL = Alert Level

<sup>2</sup> DL = Discharge Limit

<sup>3</sup> Total flow is the sum of flow to reuse, the Gila River outfalls, the BID Canal outfall, the Palo Verde Pipeline, the SAT site, the VIP, and Palm Valley WRF.

<sup>4</sup> Flow shall be measured using a continuous recording flow meter which totals the flow daily.

<sup>5</sup> NE = Not Established = Monitoring is required, but no limits are specified.

<sup>6</sup> mgd = million gallons per day

<sup>7</sup> Monthly = Calculated value = Average of daily flow values in a month.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-I - (4 mgd WRF)  
ROUTINE DISCHARGE MONITORING (continued)**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
2 <sup>8</sup>	Flow meter at the connection to the Palm Valley WRF reclaimed water distribution system, located 3,000 feet west of Palm Valley WRF, at the intersection of McDowell Road and Bullard Avenue			33° 27' 51.48" N	112° 22' 31.08" W
Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Flow: Palm Valley WRF Daily	NE	NE	mgd	Daily	Quarterly
Flow: Palm Valley WRF Monthly	NE	NE	mgd	Monthly Calculation	Quarterly
Sampling Point Number	Sampling Point Identification			Latitude	Longitude
1	Downstream of the reuse booster pump station			33° 23' 59.1" N	112° 24' 1.13" W
Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Fecal Coliform: Single sample maximum	NE	23.0	CFU <sup>9</sup>	Daily	Quarterly
Fecal Coliform: four (4) of seven (7) samples in a week <sup>10</sup>	NE	Non-Detect <sup>11</sup>	CFU	Weekly Calculation	Quarterly
Total Nitrogen <sup>12</sup> : Five-sample rolling geometric mean <sup>13</sup>	8.0	10.0	mg/l <sup>14</sup>	Monthly Calculation	Quarterly

<sup>8</sup> Only effluent flow from City of Goodyear 157<sup>th</sup> Avenue WRF to Palm Valley WRF shall be measured at this sampling point. All other discharge monitoring parameters shall be measured at Sampling Point No. 1.

<sup>9</sup> CFU = Colony Forming Units / 100 ml sample. For CFU, a value of <1.0 shall be considered to be non-detect.

<sup>10</sup> Week means a seven-day period starting on Sunday and ending on the following Saturday. The reporting form for this parameter consists of 13 weeks per quarter.

<sup>11</sup> Fecal Coliform four (4) of the last seven (7) samples” requires entering a “Compliance” or “Not in Compliance” on the SMRF for each day of the reporting period; use the following procedure to determine whether to enter a “Compliance” or “Not in Compliance” for each weekly entry: For each date of the reporting period, evaluate the daily Fecal Coliform result for that date along with the daily Fecal Coliform results for the six previous days. If, of these seven days of data, four (4) or more of the daily Fecal Coliform results are non-detect (a daily value of <1.0 CFU is considered Non-detect for that day), report “Compliance” for that date’s entry on the SMRF. If three (3) or fewer of the daily Fecal Coliform results are Non-detect, report “Not in compliance” for that date’s entry on the SMRF. For days when there is no flow the daily Fecal Coliform result is considered “Non-detect” for the purpose of evaluating the seven days of daily data for the SMRF entry report.

<sup>12</sup> Total Nitrogen = Nitrate as N + Nitrite as N + Total Kjeldahl Nitrogen

<sup>13</sup> The 5-sample rolling geometric mean is determined by multiplying the five (5) most recent monthly sample values together then taking the fifth root of the product. Example:  $GM_5 = \sqrt[5]{(m_1)(m_2)(m_3)(m_4)(m_5)}$

<sup>14</sup> mg/l = milligrams per liter.

**TABLE IA-I - (4 mgd WRF)  
ROUTINE DISCHARGE MONITORING (continued)**

<b>Parameter</b>	<b>AL</b>	<b>DL</b>	<b>Units</b>	<b>Sampling Frequency</b>	<b>Reporting Frequency</b>
<b>Metals (total):</b>					
Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.04	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.08	0.1	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

**TABLE IA-I - (4 mgd WRF)  
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
<b>Volatile and Semi-Volatile Organic Compounds (VOCs and SVOCs):</b>					
Benzene	0.004	0.005	mg/l	Annually	Annually
Carbon tetrachloride	0.004	0.005	mg/l	Annually	Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Annually	Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Annually	Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Annually	Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Annually	Annually
cis-1,2-Dichloroethylene	0.056	0.07	mg/l	Annually	Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Annually	Annually
Dichloromethane	0.004	0.005	mg/l	Annually	Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Annually	Annually
Ethylbenzene	0.56	0.7	mg/l	Annually	Annually
Hexachlorobenzene	0.0008	0.001	mg/l	Annually	Annually
Hexachlorocyclopentadiene	0.04	0.05	mg/l	Annually	Annually
Monochlorobenzene	0.08	0.1	mg/l	Annually	Annually
Styrene	0.08	0.1	mg/l	Annually	Annually
Tetrachloroethylene	0.004	0.005	mg/l	Annually	Annually
Toluene	0.8	1.0	mg/l	Annually	Annually
Trihalomethanes (total) <sup>15</sup>	0.08	0.1	mg/l	Annually	Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Annually	Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Annually	Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Annually	Annually
Trichloroethylene	0.004	0.005	mg/l	Annually	Annually
Vinyl Chloride	0.0016	0.002	mg/l	Annually	Annually
Xylenes (Total)	8.0	10.0	mg/l	Annually	Annually

<sup>15</sup>Total Trihalomethanes (TTHMs) are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-I (6 mgd WRF)  
ROUTINE DISCHARGE MONITORING**

Sampling Point Number	Sampling Point Identification		Latitude	Longitude	
3	Flow meter located on AZPDES discharge line		33° 23' 56.2" N	112° 23' 48.5" W	
4	Flow meter located on line going to Recharge		33° 23' 59.5" N	112° 24' 2.95" W	
Parameter	AL <sup>16</sup>	DL <sup>17</sup>	Units	Sampling Frequency	Reporting Frequency
Total Flow <sup>18</sup> : Daily <sup>19</sup>	NE <sup>20</sup>	NE	mgd <sup>21</sup>	Daily	Quarterly
Total Flow: Monthly Average <sup>22</sup>	5.7	6.0	mgd	Monthly Calculation	Quarterly
Flow: Reuse Daily	NE	NE	mgd	Daily	Quarterly
Flow: Reuse Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: Gila River Outfall 001 Daily	NE	NE	mgd	Daily	Quarterly
Flow: Gila River Outfall 001 Monthly Average	5.7	6.0	mgd	Monthly Calculation	Quarterly
Flow: Gila River Outfall 003 Daily	NE	NE	mgd	Daily	Quarterly
Flow: Gila River Outfall 003 Monthly Average	0.25	NE	mgd	Monthly Calculation	Quarterly
Flow: BID Canal Daily	NE	NE	mgd	Daily	Quarterly
Flow: BID Canal Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: Palo Verde Pipeline Daily	NE	NE	mgd	Daily	Quarterly
Flow: Palo Verde Pipeline Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: SAT Site Daily	NE	NE	mgd	Daily	Quarterly
Flow: SAT Site Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly
Flow: VIP Daily	NE	NE	mgd	Daily	Quarterly
Flow: VIP Monthly Average	NE	NE	mgd	Monthly Calculation	Quarterly

<sup>16</sup> AL = Alert Level

<sup>17</sup> DL = Discharge Limit

<sup>18</sup> Total flow is the sum of flow to reuse, the Gila River outfalls, the BID Canal outfall, the Palo Verde Pipeline, the SAT site, the VIP, and Palm Valley WRF.

<sup>19</sup> Flow shall be measured using a continuous recording flow meter which totals the flow daily.

<sup>20</sup> NE = Not Established = Monitoring is required, but no limits are specified.

<sup>21</sup> mgd = million gallons per day

<sup>22</sup> Monthly = Calculated value = Average of daily flow values in a month.



4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-I (6 mgd WRF)  
ROUTINE DISCHARGE MONITORING (continued)**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
5 <sup>23</sup>	Flow meter at the connection to the Palm Valley WRF reclaimed water distribution system, located 3,000 feet west of Palm Valley WRF, at the intersection of McDowell Road and Bullard Avenue			33° 27' 51.48" N	112° 22' 31.08" W
Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Flow: Palm Valley WRF Daily	NE	NE	mgd	Daily	Quarterly
Flow: Palm Valley WRF Monthly	NE	NE	mgd	Monthly Calculation	Quarterly
Sampling Point Number	Sampling Point Identification			Latitude	Longitude
6	At effluent pump station			33° 23' 59.1" N	112° 24' 1.135" W
Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Fecal Coliform: Single sample maximum	NE	23.0	CFU <sup>24</sup>	Daily	Quarterly
Fecal Coliform: four (4) of seven (7) samples in a week <sup>25</sup>	NE	Non-Detect <sup>26</sup>	CFU	Weekly Calculation	Quarterly
Total Nitrogen <sup>27</sup> : Five-sample rolling geometric mean <sup>28</sup>	8.0	10.0	mg/l <sup>29</sup>	Monthly Calculation	Quarterly

<sup>23</sup> Only effluent flow from City of Goodyear 157<sup>th</sup> Avenue WRF to Palm Valley WRF shall be measured at this sampling point. All other discharge monitoring parameters shall be measured at Sampling Point No. 1.

<sup>24</sup> CFU = Colony Forming Units / 100 ml sample. For CFU, a value of <1.0 shall be considered to be non-detect.

<sup>25</sup> Week means a seven-day period starting on Sunday and ending on the following Saturday. The reporting form for this parameter consists of 13 weeks per quarter.

<sup>26</sup> Fecal Coliform four (4) of the last seven (7) samples” requires entering a “Compliance” or “Not in Compliance” on the SMRF for each day of the reporting period; use the following procedure to determine whether to enter a “Compliance” or “Not in Compliance” for each weekly entry: For each date of the reporting period, evaluate the daily Fecal Coliform result for that date along with the daily Fecal Coliform results for the six previous days. If, of these seven days of data, four (4) or more of the daily Fecal Coliform results are non-detect(a daily value of <1.0 CFU is considered Non-detect for that day), report “Compliance” for that date’s entry on the SMRF. If three (3) or fewer of the daily Fecal Coliform results are Non-detect, report “Not in compliance” for that date’s entry on the SMRF. For days when there is no flow the daily Fecal Coliform result is considered “Non-detect” for the purpose of evaluating the seven days of daily data for the SMRF entry report.

<sup>27</sup> Total Nitrogen = Nitrate as N + Nitrite as N + Total Kjeldahl Nitrogen

<sup>28</sup> The 5-sample rolling geometric mean is determined by multiplying the five (5) most recent monthly sample values together then taking the fifth root of the product. Example:  $GM_5 = \sqrt[5]{(m_1)(m_2)(m_3)(m_4)(m_5)}$

<sup>29</sup> mg/l = milligrams per liter.

**TABLE IA-I (6 mgd WRF)  
ROUTINE DISCHARGE MONITORING (continued)**

<b>Parameter</b>	<b>AL</b>	<b>DL</b>	<b>Units</b>	<b>Sampling Frequency</b>	<b>Reporting Frequency</b>
<b>Metals (total):</b>					
Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.04	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.08	0.1	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

**TABLE IA-I (6 mgd WRF)  
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
<b>Volatile and Semi-Volatile Organic Compounds (VOCs and SVOCs):</b>					
Benzene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	0.56	0.7	mg/l	Semi-Annually	Semi-Annually
Hexachlorobenzene	0.0008	0.001	mg/l	Semi-Annually	Semi-Annually
Hexachlorocyclopentadiene	0.04	0.05	mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) <sup>30</sup>	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	mg/l	Semi-Annually	Semi-Annually

<sup>30</sup>Total Trihalomethanes (TTHMs) are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

TABLE IB-I (4 mgd WRF)  
RECLAIMED WATER MONITORING TABLE - CLASS A+<sup>31</sup>

Sampling Point Number	Sampling Point Identification		Latitude	Longitude
1	Downstream of the reuse booster pump station		33° 23' 59.1" N	112° 24' 3.8" W
Parameter	DL <sup>32</sup>	Units	Sampling Frequency	Reporting Frequency
Fecal Coliform: Single-sample maximum	23.0	CFU <sup>33</sup>	Daily <sup>34</sup>	Quarterly
Fecal Coliform: Four (4) of the last seven (7) samples	Non-detect <sup>35</sup>	CFU	Daily Calculation	Quarterly
Total Nitrogen <sup>36</sup> : Five-sample rolling geometric	10.0	mg/l <sup>38</sup>	Monthly Calculation	Quarterly
Turbidity <sup>39</sup> : Single reading	5.0	NTU <sup>40</sup>	Daily <sup>41</sup>	Quarterly
Turbidity: 24-hour average	2.0	NTU	Daily	Quarterly
Enteric Virus: Four (4) of the last seven (7) samples	Non-detect	PFU <sup>42</sup>	Monthly / Suspended <sup>43</sup>	Quarterly

<sup>31</sup> Reclaimed water monitoring under Table IB shall be performed in addition to routine discharge monitoring required under Section 4.2, Table IA-I.

<sup>32</sup> DL = discharge limit

<sup>33</sup> CFU = Colony Forming Units per 100 ml: For CFU, a value of <1.0 shall be considered to be non-detect.

<sup>34</sup> For fecal coliform only, “daily” sampling means every day in which a sample can practicably be obtained and delivered in sufficient time for proper analysis, provided that no less than four (4) samples in each seven-day period are obtained and analyzed.

<sup>35</sup> Fecal Coliform four (4) of the last seven (7) samples” requires entering a “Compliance” or “Not in Compliance” on the SMRF for each day of the reporting period; use the following procedure to determine whether to enter a “Compliance” or “Not in Compliance” for each daily entry: For each date of the reporting period, evaluate the daily Fecal Coliform result for that date along with the daily Fecal Coliform results for the six previous sample results. If, of these seven samples results, (4) or more of the daily Fecal Coliform results are Non-detect (a daily value of <1.0 CFU is considered Non-detect for that day), report “Compliance” for that date’s entry on the SMRF. If three (3) or fewer of the daily Fecal Coliform results are Non-detect, report “Not in compliance” for that date’s entry on the SMRF. For days when there is no flow of reclaimed water, the daily Fecal Coliform result is considered “Non-detect” for the purpose of evaluating the seven samples of daily data for the SMRF entry.

<sup>36</sup> Nitrate N, plus Nitrite N, plus Total Kjeldahl Nitrogen (TKN)

<sup>37</sup> The 5-sample rolling geometric mean is determined by multiplying the five (5) most recent monthly sample values together then taking the fifth root of the product. *Example:  $GM_5 = \sqrt[5]{(m_1)(m_2)(m_3)(m_4)(m_5)}$*

<sup>38</sup> mg/l = milligrams per liter

<sup>39</sup> Turbidimeter shall be placed at a point in the wastewater treatment process after filtration and immediately before disinfection and shall have a signal averaging time not exceeding 120 seconds. All exceedances must be explained and submitted to the Department with the corresponding quarterly SMRF; occasional spikes due to back-flushing or instrument malfunction shall not be considered an exceedance.

<sup>40</sup> NTU = Nephelometric Turbidity Units

<sup>41</sup> For the single turbidity reading, “daily” means the maximum reading during the 24-hour period.

<sup>42</sup> Plaque Forming Units per 40 Liters. A value of <1.1 PFU/40L shall be considered to be non-detect.

<sup>43</sup> Enteric virus sampling shall resume only when the discharge limit for the 24-hour average for turbidity is exceeded for two (2) consecutive 24-hour monitoring periods. Monthly enteric virus monitoring shall continue until four (4) out of seven (7) consecutive sample results show no detection. During times when enteric virus sampling is suspended, enter “suspended” in the comment section on the SMRF.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IB-II (6 mgd WRF)  
RECLAIMED WATER MONITORING TABLE - CLASS A+<sup>44</sup>**

Sampling Point Number	Sampling Point Identification		Latitude	Longitude
6	At effluent pump station		33° 23' 59.1" N	112° 24' 1.135" W
Parameter	DL <sup>45</sup>	Units	Sampling Frequency	Reporting Frequency
Fecal Coliform: Single-sample maximum	23.0	CFU <sup>46</sup>	Daily <sup>47</sup>	Quarterly
Fecal Coliform: Four (4) of the last seven (7) samples	Non-detect <sup>48</sup>	CFU	Daily Calculation	Quarterly
Total Nitrogen <sup>49</sup> : Five-sample rolling geometric	10.0	mg/l <sup>51</sup>	Monthly Calculation	Quarterly
Turbidity <sup>52</sup> : Single reading	5.0	NTU <sup>53</sup>	Daily <sup>54</sup>	Quarterly
Turbidity: 24-hour average	2.0	NTU	Daily	Quarterly
Enteric Virus: Four (4) of the last seven (7) samples	Non-detect	PFU <sup>55</sup>	Monthly / Suspended <sup>56</sup>	Quarterly

<sup>44</sup> Reclaimed water monitoring under Table IB shall be performed in addition to routine discharge monitoring required under Section 4.2, Table IA-I.

<sup>45</sup> DL = discharge limit

<sup>46</sup> CFU = Colony Forming Units per 100 ml: For CFU, a value of <1.0 shall be considered to be non-detect.

<sup>47</sup> For fecal coliform only, “daily” sampling means every day in which a sample can practicably be obtained and delivered in sufficient time for proper analysis, provided that no less than four (4) samples in each seven-day period are obtained and analyzed.

<sup>48</sup> Fecal Coliform four (4) of the last seven (7) samples” requires entering a “Compliance” or “Not in Compliance” on the SMRF for each day of the reporting period; use the following procedure to determine whether to enter a “Compliance” or “Not in Compliance” for each daily entry: For each date of the reporting period, evaluate the daily Fecal Coliform result for that date along with the daily Fecal Coliform results for the six previous sample results. If, of these seven samples results, (4) or more of the daily Fecal Coliform results are Non-detect (a daily value of <1.0 CFU is considered Non-detect for that day), report “Compliance” for that date’s entry on the SMRF. If three (3) or fewer of the daily Fecal Coliform results are Non-detect, report “Not in compliance” for that date’s entry on the SMRF. For days when there is no flow of reclaimed water, the daily Fecal Coliform result is considered “Non-detect” for the purpose of evaluating the seven samples of daily data for the SMRF entry.

<sup>49</sup> Nitrate N, plus Nitrite N, plus Total Kjeldahl Nitrogen (TKN)

<sup>50</sup> The 5-sample rolling geometric mean is determined by multiplying the five (5) most recent monthly sample values together then taking the fifth root of the product. Example:  $GM_5 = \sqrt[5]{(m_1)(m_2)(m_3)(m_4)(m_5)}$

<sup>51</sup> mg/l = milligrams per liter

<sup>52</sup> Turbidimeter shall be placed at a point in the wastewater treatment process after filtration and immediately before disinfection and shall have a signal averaging time not exceeding 120 seconds. All exceedances must be explained and submitted to the Department with the corresponding quarterly SMRF; occasional spikes due to back-flushing or instrument malfunction shall not be considered an exceedance.

<sup>53</sup> NTU = Nephelometric Turbidity Units

<sup>54</sup> For the single turbidity reading, “daily” means the maximum reading during the 24-hour period.

<sup>55</sup> Plaque Forming Units per 40 Liters. A value of <1.1 PFU/40L shall be considered to be non-detect.

<sup>56</sup> Enteric virus sampling shall resume only when the discharge limit for the 24-hour average for turbidity is exceeded for two (2) consecutive 24-hour monitoring periods. Monthly enteric virus monitoring shall continue until four (4) out of seven (7) consecutive sample results show no detection. During times when enteric virus sampling is suspended, enter “suspended” in the comment section on the SMRF.

**TABLE II  
GROUNDWATER MONITORING**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
7	POC No. 2, approximately 1,300 feet southwest of Gila River Outfall 001 ADWR Well No. 55-913262			33° 23' 33.2" N	112° 23' 49.4" W
Parameter	AL <sup>57</sup>	AQL <sup>58</sup>	Units	Sampling Frequency	Reporting Frequency
Total Nitrogen <sup>59</sup> :	8.0	10.0	mg/l <sup>60</sup>	Monthly Calculation	Quarterly
Nitrate-Nitrite as N	8.0	10.0	mg/l	Monthly Calculation	Quarterly
Nitrate as N	8.0	10.0	mg/l	Monthly	Quarterly
Nitrite as N	0.8	1.0	mg/l	Monthly	Quarterly
Total Kjeldahl Nitrogen (TKN)	Not Established <sup>61</sup>	Not Established	mg/l	Monthly	Quarterly
Total Coliform	Absence <sup>62</sup>	Absence	P/A <sup>63</sup>	Monthly	Quarterly
Fecal Coliform	Non-detect <sup>64</sup>	Not Established	CFU <sup>65</sup>	Monthly	Quarterly
Depth to Water (upper Limit)	Monitor	Not Established	ft. bgs <sup>66</sup>	Monthly	Quarterly
Depth to Water (Lower Limit)	50	Not Established	ft. bgs	Monthly	Quarterly

<sup>57</sup> AL = Alert Level

<sup>58</sup> AQL = Aquifer Quality Limit

<sup>59</sup> The calculation for Total Nitrogen is Nitrate as N plus Nitrite as N plus TKN.

<sup>60</sup> mg/l = milligrams per liter

<sup>61</sup> Not Established means monitoring is required, but no limits are specified.

<sup>62</sup> Each groundwater sample shall be analyzed for both total and fecal coliforms. A positive total coliform result followed by a negative fecal coliform result shall not be considered an exceedance of AL. A positive result for both total coliform and fecal coliform in the same sample shall be considered an exceedance of AL.

<sup>63</sup> P/A = Presence or absence of total coliforms in a 100-milliliter sample. If total coliforms are present, enter “Non-compliance on the SMRF. If total coliforms are absent, enter “Compliance” on the SMRF.

<sup>64</sup> For CFU, a value of <1.0 shall be considered to be non-detect.

<sup>65</sup> CFU = Colony Forming Units / 100ml sample.

<sup>66</sup> ft. bgs – feet below ground surface

**TABLE II**  
**GROUNDWATER MONITORING (continued)**

<b>Parameter</b>	<b>AL</b>	<b>DL</b>	<b>Units</b>	<b>Sampling Frequency</b>	<b>Reporting Frequency</b>
<b>Metals (total):</b>					
Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.04	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.08	0.1	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

**TABLE II**  
**GROUNDWATER MONITORING (continued)**

Parameter	AL	AQ	Units	Sampling Frequency	Reporting Frequency
<b>Volatile and Semi-Volatile Organic Compounds (VOCs and SVOCs):</b>					
Benzene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	0.56	0.7	mg/l	Semi-Annually	Semi-Annually
Hexachlorobenzene	0.0008	0.001	mg/l	Semi-Annually	Semi-Annually
Hexachlorocyclopentadiene	0.04	0.05	mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) <sup>67</sup>	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	mg/l	Semi-Annually	Semi-Annually

<sup>67</sup> Total Trihalomethanes are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.



**TABLE III**  
**FACILITY INSPECTION (OPERATIONAL MONITORING)<sup>68</sup>**

<b>Pollution Control Structure/Parameter</b>	<b>Performance Level</b>	<b>Inspection Frequency</b>	<b>Reporting Frequency</b>
Emergency Storage Basin Freeboard	Two (2) Linear Feet	Weekly	See Section 2.7.3
Pump Integrity	Good working condition	Weekly	See Section 2.7.3
Treatment Plant Components	Good working condition	Weekly	See Section 2.7.3
Stormwater Diversion Berm Integrity	No visible structural damage, breach, or erosion of embankments	Monthly	See Section 2.7.3
Emergency Storage Basin	No visible cracks or seepage Not overgrown with vegetation	Monthly	See Section 2.7.3

<sup>68</sup> The permittee shall record the inspection performance levels in a log book as per Section 2.7.2, and report any violations or exceedances as per Section 2.7.3. In the case of an exceedance, identify which structure exceeds the performance level in the log book.

## 5.0 REFERENCES AND PERTINENT INFORMATION

The terms and conditions set forth in this permit have been developed based upon the information contained in the following, which are on file with the Department:

1. APP Application, dated: September 13, 2018
2. Contingency Plan, dated: January 10, 2019
3. Final Hydrologist Report, dated: March 1, 2019
4. Final Engineering Report, dated: February 27, 2019
5. Public Notice, dated: XXXXXX
6. Responsiveness Summary, dated: XXXXXX

DRAFT

## **6.0 NOTIFICATION PROVISIONS**

### **6.1 Annual Registration Fees**

The permittee is notified of the obligation to pay an Annual Registration Fee to ADEQ. The Annual Registration Fee is based on the amount of daily influent or discharge of pollutants in gallons per day (gpd) as established by A.R.S. § 49-242.

### **6.2 Duty to Comply [A.R.S. §§ 49-221 through 263]**

The permittee is notified of the obligation to comply with all conditions of this permit and all applicable provisions of Title 49, Chapter 2, Articles 1, 2 and 3 of the Arizona Revised Statutes, Title 18, Chapter 9, Articles 1 through 4, and Title 18, Chapter 11, Article 4 of the Arizona Administrative Code. Any permit non-compliance constitutes a violation and is grounds for an enforcement action pursuant to Title 49, Chapter 2, Article 4 or permit amendment, suspension, or revocation.

### **6.3 Duty to Provide Information [A.R.S. §§ 49-243(K)(2) and 49-243(K)(8)]**

The permittee shall furnish to the Director, or an authorized representative, within a time specified, any information which the Director may request to determine whether cause exists for amending or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

### **6.4 Compliance with Aquifer Water Quality Standards [A.R.S. §§ 49-243(B)(2) and 49-243(B)(3)]**

The permittee shall not cause or contribute to a violation of an Aquifer Water Quality Standard (AWQS) at the applicable point of compliance (POC) for the facility. Where, at the time of issuance of the permit, an aquifer already exceeds an AWQS for a pollutant, the permittee shall not discharge that pollutant so as to further degrade, at the applicable point of compliance for the facility, the water quality of any aquifer for that pollutant.

### **6.5 Technical and Financial Capability [A.R.S. §§ 49-243(K)(8) and 49-243(N) and A.A.C. R18-9-A202(B) and R18-9-A203(E) and (F)]**

The permittee shall have and maintain the technical and financial capability necessary to fully carry out the terms and conditions of this permit. Any bond, insurance policy, trust fund, or other financial assurance mechanism provided as a demonstration of financial capability in the permit application, pursuant to A.A.C. R18-9-A203(C), shall be in effect prior to any discharge authorized by this permit and shall remain in effect for the duration of the permit.

### **6.6 Reporting of Bankruptcy or Environmental Enforcement [A.A.C. R18-9-A207(C)]**

The permittee shall notify the Director within five days after the occurrence of any one of the following:

1. the filing of bankruptcy by the permittee; or
2. the entry of any order or judgment not issued by the Director against the permittee for the enforcement of any environmental protection statute or rule.

### **6.7 Monitoring and Records [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A206]**

The permittee shall conduct any monitoring activity necessary to assure compliance with this permit, with the applicable water quality standards established pursuant to A.R.S. §§ 49-221 and 49-223 and §§ 49-241 through 49-252.

**6.8 Inspection and Entry [A.R.S. §§ 49-1009, 49-203(B), and 49-243(K)(8)]**

In accordance with A.R.S. §§ 41-1009 and 49-203(B), the permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to enter and inspect the facility as reasonably necessary to ensure compliance with Title 49, Chapter 2, Article 3 of the Arizona Revised Statutes, and Title 18, Chapter 9, Articles 1 through 4 of the Arizona Administrative Code and the terms and conditions of this permit.

**6.9 Duty to Modify [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A211]**

The permittee shall apply for and receive a written amendment before deviating from any of the designs or operational practices authorized by this permit.

**6.10 Permit Action: Amendment, Transfer, Suspension, and Revocation  
[A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]**

This permit may be amended, transferred, suspended, or revoked for cause, under the rules of the Department. The permittee shall notify the Groundwater Protection Value Stream in writing within 15 days after any change in the owner or operator of the facility. The notification shall state the permit number, the name of the facility, the date of property transfer, and the name, address, and phone number where the new owner or operator can be reached. The operator shall advise the new owner or operators of the terms of this permit and the need for permit transfer in accordance with the rules.

**7.0 ADDITIONAL PERMIT CONDITIONS**

**7.1 Other Information [A.R.S. § 49-243(K)(8)]**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, the permittee shall promptly submit the correct facts or information.

**7.2 Severability  
[A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]**

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby. The filing of a request by the permittee for a permit action does not stay or suspend the effectiveness of any existing permit condition.

**7.3 Permit Transfer**

This permit may not be transferred to any other person except after notice to and approval of the transfer by the Department. No transfer shall be approved until the applicant complies with all transfer requirements as specified in A.A.C. R18-9-A212(B) and (C).