

STATE OF ARIZONA
AQUIFER PROTECTION PERMIT NO. P-105248
PLACE ID 6578, LTF 77602
SIGNIFICANT AMENDMENT

1.0 AUTHORIZATION

In compliance with the provisions of Arizona Revised Statutes (A.R.S.) Title 49, Chapter 2, Articles 1, 2, and 3, Arizona Administrative Code (A.A.C.) Title 18, Chapter 9, Articles 1 and 2, A.A.C. Title 18, Chapter 11, Article 4 and amendments thereto, and the conditions set forth in this permit, the Arizona Department of Environmental Quality (ADEQ) hereby authorizes Munds Park RV Campground Wastewater Treatment System, located at 17550 Munds Ranch Road, Pinewood AZ 86017, in Coconino County, over groundwater of the Verde River Basin in Township 18 N, Range 7 E, Section 16 N½ NE¼ SW¼ and S ½ SE¼ NW¼ of the Gila and Salt River Base Line and Meridian.

This permit becomes effective on the date of the Water Quality Division Director's signature and shall be valid for the life of the facility (operational, closure, and post-closure periods) unless suspended or revoked pursuant to A.A.C. R18-9-A213. The permittee shall construct, operate and maintain the permitted facilities:

1. Following all the conditions of this permit including the design and operational information documented or referenced below, and
2. Such that Aquifer Water Quality Standards (AWQS) are not violated at the applicable point(s) of compliance (POC) set forth below or if an AWQS for a pollutant has been exceeded in an aquifer at the time of permit issuance, that no additional degradation of the aquifer relative to that pollutant and as determined at the applicable POC occurs as a result of the discharge from the facility.

1.1. PERMITTEE INFORMATION

Facility Name: Munds Park RV Campground Wastewater Treatment System
Facility Address: 17550 Munds Ranch Road,
Munds Park, Arizona 86017
County: Coconino
Permitted Flow Rate: 44,600 gallons per day
Permittee: Munds Park RV Resort, Inc.
Permittee Address: 2200 N Central Ave., Suite #105
Phoenix, AZ 85004
Facility Contact: Cindi Eagleton
Emergency Phone No.: 602-400-0990
Latitude/Longitude: 34° 56' 35" N/ 111° 39' 28" W
Legal Description: Township 18 N, Range 7 E, Section 16 N½ NE¼ SW¼ and S ½ SE¼ NW¼ of
the Gila and Salt River Base Line and Meridian

1.2. AUTHORIZING SIGNATURE

Trevor Baggione, Director

Water Quality Division

Arizona Department of Environmental Quality

Signed this _____ day of _____, 2020

THIS AMENDED PERMIT SUPERCEDES ALL PREVIOUS PERMITS

TABLE OF CONTENTS

1.0 AUTHORIZATION 1

1.1. PERMITTEE INFORMATION 1

1.2. AUTHORIZING SIGNATURE 1

2.0 SPECIFIC CONDITIONS..... 4

2.1. FACILITY / SITE DESCRIPTION 4

2.1.1. Annual Registration Fee 5

2.1.2. Financial Capability..... 5

2.2. BEST AVAILABLE DEMONSTRATED CONTROL TECHNOLOGY (BADCT) 5

2.2.1. Engineering Design 5

2.2.2. Site-Specific Characteristics 5

2.2.3. Pre-Operational Requirements..... 6

2.2.4. Operational Requirements 6

2.2.5. Reclaimed Water Classification 6

2.2.6. Certified Areawide Water Quality Management Plan Conformance 6

2.3. DISCHARGE LIMITATIONS 6

2.4. POINT OF COMPLIANCE (POC)..... 6

2.4.1. BADCT ALERT LEVEL WELLS for PHASE II 7

2.5. MONITORING REQUIREMENTS 7

2.5.1. Pre-Operational Monitoring..... 7

2.5.2. Routine Discharge Monitoring 7

2.5.3. Reclaimed Water Monitoring 7

2.5.4. Facility / Operational Monitoring 7

2.5.5. Groundwater Monitoring And Sampling Protocols..... 8

2.5.5.1. POC Well Replacement 8

2.5.6. Surface Water Monitoring And Sampling Protocols 8

2.5.7. Analytical Methodology 8

2.5.8. Installation And Maintenance Of Monitoring Equipment 8

2.6. CONTINGENCY PLAN REQUIREMENTS 9

2.6.1. General Contingency Plan Requirements 9

2.6.2. Exceeding Of Alert Levels And Performance Levels 9

2.6.2.1. Exceeding Of Performance Levels Set For Operational Conditions 9

2.6.2.2. Exceeding Of Alert Levels (ALs) Set For Discharge Monitoring..... 9

2.6.2.3. Exceeding Of Alert Levels In Groundwater Monitoring 10

2.6.2.3.1. Alert Levels For Indicator Parameters 10

2.6.2.3.2. Alert Levels For Pollutants With Numeric Aquifer Water Quality Standards..... 10

2.6.2.3.3. Alert Levels To Protect Downgradient Users From Pollutants Without Numeric Aquifer Water Quality Standards 11

2.6.2.3.4. Alert Level For Groundwater Level 11

2.6.3. Discharge Limit Violation 11

2.6.4. Aquifer Quality Limit Exceedances 12

2.6.5. Emergency Response And Contingency Requirements For Unauthorized Discharges 13

2.6.5.1. Duty To Respond 13

2.6.5.2. Discharge Of Hazardous Substances Or Toxic Pollutants 13

2.6.5.3. Discharge Of Non-Hazardous Materials 13

2.6.5.4. Reporting Requirements 13

2.6.6. Corrective Actions 13

2.7. REPORTING AND RECORDKEEPING REQUIREMENTS 14

2.7.1. Self-Monitoring Report Form..... 14

2.7.2. Operation Inspection / Log Book Recordkeeping 14

2.7.3. Permit Violation And Alert Level Status Reporting..... 14

- 2.7.4. Operational, Other Or Miscellaneous Reporting 15
- 2.7.5. Reporting Location 15
- 2.7.6. Reporting Deadline 15
- 2.7.7. Changes To Facility Information In Section 1.0 16
- 2.8. TEMPORARY CESSATION 16
- 2.9. CLOSURE..... 16
 - 2.9.1. Closure Plan..... 16
 - 2.9.2. Closure Completion 17
- 2.10. POST-CLOSURE..... 17
 - 2.10.1. Post-Closure Plan..... 17
 - 2.10.2. Post-Closure Completion..... 17
- 3.0 COMPLIANCE SCHEDULE 18**
- 4.0 TABLES OF MONITORING REQUIREMENTS 20**
 - 4.1. PRE-OPERATIONAL MONITORING (OR CONSTRUCTION REQUIREMENTS) 20
 - 4.2. COMPLIANCE OR OPERATIONAL MONITORING 20
- 5.0 REFERENCES AND PERTINENT INFORMATION 24**
- 6.0 NOTIFICATION PROVISIONS 24**
 - 6.1. ANNUAL REGISTRATION FEES 24
 - 6.2. DUTY TO COMPLY 24
 - 6.3. DUTY TO PROVIDE INFORMATION 24
 - 6.4. COMPLIANCE WITH AQUIFER WATER QUALITY STANDARDS 24
 - 6.5. TECHNICAL AND FINANCIAL CAPABILITY 25
 - 6.6. REPORTING OF BANKRUPTCY OR ENVIRONMENTAL ENFORCEMENT 25
 - 6.7. MONITORING AND RECORDS 25
 - 6.8. INSPECTION AND ENTRY 25
 - 6.9. DUTY TO MODIFY 25
 - 6.10. PERMIT ACTION: AMENDMENT, TRANSFER, SUSPENSION, AND REVOCATION 25
- 7.0 ADDITIONAL PERMIT CONDITIONS 25**
 - 7.1. OTHER INFORMATION..... 25
 - 7.2. SEVERABILITY 26
 - 7.3. PERMIT TRANSFER 26

TABLE OF TABLES

- TABLE 1: DISCHARGING FACILITIES 5
- TABLE 2: POINT(S) OF COMPLIANCE 6
- TABLE 3: BADCT ALERT LEVEL WELLS 7
- TABLE 4: ACCELERATED MONITORING - ALERT LEVEL EXCEEDANCE 10
- TABLE 5: ACCELERATED MONITORING - AQUIFER QUALITY LIMIT VIOLATION 12
- TABLE 6: QUARTERLY REPORTING DEADLINES 15
- TABLE 7: (SEMI-)ANNUAL REPORTING DEADLINES 16
- TABLE 8: COMPLIANCE SCHEDULE ITEMS 18
- TABLE 9: ROUTINE DISCHARGE MONITORING FOR PHASE II SYSTEM 20
- TABLE 10: GROUNDWATER MONITORING 22
- TABLE 11: FACILITY INSPECTION AND OPERATIONAL MONITORING 23
- TABLE 12: FACILITY INSPECTION AND OPERATIONAL MONITORING FOR PHASE III..... 23

2.0 SPECIFIC CONDITIONS

[A.R.S. §§ 49-203(4), 49-241(A)]

2.1 FACILITY / SITE DESCRIPTION

[A.R.S. § 49-243(K)(8)]

The permittee is authorized to operate Munds Park RV Campground Wastewater Treatment System (WWTS) with a maximum flow of 44,600 gallons per day (gpd) from four phases. The WWTS serves RV sites from Phase I, IA, II and III. Once the Phase III flows are diverted to Pinewood Sanitary District Wastewater Treatment Plant (WWTP), the flow for the Munds Park WWTS will be reduced to 34,000 gpd from Phase I, IA and II.

Phase I System: Phase I system is designed to treat 17,156 gallons per day (gpd) of flow from 142 RV spaces, a general store, a commercial swimming pool, two apartments and laundry machines. Phase I consists of 14 septic tanks with disposal through leach lines.

Phase IA System: Phase IA consists of the individual wastewater treatment systems for the Shopping Center and Recreation Buildings. The treatment system for the Shopping Center consists of a grease trap interceptor, two 5,500 gallon septic tanks, one recirculation tanks, an Advantex AX-100 Textile filter, chlorinator/dechlorinator and the pump tank. The flow is designed to be 2,100 gpd for the Shopping Center. The effluent is discharged to a drip irrigation system buried one foot in depth. The Recreation Buildings System is designed for flow of 700 gpd and consists of two 1,700 gallon septic tanks, a grease trap interceptor, two Advantex AX-20 filters, one 4,000 gallon recirculation tank/surge tank, Norweco XT-discharged to infiltrator trenches. The total flow for Phase IA is approximately 2,800 gpd.

Phase II System: Phase II System is designed to treat flow of 14,037 gpd. Phase II System serves 122 RV spaces and a laundry facility with 6 washing machines. Phase II system consists of 14 septic tanks, 12 distribution field pumps, and 10 disposal beds. The disposal beds are constructed of a layer of silt, filter fabric, coarse gravel and sawdust. The facility is required to monitor the Best Available Demonstrated Control Technology (BADCT) Alert Level wells MW-4, MW-5 and MW-6 in lieu of the L-shaped effluent sampling ports for Phase II System per Table 9. This monitoring will be conducted only during the normal months of operation of the RV Campground, which is from 1st April to 31st October every year.

Phase III System: Phase III system is designed to treat 10,600 gpd of flow. Phase III consists of 106 RV spaces that includes 6 septic tanks (a series of 5 larger septic tanks and 1 smaller septic tanks), 2 pumping stations, and 2 larger disposal fields. The disposal beds are constructed of a layer of silt, filter fabric, coarse gravel, and sawdust.

Phase III will be connected to the Pinewood Sanitary District WWTP (PWSD) and the wastewater flow from Phase III will be diverted for treatment to PWSD WWTP. Until the Phase III flow is diverted, the facility shall continue the facility inspection for Phase III system per Table 12. The facility shall notify Groundwater Protection Value Stream upon connecting to the PWSD WWTP per Table 8: COMPLIANCE SCHEDULE ITEMS, Compliance Schedule Item #1. The facility shall conduct the closure of Phase III per approved closure plan per Compliance Schedule Item #3. In case, the facility decides not to connect to PWSD WWTP, the facility shall submit an amendment application to add the monitoring requirements for Phase III per Compliance Schedule Item #2.

The Munds Park RV Campground (Campground) is only open from 1st April to 31st October every year and closed during other months of the year. There will not be any flow to the WWTS during the months of closure. The permittee is not required to provide any written notification regarding the cessation of the Campground during the normal closure which is from November to March. The cessation of WWTS during these five months is considered a normal operational practice for the Campground and the requirements of Temporary Cessation per Section 2.8 of the permit does not apply during these months. If the WWTS is closed during the normal operational months of the Campground, the permittee shall provide the notification to ADEQ as required per the Section 2.8, Temporary Cessation.

ADEQ reviewed and approved the following changes to the permit:

1. Allowance of monitoring of BADCT Alert Level wells MW-4, MW-5 and MW-6 in lieu of the L-shaped effluent sampling ports per Table 9 for discharge monitoring in the permit.
2. Updated the closure and post closure cost and financial assurance mechanism for the facility.
3. Allowance to conduct discharge and groundwater monitoring only during the operational season of the RV Park, which is from 1st April to 31st October every year.
4. Addition of the groundwater monitoring requirements in the permit for monitoring well POC-1.
5. Addition of the compliance schedule item to reduce the monitoring requirements for Phase II after two operational seasons of monitoring.
6. Approval of closure plan for Phase III system. Once Phase III flow will be diverted to the Pinewood Sanitary District WWTP, Phase III system will be closed per the closure plan submitted under this amendment.

All industrial hookups and other non-residential hookups to the treatment system shall be authorized according to the applicable federal, state or local regulations.

The site includes the following permitted discharging facilities:

Table 1: DISCHARGING FACILITIES		
Facility	Latitude	Longitude
Phase I	34° 56' 35" N	111° 39' 28" W
Phase IA	34° 56' 35.2" N	111° 39' 25.2" W
Phase II	34° 56' 36" N	111° 39' 33" W
Phase III	34° 56' 41" N	111° 39' 34" W

2.1.1. Annual Registration Fee

[A.R.S. § 49-242 and A.A.C. R18-14-104]

The annual registration fee for this permit is payable to ADEQ each year. The annual registration fee flow rate is established by the permitted flow rate identified in Section 1.1.

2.1.2. Financial Capability

[A.R.S. § 49-243(N) and A.A.C. R18-9-A203]

The permittee has demonstrated financial capability under A.R.S. § 49-243(N) and A.A.C. R18-9-A203. The estimated dollar amount for facility closure is \$51,100. The financial capability will be demonstrated through cash deposit per A.A.C. R18-9-A203(C)(7) or Letter of Credit per A.A.C. R18-9-A203(C)(5).

2.2. BEST AVAILABLE DEMONSTRATED CONTROL TECHNOLOGY (BADCT)

[A.R.S. § 49-243(B) and A.A.C. R18-9-A202(A)(5)]

Phase II & III Wastewater Treatment System is designed to meet the treatment performance criteria for new facilities as specified in Arizona Administrative Code R18-9-B204. Phase I and IA has been operating under a Type 4.23 General APP.

2.2.1. Engineering Design

The Phase III Wastewater Treatment System was designed as per the design report dated October 2002 and design plans dated May 15, 2002.

2.2.2. Site-Specific Characteristics

Not applicable.

2.2.3. Pre-Operational Requirements

Not applicable.

2.2.4. Operational Requirements

1. The permittee shall maintain a copy of the up-to-date operations and maintenance manual at the treatment facility site at all times; the manual shall be available upon request during inspections by ADEQ personnel.
2. The pollution control structures shall be inspected for the items listed in Section 4.2, Table 11 and Table 12.
3. If any damage of the pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and materials used shall be documented in the facility log book as per Section 2.7.2 and reported to ADEQ in the event of a violation or exceedance as per Section 2.7.3.

2.2.5. Reclaimed Water Classification

[A.A.C. R18-9-B701(C)(2)(a), A.A.C. R18-11-303 through 307]

Not applicable.

2.2.6. Certified Areawide Water Quality Management Plan Conformance

[A.A.C. R18-9-A201(B)(6)(a)]

Facility operations must conform to the approved Certified Areawide Water Quality Management Plan according to the 208 consistency determination in place at the time of permit issuance.

2.3. DISCHARGE LIMITATIONS

[A.R.S. §§ 49-201(14), 49-243 and A.A.C. R18-9-A205(B)]

1. The permittee is authorized to operate the treatment systems with a total flow of 44,600 gpd for Phase I, IA, II and III and with a total flow of 34,000 gpd for Phase I, IA and II.
2. The permittee shall notify all users that the materials authorized to be disposed of through the treatment facility are typical household sewage and pre-treated commercial wastewater and shall not include motor oil, gasoline, paints, varnishes, hazardous wastes, solvents, pesticides, fertilizers or other materials not generally associated with toilet flushing, food preparation, laundry facilities and personal hygiene.
3. The permittee shall operate and maintain all permitted facilities to prevent unauthorized discharges pursuant to A.R.S. § 49-201(12) resulting from failure or bypassing of applicable BADCT.
4. Specific discharge limitations are listed in Section 4.2, Table 9: ROUTINE DISCHARGE MONITORING FOR PHASE II SYSTEM .

2.4. POINT OF COMPLIANCE (POC)

[A.R.S. § 49-244]

The Points of Compliance (POCs) have been established at the following locations:

Table 2: POINT(S) OF COMPLIANCE					
POC #	POC Location	Latitude (North)	Longitude (West)	ADWR Well #	Screen Interval (ft bgs)
1	Southeastern edge of the facility	34° 56' 52"	111° 39' 43.2"	55-218577	6-39

Groundwater monitoring is required at the point of compliance wells per Table 10. The Director may amend this permit to designate additional points of compliance if information on groundwater gradients or groundwater usage indicates the need.

2.4.1. BADCT ALERT LEVEL WELLS for PHASE II

Table 3: BADCT ALERT LEVEL WELLS						
Well #	Well Location	Well Location	Latitude (North)	Longitude (West)	ADWR Well #	Screen Interval (ft bgs)
1	MW-4	Within Phase II development	34° 56' 36"	111° 39' 30"	55-809512	6-15
2	MW-5	Within Phase II development	34° 56' 34"	111° 39' 35"	55-809513	6-15
3	MW-6	Within Phase II development	34° 56' 32"	111° 39' 39"	55-809514	6-15

The monitoring for these BADCT Alert Level Wells shall be conducted in lieu of the effluent sampling ports for Phase II Treatment System. The monitoring shall be conducted per Table 9.

2.5. MONITORING REQUIREMENTS

[A.R.S. § 49-243(K)(1), A.A.C. R18-9-A206(A)]

Unless otherwise specified in this permit, all monitoring required in this permit shall continue for the duration of the permit, regardless of the status of the facility. Unless otherwise provided, monitoring shall commence the first full monitoring period following permit issuance. All sampling, preservation and holding times shall be in accordance with currently accepted standards of professional practice. Trip blanks, equipment blanks and duplicate samples shall also be obtained, and Chain-of-Custody procedures shall be followed, in accordance with currently accepted standards of professional practice. Copies of laboratory analyses and Chain-of-Custody forms shall be maintained at the permitted facility. Upon request, these documents shall be made immediately available for review by ADEQ personnel.

2.5.1. Pre-Operational Monitoring

Not applicable

2.5.2. Routine Discharge Monitoring

The permittee shall monitor the effluent from Phase II System according to Section 4.2, Table 9. Representative samples of the effluent shall be collected from BADCT Alert Level Wells MW-4, MW-5 and MW-6.

2.5.3. Reclaimed Water Monitoring

Not applicable.

2.5.4. Facility / Operational Monitoring

Operational monitoring inspections shall be conducted according to Section 4.2, Table 11 and Table 12.

If any damage of the pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and materials used shall be documented in the facility log book as per Section 2.7.2 and reported to ADEQ in case of a violation or exceedance as per Section 2.7.3.

2.5.5. Groundwater Monitoring And Sampling Protocols

Static water levels shall be measured and recorded prior to sampling. Wells shall be purged of at least three borehole volumes (as calculated using the static water level) or until field parameters (pH, temperature, conductivity) are stable, whichever represents the greater volume. If evacuation results in the well going dry, the well shall be allowed to recover to 80 percent of the original borehole volume, or for 24 hours, whichever is shorter, prior to sampling. If after 24 hours there is not sufficient water for sampling, the well shall be recorded as “dry” for the monitoring event. An explanation for reduced pumping volumes, a record of the volume pumped, and modified sampling procedures shall be reported and submitted with the SMRF.

The permittee may conduct the sampling using the low-flow purging method as described in the Arizona Water Resources Research Center, March 1995 *Field Manual for Water Quality Sampling*. The well must be purged until indicator parameters stabilize. Indicator parameters shall include dissolved oxygen, turbidity, pH, temperature, and conductivity.

2.5.5.1. POC Well Replacement

In the event that one or more of the designated POC wells should become unusable or inaccessible due to damage, or any other event, a replacement POC well shall be constructed and installed upon approval by ADEQ. If the replacement well is fifty feet or less from the original well, the ALs and/or aquifer quality limits (AQLs) calculated for the designated POC well shall apply to the replacement well.

2.5.6. Surface Water Monitoring And Sampling Protocols

Routine surface water monitoring is not required under the terms of this permit.

2.5.7. Analytical Methodology

All samples collected for compliance monitoring shall be analyzed using Arizona state-approved methods. If no state-approved method exists, then any appropriate EPA-approved method shall be used. Regardless of the method used, the detection limits must be sufficient to determine compliance with the regulatory limits of the parameters specified in this permit. If all methods have detection limits higher than the applicable limit, the permittee shall follow the applicable contingency requirements of Section 2.6 and may propose “other actions” including amending the permit to set higher limits. Analyses shall be performed by a laboratory licensed by the Arizona Department of Health Services, Office of Laboratory Licensure and Certification. For results to be considered valid, all analytical work shall meet quality control standards specified in the approved methods. A list of state-certified laboratories in Arizona can be obtained at the address below:

Arizona Department of Health Services
Office of Laboratory Licensure and Certification
250 North 17th Avenue
Phoenix, Arizona 85007
Phone: (602) 364-0720

2.5.8. Installation And Maintenance Of Monitoring Equipment

Monitoring equipment required by this permit shall be installed and maintained so that representative samples required by the permit can be collected. If new groundwater wells are determined to be necessary, the construction details shall be submitted to the Groundwater Protection Value Stream for approval prior to installation and the permit shall be amended to include any new monitoring points.

2.6. CONTINGENCY PLAN REQUIREMENTS

[A.R.S. § 49-243(K)(3), (K)(7) and A.A.C. R18-9-A204 and R18-9-A205]

2.6.1. General Contingency Plan Requirements

At least one copy of this permit and the approved contingency and emergency response plan submitted in the application shall be maintained at the location where day-to-day decisions regarding the operation of the facility are made. The permittee shall be aware of and follow the contingency and emergency plans.

Any AL exceedance, or violation of an AQL, DL, or other permit condition shall be reported to ADEQ following the reporting requirements in Section 2.7.3, unless more specific reporting requirements are set forth in Section 2.6.2 through 2.6.5.

Some contingency actions involve verification sampling. Verification sampling shall consist of the first follow-up sample collected from a location that previously indicated a violation or the exceedance of an AL. Collection and analysis of the verification sample shall use the same protocols and test methods to analyze for the pollutant or pollutants that exceeded an AL or violated an AQL or DL. Where verification sampling is specified in this permit, it is the option of the permittee to perform such sampling. If verification sampling is not conducted within the timeframe allotted, ADEQ and the permittee shall presume the initial sampling result to be confirmed as if verification sampling had been conducted. The permittee is responsible for compliance with contingency plans relating to the exceedance of an AL or violation of a DL, AQL or any other permit condition. The permittee is subject to enforcement action for the failure to comply with any contingency actions in this permit.

2.6.2. Exceeding Of Alert Levels And Performance Levels

2.6.2.1. Exceeding Of Performance Levels Set For Operational Conditions

If an alert level set in Section 4.2, Table 11 and Table 12 has been exceeded the permittee shall:

1. Notify the Groundwater Protection Value Stream within five (5) days of becoming aware of the exceedance.
2. Submit a written report to the Groundwater Protection Value Stream within 30 days after becoming aware of the exceedance. The report shall document all of the following:
 - a. A description of the exceedance and the cause of the exceedance;
 - b. The period of the exceedance, including exact date(s) and time(s), if known, and the anticipated time period during which the exceedance is expected to continue;
 - c. Any action taken or planned to mitigate the effects of the exceedance or spill, or to eliminate or prevent recurrence of the exceedance or spill;
 - d. Any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an AWQS; and
 - e. Any malfunction or failure of pollution control devices or other equipment or process.
3. The facility is no longer on alert status once the operational indicator no longer indicates that a performance level is being exceeded. The permittee shall, however, complete all tasks necessary to return the facility to its pre-alert operating condition.

2.6.2.2. Exceeding Of Alert Levels (ALs) Set For Discharge Monitoring

1. If an AL set in Section 4.2, Table 9: ROUTINE DISCHARGE MONITORING FOR PHASE II SYSTEM has been exceeded, the permittee shall immediately investigate to determine the cause. The investigation shall include the following:
 - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant

- discharge control systems that may have contributed to the exceedance;
- b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences; and
 - c. If the investigation procedures indicated in (a) and (b) above fail to reveal the cause of the exceedance, the permittee shall sample individual waste streams composing the wastewater for the parameter(s) in question, if necessary to identify the cause of the exceedance.
2. The permittee shall initiate actions identified in the approved contingency plan referenced in Section 5.0 and specific contingency measures identified in Section 2.6 to resolve any problems identified by the investigation which may have led to the AL exceedance. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6.
 3. Within thirty days of an AL exceedance, the permittee shall submit the laboratory results to the Groundwater Protection Value Stream along with a summary of the findings of the investigation, the cause of the exceedance, and actions taken to resolve the problem.
 4. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.2.3. Exceeding Of Alert Levels In Groundwater Monitoring

2.6.2.3.1. Alert Levels For Indicator Parameters

No ALs have been established for indicator parameters.

2.6.2.3.2. Alert Levels For Pollutants With Numeric Aquifer Water Quality Standards

1. In the case of an exceedance of an AL for a pollutant set in Section 4.2, Table 10, the permittee may conduct verification sampling for those pollutant(s) that exceeded their respective AL(s) within five (5) days of becoming aware of the exceedance. The permittee may use results of another sample taken between the date of the last sampling event and the date of receiving the result as verification.
2. If verification sampling confirms the AL exceedance or if the permittee opts not to perform verification sampling, then the permittee shall increase the frequency of monitoring for each pollutant exceeding its' respective AL(s) as follows:

Table 4: ACCELERATED MONITORING - ALERT LEVEL EXCEEDANCE	
Specified Monitoring Frequency	Monitoring Frequency for AL Exceedance
Daily	Daily
Weekly	Daily
Monthly	Weekly
Quarterly	Monthly
Semi-annually	Quarterly
Annually	Quarterly

In addition, the permittee shall immediately initiate an investigation of the cause of the AL exceedance, including inspection of all discharging units and all related pollution control devices, review of any operational and maintenance practices that might have resulted in an unexpected discharge, and hydrologic review of groundwater conditions including upgradient water quality.

3. The permittee shall initiate actions identified in the approved contingency plan referenced in Section 5.0 and specific contingency measures identified in Section 2.6 to resolve any problems identified by the investigation which may have led to an AL exceedance. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6. Alternatively, the permittee may submit a technical demonstration, subject to written approval by the Groundwater Protection Value Stream, that although an AL has been exceeded, the pollutant(s) that exceeded their respective AL(s) are not reasonably expected to cause a violation of an AQL. The demonstration may propose a revised AL or monitoring frequency, for those pollutant(s) that exceeded their respective AL(s), for approval in writing by the Groundwater Protection Value Stream.
4. Within 30 days after confirmation of an AL exceedance, for each pollutant that exceeded an AL, the permittee shall submit the laboratory results to the Groundwater Protection Value Stream along with a summary of the findings of the investigation, the cause of the exceedance, and actions taken to resolve the problem.
5. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.
6. For each pollutant that exceeded an AL, the increased monitoring required as a result of an AL exceedance may be reduced to the monitoring frequency in Section 4.2, Table 10 if the results of four sequential sampling events of those pollutants demonstrate that they did not exceed the AL.
7. If the increased monitoring required as a result of an AL exceedance continues for more than six (6) sequential sampling events, the permittee shall submit to ADEQ a second report documenting an investigation of each pollutant which continued to exceed an AL. This report is due within 30 days of the receipt of laboratory results of the sixth sampling event.

2.6.2.3.3. Alert Levels To Protect Downgradient Users From Pollutants Without Numeric Aquifer Water Quality Standards

Not required at time of issuance.

2.6.2.3.4. Alert Level For Groundwater Level

Not applicable.

2.6.3. Discharge Limit Violation

1. If a DL set in Section 4.2, Table 9 has been violated, the permittee shall immediately investigate to determine the cause. The investigation shall include the following:
 - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the violation;
 - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences;
 - c. If the investigation procedures indicated in (a) and (b) above fail to reveal the cause of the violation, the permittee shall sample individual waste streams composing the wastewater for the parameters in violation, as necessary to identify the cause of the violation.

The permittee shall submit a report to the Groundwater Protection Value Stream according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. The permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected

soil, surface water or groundwater, notification of downstream or downgradient users who may be directly affected by the discharge, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ-approved contingency plan, or separately approved according to Section 2.6.6.

2. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions, or other actions.

2.6.4. Aquifer Quality Limit Exceedances

1. If an AQL set in Section 4.2, Table 10 has been exceeded, the permittee may conduct verification sampling for those pollutant(s) that were above their respective AQL(s) within five (5) days of becoming aware of the exceedance. The permittee may use results of another sample taken between the date of the last sampling event and the date of receiving the result as verification.
2. If verification sampling does not confirm an AQL exceedance, no further action is needed under this Section.
3. If verification sampling confirms that an AQL was exceeded for any parameter or if the permittee opts not to perform verification sampling, then, the permittee shall increase the frequency of monitoring for those parameters as follows:

Table 5: ACCELERATED MONITORING - AQUIFER QUALITY LIMIT VIOLATION	
Specified Monitoring Frequency	Monitoring Frequency for AQL Violation
Daily	Daily
Weekly	Daily
Monthly	Weekly
Quarterly	Monthly
Semi-annually	Quarterly
Annually	Quarterly

In addition, the permittee shall immediately initiate an evaluation for the cause of the violation, including inspection of all discharging units and all related pollution control devices, and review of any operational and maintenance practices that might have resulted in unexpected discharge.

The permittee also shall submit a report according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. A verified exceedance of an AQL will be considered a violation unless the permittee demonstrates within 30 days that the exceedance was not caused or contributed to by pollutants discharged from the facility. Unless the permittee has demonstrated that the exceedance was not caused or contributed to by pollutants discharged from the facility, the permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected soil, surface water, or groundwater, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ approved contingency plan, or separately approved according to Section 2.6.6.

Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.5. Emergency Response And Contingency Requirements For Unauthorized Discharges

[A.R.S. § 49-201(12) AND PURSUANT TO A.R.S. § 49-241]

2.6.5.1. Duty To Respond

The permittee shall act immediately to correct any condition resulting from a discharge pursuant to A.R.S. § 49-201(12) if that condition could pose an imminent and substantial endangerment to public health or the environment.

2.6.5.2. Discharge Of Hazardous Substances Or Toxic Pollutants

In the event of any unauthorized discharge pursuant to A.R.S. § 49-201(12) of suspected hazardous substances (A.R.S. § 49-201(19)) or toxic pollutants (A.R.S. § 49-243(I)) on the facility site, the permittee shall promptly isolate the area and attempt to identify the discharged material. The permittee shall record information, including name, nature of exposure and follow-up medical treatment, if necessary, on persons who may have been exposed during the incident. The permittee shall notify the Groundwater Protection Value Stream within 24 hours of discovering the discharge of hazardous material which (a) has the potential to cause an AWQS or AQL exceedance, or (b) could pose an endangerment to public health or the environment.

2.6.5.3. Discharge Of Non-Hazardous Materials

In the event of any unauthorized discharge pursuant to A.R.S. § 49-201(12) of non-hazardous materials from the facility, the permittee shall promptly attempt to cease the discharge and isolate the discharged material. Discharged material shall be removed and the site cleaned up as soon as possible. The permittee shall notify the Groundwater Protection Value Stream within 24 hours of discovering the discharge of non-hazardous material which has the potential to cause an AQL exceedance, or could pose an endangerment to public health or the environment.

2.6.5.4. Reporting Requirements

The permittee shall submit a written report for any unauthorized discharges reported under Sections 2.6.5.2 and 2.6.5.3 to the Groundwater Protection Value Stream within 30 days of the discharge or as required by subsequent ADEQ action. The report shall summarize the event, including any human exposure, and facility response activities and include all information specified in Section 2.7.3. If a notice is issued by ADEQ subsequent to the discharge notification, any additional information requested in the notice shall also be submitted within the time frame specified in the notice. Upon review of the submitted report, ADEQ may require additional monitoring or corrective actions.

2.6.6. Corrective Actions

Specific contingency measures identified in Section 2.6 have already been approved by ADEQ and do not require written approval to implement.

With the exception of emergency response actions taken under Section 2.6.5, the permittee shall obtain written approval from the Groundwater Protection Value Stream prior to implementing a corrective action to accomplish any of the following goals in response to exceedance of an AL, AQL, DL, or other permit condition:

1. Control of the source of an unauthorized discharge;
2. Soil cleanup;
3. Cleanup of affected surface waters;
4. Cleanup of affected parts of the aquifer;
5. Mitigation to limit the impact of pollutants on existing uses of the aquifer.

Within 30 days of completion of any corrective action, the operator shall submit to the Groundwater Protection Value Stream, a written report describing the causes, impacts, and actions taken to resolve the problem.

2.7. REPORTING AND RECORDKEEPING REQUIREMENTS

[A.R.S. § 49-243(K)(2) and A.A.C. R18-9-A206(B) and R18-9-A207]

2.7.1. Self-Monitoring Report Form

1. The permittee shall complete the Self-Monitoring Reporting Forms (SMRFs) provided by ADEQ, and submit the completed report through the myDEQ online reporting system. The permittee shall use the format devised by ADEQ.
2. The permittee shall complete the SMRF to the extent that the information reported may be entered on the form. If no information is required during a reporting period, the permittee shall enter “not required” on the form, include an explanation, and submit the form to the Groundwater Protection Value Stream.
3. The tables contained in Section 4.0 list the monitoring parameters and the frequencies for reporting results on the SMRF:
 - a. Table 9: ROUTINE DISCHARGE MONITORING FOR PHASE II SYSTEM
 - b. Table 10: GROUNDWATER MONITORING

The parameters listed in the above-identified tables from Section 4.0 are the only parameters for which SMRF reporting is required.

2.7.2. Operation Inspection / Log Book Recordkeeping

A signed copy of this permit shall be maintained at all times at the location where day-to-day decisions regarding the operation of the facility are made. A log book (paper copies, forms, or electronic data) of the inspections and measurements required by this permit shall be maintained at the location where day-to-day decisions are made regarding the operation of the facility. The log book shall be retained for ten years from the date of each inspection, and upon request, the permit and the log book shall be made immediately available for review by ADEQ personnel. The information in the log book shall include, but not be limited to, the following information as applicable:

1. Name of inspector;
2. Date and shift inspection was conducted;
3. Condition of applicable facility components;
4. Any damage or malfunction, and the date and time any repairs were performed;
5. Documentation of sampling date and time; and
6. Any other information required by this permit to be entered in the log book.
7. Monitoring records for each measurement shall comply with A.A.C. R18-9-A206(B)(2).

2.7.3. Permit Violation And Alert Level Status Reporting

1. The permittee shall notify the Groundwater Protection Value Stream within five (5) days (except as provided in Section 2.6.5) of becoming aware of an AL exceedance, or violation of any permit condition, AQL, or DL for which notification requirements are not specified in Sections 2.6.2 through 2.6.5.

2. The permittee shall submit a written report to the Groundwater Protection Value Stream within 30 days of becoming aware of the violation of any permit condition, AQL, or DL. The report shall document all of the following:
 - a. Identification and description of the permit condition for which there has been a violation and a description of the cause;
 - b. The period of violation including exact date(s) and time(s), if known, and the anticipated time period during which the violation is expected to continue;
 - c. Any corrective action taken or planned to mitigate the effects of the violation, or to eliminate or prevent a recurrence of the violation;
 - d. Any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an AWQS;
 - e. Proposed changes to the monitoring which include changes in constituents or increased frequency of monitoring; and
 - f. Description of any malfunction or failure of pollution control devices or other equipment or processes.

2.7.4. Operational, Other Or Miscellaneous Reporting

The permittee shall record the information as required in Section 4.2, Table 11 and Table 12 in the facility log book as per Section 2.7.2, and report to the Groundwater Protection Value Stream any violations or exceedances as per Section 2.7.3.

2.7.5. Reporting Location

All Self-Monitoring Report Forms (SMRFs) shall be submitted Through the myDEQ portal accessible on the ADEQ website at: <http://www.azdeq.gov/welcome-mydeq>

All other documents required by this permit shall be mailed to:

The Arizona Department of Environmental Quality
 Groundwater Protection Value Stream
 Mail Code 5415B-3
 1110 West Washington Street
 Phoenix, Arizona 85007
 Phone (602) 771-4571

2.7.6. Reporting Deadline

The following table lists the quarterly report due dates:

Table 6: QUARTERLY REPORTING DEADLINES	
Monitoring Conducted During Quarter:	Quarterly Report Due By:
January-March	April 30
April-June	July 30
July-September	October 30
October-December	January 30

The following table lists the semi-annual and annual report due dates if applicable:

Table 7: (SEMI-)ANNUAL REPORTING DEADLINES	
Monitoring Conducted:	Report Due By:
Annual: January-December	January 30

2.7.7. Changes To Facility Information In Section 1.0

The Groundwater Protection Value Stream shall be notified within ten days of any change of facility information including Facility Name, Permittee Name, Mailing or Street Address, Facility Contact Person, or Emergency Telephone Number.

2.8. Temporary Cessation

[A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A209(A)]

The permittee shall give written notice to the Groundwater Protection Value Stream before ceasing operation of the facility for a period of 60 days or greater. The permittee shall take the following measures upon temporary cessation:

1. If applicable, direct the wastewater flows from the facility to another state-approved wastewater treatment facility;
2. Correct the problem that caused the temporary cessation of the facility; and
3. Notify the Groundwater Protection Value Stream with a monthly facility status report describing the activities conducted on the treatment facility to correct the problem.
4. Submittal of Self-Monitoring Report Forms (SMRFs) is still required; report “temporary cessation” in the comment section.

At the time of notification the permittee shall submit for ADEQ approval a plan for maintenance of discharge control systems and for monitoring during the period of temporary cessation. Immediately following ADEQ approval, the permittee shall implement the approved plan. If necessary, ADEQ shall amend permit conditions to incorporate conditions to address temporary cessation. During the period of temporary cessation, the permittee shall provide written notice to the Groundwater Protection Value Stream of the operational status of the facility every three years. If the permittee intends to permanently cease operation of any facility, the permittee shall submit closure notification, as set forth in Section 2.9 below.

2.9. Closure

[A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9-A209(B)]

For a facility addressed under this permit, the permittee shall give written notice of closure to the Groundwater Protection Value Stream of the intent to cease operation without resuming activity for which the facility was designed or operated. Submittal of SMRFs is still required; report “closure in process” in the comment section.

2.9.1. Closure Plan

Within 90 days following notification of closure, the permittee shall submit for approval to the Groundwater Protection Value Stream, a closure plan which meets the requirements of A.R.S. § 49-252 and A.A.C. R18-9-A209(B)(3).

If the closure plan achieves clean-closure immediately, ADEQ shall issue a letter of approval to the permittee. If the closure plan contains a schedule for bringing the facility to a clean-closure configuration at a future date, ADEQ may incorporate any part of the schedule as an amendment to this permit.

2.9.2. Closure Completion

Upon completion of closure activities, the permittee shall give written notice to the Groundwater Protection Value Stream indicating that the approved closure plan has been implemented fully and providing supporting documentation to demonstrate that clean-closure has been achieved (soil sample results, verification sampling results, groundwater data, as applicable). If clean-closure has been achieved, ADEQ shall issue a letter of approval to the permittee at that time. If any of the following conditions apply, the permittee shall follow the terms of post-closure stated in this permit:

1. Clean-closure cannot be achieved at the time of closure notification or within one year thereafter under a diligent schedule of closure actions;
2. Further action is necessary to keep the facility in compliance with the AWQS at the applicable POC or, for any pollutant for which the AWQS was exceeded at the time this permit was issued, further action is necessary to prevent the facility from further degrading the aquifer at the applicable POC with respect to that pollutant;
3. Remedial, mitigative or corrective actions or controls are necessary to comply with A.R.S. § 49-201(30) and Title 49, Chapter 2, Article 3;
4. Further action is necessary to meet property use restrictions.
5. SMRF submittals are still required until Clean Closure is issued.

2.10. Post-closure

[A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9 A209(C)]

Post-closure requirements shall be established based on a review of facility closure actions and will be subject to review and approval by the Groundwater Protection Value Stream.

In the event clean-closure cannot be achieved pursuant to A.R.S. § 49-252, the permittee shall submit for approval to the Groundwater Protection Value Stream a post-closure plan that addresses post-closure maintenance and monitoring actions at the facility. The post-closure plan shall meet all requirements of A.R.S. §§ 49-201(30) and 49-252 and A.A.C. R18-9-A209(C). Upon approval of the post-closure plan, this permit shall be amended or a new permit shall be issued to incorporate all post-closure controls and monitoring activities of the post-closure plan.

2.10.1. Post-Closure Plan

A specific post-closure plan may be required upon the review of the closure plan.

2.10.2. Post-Closure Completion

Not required at the time of permit issuance.

3.0 COMPLIANCE SCHEDULE

[A.R.S. § 49-243(K)(5) and A.A.C. R18-9-A208]

Unless otherwise indicated, for each compliance schedule item listed below, the permittee shall submit the required information to the Groundwater Protection Value Stream.

Table 8: COMPLIANCE SCHEDULE ITEMS			
No.	Description	Due By:	Permit Amendment Required?
Phase III Flow Diversion to Pinewood Sanitary District WWTP			
1	The permittee shall notify the Department upon connecting and diverting the flow from Phase III system to Pinewood Sanitary District WWTP.	Within 15 days of connecting to the Pinewood Sanitary District	No
2	If the permittee decides not to connect to PWSD WWTP, the permittee shall submit an amendment application to the Department to add the monitoring requirements for Phase III system in the permit.	By April 1, 2021	Yes
Closure of Phase III System			
3	The permittee shall perform closure of Phase III systems per the closure plan approved by ADEQ.	Within 60 days of connecting to the Pinewood Sanitary District	No
4	The permittee shall submit an amendment application along with the closure report to the Department to close the Phase III system under the permit.	Within 30 days closure of Phase III system	Yes
Reduction in Monitoring Frequency			
5	The permittee shall conduct the Routine Discharge Monitoring per Table 9: ROUTINE DISCHARGE MONITORING FOR PHASE II SYSTEM for Phase II. The permittee may request reduction in monitoring frequency if the discharge limit (DL) for all the parameters are met for two consecutive years (two operational seasons). The permittee shall summarize the monitoring results and submit along with an application form to the Department. The Department will reduce the monitoring frequency for total nitrogen and <i>E.coli</i> from monthly to bimonthly, and for metals and VOCs from annually to bi-annually.	Upon meeting DL for two consecutive years	Yes

Table 8: COMPLIANCE SCHEDULE ITEMS			
No.	Description	Due By:	Permit Amendment Required?
Report for Groundwater Level and Flow Direction			
6	The permittee shall submit a groundwater level and groundwater flow direction report. Groundwater elevation data shall be obtained from at least three (3) wells that are sufficiently spaced and located to provide an accurate calculation of the groundwater flow direction. The measurements shall be obtained no more than two days apart for all of the wells. The report shall provide the collected depth to groundwater and groundwater elevation data for each well, a calculation of the groundwater flow direction, and a determination of whether the current POC location is located down-gradient of the facility.	One year from the permit issuance date	No
Financial Assurance Mechanism and Closure Cost Update			
7	The permittee shall submit a demonstration that the financial assurance mechanism listed in Section 2.1, Financial Capability, is being maintained as per A.R.S. 49-243.N.4 and A.A.C. R18-9-A203(H) for all estimated closure and post-closure costs including updated costs submitted under Section 3.0, No. 8 below. The demonstration shall include a statement that the closure and post-closure strategy has not changed, the discharging facilities listed in the permit have not been altered in a manner that would affect the closure and post-closure costs, and discharging facilities have not been added. The demonstration shall also include information in support of a cash deposit as required in A.A.C. R18-9-A203(C)(7).	By August 2026 and every 6 years from the date of permit signature, for the duration of the permit	No
8	The permittee shall submit updated cost estimates for facility closure and post-closure, as per A.A.C. R18-9-A201(B)(5) and A.R.S. 49-243.N.2.a.	By August 2026 and every six years from the date of permit signature, for the duration of the permit	Yes

4.0 TABLES OF MONITORING REQUIREMENTS

4.1. PRE-OPERATIONAL MONITORING (OR CONSTRUCTION REQUIREMENTS)

Not applicable.

4.2. COMPLIANCE OR OPERATIONAL MONITORING

Table 9: ROUTINE DISCHARGE MONITORING FOR PHASE II SYSTEM					
The monitoring requirements under this table are only for Phase II system. Monitoring shall be conducted only during the operation season for Munds RV Park Campground which is from April 1 st to October 31 st each year. During other months, the permittee shall submit SMRFs and report 'Not Required' on SMRFs.					
Sampling Point Number	Sampling Point Identification			Latitude (North)	Longitude (West)
1	MW-4			34° 56' 36"	111° 39' 30"
2	MW-5			34° 56' 36"	111° 39' 30"
3	MW-6			34° 56' 36"	111° 39' 30"
Parameter	Alert Level	Discharge Limit	Units	Sampling Frequency	Reporting Frequency
<i>E. coli</i>	Not Established	Non-detect	MPN ₁	Monthly	Quarterly
Total Nitrogen ₂	8.0	10.0	mg/l ₃	Monthly	Quarterly
Metals (Dissolved)					
Antimony	0.0048	0.006	mg/l	Annually	Annually
Arsenic	0.04	0.05	mg/l	Annually	Annually
Barium	1.60	2.00	mg/l	Annually	Annually
Beryllium	0.0032	0.004	mg/l	Annually	Annually
Cadmium	0.004	0.005	mg/l	Annually	Annually
Chromium	0.08	0.1	mg/l	Annually	Annually
Cyanide (as free cyanide)	0.16	0.2	mg/l	Annually	Annually
Fluoride	3.2	4.0	mg/l	Annually	Annually
Lead	0.04	0.05	mg/l	Annually	Annually
Mercury	0.0016	0.002	mg/l	Annually	Annually
Nickel	0.08	0.1	mg/l	Annually	Annually
Selenium	0.04	0.05	mg/l	Annually	Annually
Thallium	0.0016	0.002	mg/l	Annually	Annually

¹ MPN = Most Probable Number / 100 ml sample. For MPN, a value of <2.2 shall be considered to be non-detect.

² Total Nitrogen = Nitrate as N + Nitrite as N + Total Kjeldahl Nitrogen

³ mg/l = milligrams per liter

Table 9: ROUTINE DISCHARGE MONITORING (Continued)					
Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	0.004	0.005	mg/l	Annually	Annually
Carbon tetrachloride	0.004	0.005	mg/l	Annually	Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Annually	Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Annually	Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Annually	Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Annually	Annually
cis-1,2-Dichloroethylene	0.056	0.07	mg/l	Annually	Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Annually	Annually
Dichloromethane	0.004	0.005	mg/l	Annually	Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Annually	Annually
Ethylbenzene	0.56	0.7	mg/l	Annually	Annually
Hexachlorobenzene	0.0008	0.001	mg/l	Annually	Annually
Hexachlorocyclopentadiene	0.04	0.05	mg/l	Annually	Annually
Monochlorobenzene	0.08	0.1	mg/l	Annually	Annually
Styrene	0.08	0.1	mg/l	Annually	Annually
Tetrachloroethylene	0.004	0.005	mg/l	Annually	Annually
Toluene	0.8	1.0	mg/l	Annually	Annually
Trihalomethanes (total) ⁴	0.08	0.1	mg/l	Annually	Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Annually	Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Annually	Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Annually	Annually
Trichloroethylene	0.004	0.005	mg/l	Annually	Annually
Vinyl Chloride	0.0016	0.002	mg/l	Annually	Annually
Xylenes (Total)	8.0	10.0	mg/l	Annually	Annually

⁴Total Trihalomethanes are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

Table 10: GROUNDWATER MONITORING

Monitoring under this table shall be conducted only during the operation season for Munds RV Park Campground which is from April 1st to October 31st each year. During other months, the permittee shall submit SMRFs and report 'Not Required' on SMRFs.

Sampling Point Number	Sampling Point Identification			Latitude (North)	Longitude (West)
2	POC Well #1			34° 56' 52"	111° 39' 43.2"
Parameter	Alert Level	Aquifer Quality Limit	Units	Sampling Frequency	Reporting Frequency
Nitrate-Nitrite as N	8.0	10.0	mg/l	Monthly	Quarterly
Nitrate as N	8.0	10.0	mg/l	Monthly	Quarterly
Nitrite as N	0.8	1.0	mg/l	Monthly	Quarterly
<i>E. Coli</i>	Not Established	Non-detect ⁵	MPN ⁶	Monthly	Quarterly

⁵ Non-detect = For CFU, a value of <1.0 shall be considered to be non-detect

⁶ MPN = Most Probable Number per 100 ml

Table 11: FACILITY INSPECTION AND OPERATIONAL MONITORING

The monitoring under this table shall be conducted for Phase I, IA and II only. The permittee shall record the inspection performance levels in a log book as per Section 2.7.2, and report any violations or exceedances as per Section 2.7.3. In the case of an exceedance, identify which structure exceeds the performance level in the log book.

Pollution Control Structure/Parameter	Performance Level	Inspection Frequency	Reporting Frequency
Disposal Beds	Good Working Condition, No Surfacing of effluent	Weekly	See Section 2.7.3
Treatment System Components	Good Working Condition	Weekly	
Septic Tanks	Good Working Condition No accumulation of solids that impairs performance	Annually	
POC Wells	Well cap and seals are intact. No discernable corrosion or deterioration of the well(s). No discernable materials accumulating in the well. Any dedicated well equipment are functional and intact.	Monthly	See Section 2.7.3 and 2.5.5.1

Table 12: FACILITY INSPECTION AND OPERATIONAL MONITORING for PHASE III

The monitoring under this table shall be conducted for Phase III only. The permittee shall record the inspection performance levels in a log book as per Section 2.7.2, and report any violations or exceedances as per Section 2.7.3. In the case of an exceedance, identify which structure exceeds the performance level in the log book.

Pollution Control Structure/Parameter	Performance Level	Inspection Frequency	Reporting Frequency
Disposal Beds	Good Working Condition, No Surfacing of effluent	Weekly	See Section 2.7.3
Treatment System Components	Good Working Condition	Weekly	
Septic Tanks	Good Working Condition No accumulation of solids that impairs performance	Annually	

5.0 REFERENCES AND PERTINENT INFORMATION

The terms and conditions set forth in this permit have been developed based upon the information contained in the following, which are on file with the Department:

APP Application, dated:	February 7, 2020
Contingency Plan	July 30, 2020
Final Hydrologist Report, dated:	June 23, 2020
Final Engineering Report, dated:	June 26, 2020
Public Notice, dated:	XXXX

6.0 NOTIFICATION PROVISIONS

6.1. Annual Registration Fees

The permittee is notified of the obligation to pay an Annual Registration Fee to ADEQ. The Annual Registration Fee is based on the amount of daily influent or discharge of pollutants in gallons per day (gpd) as established by A.R.S. § 49-242.

6.2. Duty to Comply

[A.R.S. §§ 49-221 through 263]

The permittee is notified of the obligation to comply with all conditions of this permit and all applicable provisions of Title 49, Chapter 2, Articles 1, 2 and 3 of the Arizona Revised Statutes, Title 18, Chapter 9, Articles 1 through 4, and Title 18, Chapter 11, Article 4 of the Arizona Administrative Code. Any permit non-compliance constitutes a violation and is grounds for an enforcement action pursuant to Title 49, Chapter 2, Article 4 or permit amendment, suspension, or revocation.

6.3. Duty to Provide Information

[A.R.S. §§ 49-243(K)(2) and 49-243(K)(8)]

The permittee shall furnish to the Director, or an authorized representative, within a time specified, any information which the Director may request to determine whether cause exists for amending or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

6.4. Compliance with Aquifer Water Quality Standards

[A.R.S. §§ 49-243(B)(2) and 49-243(B)(3)]

The permittee shall not cause or contribute to a violation of an Aquifer Water Quality Standard (AWQS) at the applicable point of compliance (POC) for the facility. Where, at the time of issuance of the permit, an aquifer already exceeds an AWQS for a pollutant, the permittee shall not discharge that pollutant so as to further degrade, at the applicable point of compliance for the facility, the water quality of any aquifer for that pollutant.

6.5. Technical and Financial Capability

[A.R.S. §§ 49-243(K)(8) and 49-243(N) and A.A.C. R18-9-A202(B) and R18-9-A203(E) and (F)]

The permittee shall have and maintain the technical and financial capability necessary to fully carry out the terms and conditions of this permit. Any bond, insurance policy, trust fund, or other financial assurance mechanism provided as a demonstration of financial capability in the permit application, pursuant to A.A.C. R18-9-A203(C), shall be in effect prior to any discharge authorized by this permit and shall remain in effect for the duration of the permit.

6.6. Reporting of Bankruptcy or Environmental Enforcement

[A.A.C. R18-9-A207(C)]

The permittee shall notify the Director within five days after the occurrence of any one of the following:

1. the filing of bankruptcy by the permittee; or
2. the entry of any order or judgment not issued by the Director against the permittee for the enforcement of any environmental protection statute or rule.

6.7. Monitoring and Records

[A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A206]

The permittee shall conduct any monitoring activity necessary to assure compliance with this permit, with the applicable water quality standards established pursuant to A.R.S. §§ 49-221 and 49-223 and §§ 49-241 through 49-252.

6.8. Inspection and Entry

[A.R.S. §§ 49-1009, 49-203(B), and 49-243(K)(8)]

In accordance with A.R.S. §§ 41-1009 and 49-203(B), the permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to enter and inspect the facility as reasonably necessary to ensure compliance with Title 49, Chapter 2, Article 3 of the Arizona Revised Statutes, and Title 18, Chapter 9, Articles 1 through 4 of the Arizona Administrative Code and the terms and conditions of this permit.

6.9. Duty to Modify

[A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A211]

The permittee shall apply for and receive a written amendment before deviating from any of the designs or operational practices authorized by this permit.

6.10. Permit Action: Amendment, Transfer, Suspension, and Revocation

[A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]

This permit may be amended, transferred, suspended, or revoked for cause, under the rules of the Department. The permittee shall notify the Groundwater Protection Value Stream in writing within 15 days after any change in the owner or operator of the facility. The notification shall state the permit number, the name of the facility, the date of property transfer, and the name, address, and phone number where the new owner or operator can be reached. The operator shall advise the new owner or operators of the terms of this permit and the need for permit transfer in accordance with the rules.

7.0. ADDITIONAL PERMIT CONDITIONS

7.1. Other Information

[A.R.S. § 49-243(K)(8)]

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, the permittee shall promptly submit the correct facts or information.

7.2. Severability

[A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby. The filing of a request by the permittee for a permit action does not stay or suspend the effectiveness of any existing permit condition.

7.3. Permit Transfer

This permit may not be transferred to any other person except after notice to and approval of the transfer by the Department. No transfer shall be approved until the applicant complies with all transfer requirements as specified in A.A.C. R18-9-A212(B) and (C).