

ARIZONA POLLUTANT DISCHARGE ELIMINATION SYSTEM (AZPDES)

This document gives pertinent information concerning the reissuance of the AZPDES permit listed below. This facility is a wastewater treatment plant (WWTP) with a design capacity of 0.015 million gallons per day (MGD) and is considered to be a minor facility under the AZPDES program. The effluent limitations contained in this permit will maintain the Water Quality Standards listed in Arizona Administrative Code (A.A.C.) R18-11-101 *et seq.* This permit is proposed to be issued for a period of 5 years.

I. PERMITTEE INFORMATION	
Permittee's Name:	Pima County Regional Wastewater Reclamation Department (PCRWRD)
Permittee's Mailing Address:	2955 West Calle Agua Nueva, Tucson, AZ 85745
Facility Name:	Mount Lemmon Wastewater Reclamation Facility (WRF)
Facility Address or Location:	12633 North Sabino Canyon Park Road, Summerhaven, AZ 85619
County:	Pima County
Contact Person(s):	Max DiSante
Phone/e-mail address	520-724-6052 / max.disante@pima.gov
AZPDES Permit Number:	AZ0022250
Inventory Number:	100345
LTF Number:	115110

II. STATUS OF PERMIT(s)	
AZPDES permit applied for:	Renewal
Date application received:	3/3/2026
Date application was determined administratively complete:	3/5/2026
Previous permit expiration date:	9/1/2026
208 Consistency:	
<p>In accordance with A.A.C. R18-9-A903(6), a permit cannot be issued for any discharge inconsistent with a plan or plan amendment approved under section 208(b) of the Clean Water Act.</p> <p>Based on review of the application, there are no changes to the facility that require a new determination of consistency with the Regional Water Quality Management Plan.</p>	

Pima County Regional Wastewater Reclamation Department (PCRWRD) has the following permits issued by ADEQ applicable to the Mount Lemmon WRF:

Type of Permit		
Aquifer Protection Permit (APP)	P100345	Regulates discharges to the local aquifer

III. GENERAL FACILITY INFORMATION	
Type of Facility:	Publicly owned treatment works (POTW)
Facility Location Description:	Mt. Lemmon WRF is located in the town of Summerhaven, north of Tucson in the Catalina Mountains.
Permitted Design Flow:	0.015 million gallons per day (MGD)
Treatment Level (WWTP):	Secondary Treatment Level
Treatment Processes:	The Mt. Lemmon WRF consists of a circular oxidation tank and aeration basin with chlorination and dechlorination of domestic sewage for the properties of Summerhaven.
Sludge Handling and Disposal:	Sludge is transported offsite via truck to Manhole #8716-03 where it is incorporated into the influent stream to Tres Rios WRF (AZ0020001) at 7101 North Casa Grande Highway, Tucson, AZ 85743. After treatment and prior to disposal all biosolids are dewatered. Biosolids are ultimately land applied by Synagro.
Nature of Facility Discharge:	Domestic wastewater from residential properties in Summerhaven. The proposed AZPDES permit will authorize discharge of treated effluent to the unnamed wash, tributaries to the San Pedro River.
Average Flow Per Discharge:	There were no discharges from the facility since 2002. Therefore, the average discharge is 0.
Service Area:	The Mt. Lemmon WRF serves the Town of Summerhaven.
Service Population:	100
Reuse / Irrigation or other disposal method(s):	Currently, all treated effluent from the Mt. Lemmon WRF is reused under a valid United States Forest Service (USFS) Special Use Permit (SAN0139) to be used via sprayfield irrigation on forest vegetation.
Continuous or Intermittent Discharge:	Intermittent
Discharge Pattern Summary:	The renewal application submitted by PCRWRD indicated that the Mt. Lemmon WRF has not discharged since 2002. As acute standards were requested by PCRWRD, discharge duration and frequency are restricted. Discharges from any individual outfall lasting seven or more days and occurring more than one time each per month are prohibited. PCRWRD has indicated that discharge to the unnamed wash occurred in 2001 and 2002 during colder months. PCRWRD has stated discharge will only occur if there are inoperable conditions of the sprayfield and volume exceeds the 3 to 4 day storage at the booster station.

IV. RECEIVING WATER	
The State of Arizona has adopted water quality standards to protect the designated uses of its surface waters. Streams have been divided into segments and designated uses assigned to these segments. The water quality standards vary by designated use depending on the level of protection required to maintain that use.	
Receiving Water (Federal):	The Water of the U.S. Protected Surface Water (WOTUS PSW) for the Mt. Lemmon WWTP is an unnamed wash, from the Mt. Lemmon WWTP outfall at 32° 26' 51" / 110° 45' 08" to 0.25 km downstream. This is a surface water listed in A.A.C. R18-11 Appendix B.
River Basin:	San Pedro – Willcox Playa – Rio Yaqui River Basin
Outfall Location(s):	<p>Outfall 001: Township 11 S Range 16 E, Section 30 Latitude 32° 26' 55" N, Longitude 110° 45' 09" W (32.448611, -110.7525)</p> <p>Outfall 002: Township 11 S, Range 16 E, Section 30 Latitude 32° 26' 51" N, Longitude 110° 45' 08" W (32.4475, -110.752222)</p> <p>Outfall 003: Township 11 S, Range 16 E, Section 30 Latitude 32° 26' 49" N, Longitude 110° 45' 07" W (32.446944, -110.751944)</p>
Designated uses for the receiving water listed above:	Aquatic and Wildlife effluent dependent water (A&Wedw) Partial Body Contact (PBC)
Is the receiving water on the 303(d) list?	No, and there are no Total Maximum Daily Load (TMDL) issues associated.
Given the uses stated above, the applicable narrative water quality standards are described in A.A.C. R18-11-108, and the applicable numeric water quality standards are listed in A.A.C. R18-11-109 and in Appendix A thereof. There are two standards for the Aquatic and Wildlife uses, acute and chronic. In developing AZPDES permits, the standards for all applicable designated uses are compared and limits that will protect for all applicable designated uses are developed based on the standards.	

V. DESCRIPTION OF DISCHARGE		
Because the facility is in operation and discharges have occurred, effluent monitoring data are available. The following is the measured effluent quality reported in the application.		
Parameters	Units	Maximum Daily Discharge Concentration
Biochemical Oxygen Demand (BOD)	mg/L	19.7

Total Suspended Solids (TSS)	mg/L	54
Total Kjeldahl Nitrogen (TKN)	mg/L	10.9
<i>E. coli</i>	cfu/100 mL	>2419.6
Facility Design Removal Rates:		BOD 85 % TSS 85 %

VI. STATUS OF COMPLIANCE WITH THE EXISTING AZPDES PERMIT	
Date of Most Recent Inspection:	06/04/2025; no potential violations were noted as a result of this inspection.
Discharge Monitoring Reports (DMR) Reviewed:	1/2022 through 12/2025
Lab Reports Reviewed:	1/2022 through 12/2025
DMR Exceedances:	None
Notice(s) of Violation (NOV) Issued:	None
NOVs Closed:	N/A
Formal Enforcement Action(s):	None

VII. PROPOSED PERMIT CHANGES			
The following table lists the major changes from the previous permit in this permit.			
Parameter	Existing Permit	Proposed Permit	Reason for Change
Noncompliance Reporting Hotline	(602) 771-2330	Noncompliance resulting in imminent threat to human health or the environment must be reported to (602) 771-2330, while all other noncompliance must be reported to (602) 771-1440.	Routing emergency calls to the emergency hotline, but all other calls to a non-emergency number.

<p>Reporting Location for Effluent Characterization Monitoring</p>	<p>Submit results through DMRs</p>	<p>Report results on the EC Monitoring Data Sheet Excel form provided by ADEQ and submit annually to azpdes_data@azdeq.gov by January 28th following each annual reporting period. See Part I.D.2 and Part II.B.3 of permit.</p> <p>Laboratory reports for EC monitoring shall be submitted through myDEQ with the last DMR of the calendar year. See Part II.B.3.b. of the permit.</p>	<p>ADEQ is implementing this new procedure to facilitate data analysis by ADEQ and reporting by permittees. Outcomes include expedited data processing and improved data quality review, per ADEQ Surface Water Protection Quality Assurance Program Plan (2022).</p>
<p>Sufficiently Sensitive Test Methods and Limit of Quantitation (LOQ) Reporting Requirements</p>	<p>Limited explanation of analytical requirements for LOQ and sufficiently sensitive test methods.</p>	<p>Analytical test sensitivity requirements are specified in the footnotes of Part I Tables 1-4 of the permit and associated definitions in Appendix A. Part B. The requirement to use sufficiently sensitive test methods is specified in Part II.A.5.</p>	<p>The Limit of Quantitation (LOQ) must be low enough to allow comparison of the results to the applicable water quality standards (WQS) to be protective of the receiving water designated uses. New language clarifies the requirement that parameters must be analyzed using sufficiently sensitive test methods in accordance with 40 CFR 136.1(c).</p>
<p>Use of Metal Translators to Calculate Total Recoverable Permit Limits from Dissolved Criteria (Applicable to Cadmium, Chromium VI, Copper, Lead, Mercury, Nickel, Silver, and Zinc).</p>	<p>No metal translators were used. Assumed the ratio of dissolved to total recoverable is 1 to 1 for all metals with water quality criteria expressed as dissolved.</p>	<p>Water quality-based effluent limitations (WQBELs) and assessment levels (ALs) were converted from dissolved to total recoverable using the process from the EPA's <i>The Metals Translator: Guidance for Calculating A Total Recoverable Permit Limit from A Dissolved Criterion</i>.</p>	<p>New procedure for ADEQ to incorporate default metal translators when calculating total recoverable WQBELs and ALs from dissolved criteria.</p>

<p>Reporting Location for Annual Biosolids/Sewage Sludge Report</p>	<p>Electronic copy submitted to biosolids@azdeq.gov and myDEQ.</p>	<p>Annual reports submitted to EPA’s Central Data Exchange using the NPDES Electronic Reporting Tool (NeT – Biosolids) by February 19 of each year.</p>	<p>ADEQ has updated the annual reporting method for consistency with 40 CFR 403 and the National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule.</p>
<p>Whole Effluent Toxicity (WET) Data Evaluation and Reporting</p>	<p>Calculation of the no observed effect concentration (NOEC) and the 25% inhibition effect concentration (IC25). Report results on the DMR as Pass (0)/Fail (1) for acute tests and 100/NOEC result in toxicity units (TUc) for chronic tests. An exceedance was any one test result greater than 1.6 TUc or any calculated monthly median value greater than 1.0 TUc or a Fail.</p>	<p>Pass and Fail results are declared by comparing percent effect (PE) to the regulatory management decision (RMD) threshold established for the test.</p> <p>For acute tests, report results as Pass (0)/Fail (1) on the DMR.</p> <p>For chronic tests, report Pass (0)/Fail (1) and report the PE on the DMR.</p>	<p>WET test results must now be analyzed and reported using the Test for Significant Toxicity (TST). This statistical approach detailed in EPA’s 2010 “National Pollutant Discharge Elimination System Test of Significant Toxicity Technical Document” (EPA-833-R-10-004) encourages the generation of higher quality WET data through increased within-test replicates or improved method precision. The TST ultimately minimizes false negative and positive results leading to more reliable data for regulatory decision-making.</p>
<p>WET tests with a result of Fail</p>	<p>WET lab reports and any required additional attachments shall be submitted to ADEQ using the myDEQ electronic portal by the 28th day of the month following the end of the WET monitoring period, or upon request.</p>	<p>Certified laboratory reports with a Fail test result for either an Action Level or Limit shall be emailed to AZPDES@azdeq.gov within five days of receipt.</p>	<p>Prompt notification to ADEQ is crucial for protecting aquatic and wildlife when toxicity is detected during action level or limitations monitoring. This new requirement for notification ensures that all necessary follow-up testing is conducted as required by the permit.</p>

WET test frequency	1x/permit term in year 2025	4x/permit term in years 2027, 2028, 2029, 2030	TST method for determining WET toxicity requires a minimum of 4 samples in order to conduct statistical tests to determine if reasonable potential (RP) exists.
Toxicity Reduction Evaluation (TRE) Plan	TRE plan developed following detection of effluent toxicity.	TRE Plan submitted to AZPDES@azdeq.gov within 90 days of permit effective date. This is required regardless of whether effluent toxicity has been detected or not. Use the template supplied by ADEQ (See Part IV of the permit).	Permittees may be required to execute a TRE Plan to address effluent toxicity issues. This new requirement added to all AZPDES permits with WET testing requirements ensures permittees proactively develop a systematic approach to identify and eliminate the cause of toxicity before toxicity is detected. This enables a timely response to protect aquatic and wildlife.
Narrative Surface Water Quality Standards	Narrative surface water quality standards applicable to the receiving water listed in Part I.E of the permit.	Other limitations for the effluent listed in Part I.E of the permit to ensure the discharge is protective of the narrative surface water quality standards of the receiving water.	ADEQ is clarifying all narrative permit requirements are applicable to the discharge rather than the “end result” in the receiving water in accordance with <i>City & County of San Francisco v. EPA</i> .
Silver	Monitoring required for effluent characterization.	Monitoring required and limit is set.	Data submitted indicated RP for an exceedance of a standard.
Fluoride	Not in current permit.	Monitoring required for effluent characterization.	The designated uses (DUs) for Mt. Lemmon WRF include PBC. The water quality standards listed in A.A.C. R18-11 Appendix A Table 1 include fluoride. To be protective of surface waters and in compliance with state code, monitoring is required.

<p>Hydrogen Sulfide and Sulfides</p>	<p>Not in current permit.</p>	<p>Monitoring required for effluent characterization.</p>	<p>ADEQ requires monitoring for all trace substances and metals, including hydrogen sulfide and sulfides, in all AZPDES individual permits. This new change ensures that both major and minor facilities monitor for trace substances.</p>
<p>Iron</p>	<p>Monitoring required for effluent characterization.</p>	<p>Monitoring required and assessment level is set.</p>	<p>Iron does not have any acute standards in A.A.C. R18-11 Appendix A Table 1. However, the chronic standard is 1,000 µg/L, and based on the reported maximum concentration, the calculated critical effluent concentration is 2,202.25 µg/L. As this is double the chronic limits, an assessment level was set for iron to better observe discharge concentrations.</p>
<p>Biochemical Oxygen Demand (BOD) (5-day) and Total Suspended Solids (TSS) – limit change</p>	<p>Monthly average 1.7 kg/day Weekly average 2.6 kg/day</p>	<p>Monthly average 2 kg/day Weekly average 3 kg/day</p>	<p>BOD and TSS mass limits were determined using standard practice calculations using the design flow of 0.015 MGD and updated to reflect the true limits for the facility.</p>

<p>Effluent characterization monitoring frequency:</p> <p><i>E. coli</i>; Biochemical Oxygen Demand (BOD-5); Chlorine, Total Residual (TRC); Nitrate/Nitrite (as N); Nitrogen, Total Kjeldahl (TKN); pH; Phosphorus; Temperature; Total Suspended Solids (TSS)</p>	<p>1x/year in years 2022, 2023, 2024 of permit term</p>	<p>1x/ year</p>	<p>Monitoring frequency is based on tiers established for design flow to (1) obtain sufficient data to protect surface water quality and (2) set monitoring requirements consistently among permitted discharges. For this POTW, monitoring frequency is based on the design flow tiers established for 0.015 MGD. As the facility is a non-discharging facility for over 20 years and has a low design flow, it was determined that annual sampling is sufficient for effluent characterization.</p>
--	---	-----------------	---

Anti-backsliding considerations — “Anti-backsliding” refers to statutory (Section 402(o) of the Clean Water Act) and regulatory (40 CFR 122.44(l)) requirements that prohibit the renewal, reissuance, or modification of an existing NPDES permit that contains effluent limits, permit conditions, or standards that are less stringent than those established in the previous permit. The rules and statutes do identify exceptions to these circumstances where backsliding is acceptable. This permit has been reviewed and drafted with consideration of anti-backsliding concerns.

No limits have been removed from the permit. Limits are retained in the permit for parameters where reasonable potential (RP) for an exceedance of a standard continues to exist or is indeterminate. In these cases, limits will be recalculated using the most current Arizona Water Quality Standards (WQS). If less stringent limits result due to a change in the WQS then backsliding is allowed in accordance with 303(d)(4) if the new limits are consistent with antidegradation requirements and the receiving water is in attainment of the new standard; see Section XII for information regarding antidegradation requirements.

Limits for the following parameter are less stringent because of a change in the standards in 2025: *E. coli*.

<p>VIII. DETERMINATION OF EFFLUENT LIMITATIONS, OTHER LIMITATIONS, and ASSESSMENT LEVELS</p>
<p>When determining what parameters need monitoring and/or limits included in the permit, both technology-based and water quality-based criteria were compared and the more stringent criteria applied.</p>
<p>Technology-Based Limitations: As outlined in 40 CFR Part 133:</p> <p>The regulations found at 40 CFR §133 require that POTWs achieve specified treatment standards for BOD, TSS, and pH based on the type of treatment technology available. Therefore, technology-based effluent limitations (TBELs) have been established in the permit for these parameters. Additionally, oil & grease will be monitored with an assessment level based on best professional judgment (BPJ). The average monthly assessment level of 10 mg/L and daily maximum of 15 mg/L are commonly accepted values that can be achieved by properly operated and maintained WWTPs. This level is also considered protective of the narrative standard at A.A.C. R18-11-108(B).</p>
<p>Water Quality-Based Effluent Limitations:</p>

Per 40 CFR 122.44(d)(1)(ii), (iii) and (iv), discharge limits must be included in the permit for parameters with “reasonable potential” (RP), that is, those known to be or expected to be present in the effluent at a level that could potentially cause any applicable numeric water quality standard to be exceeded. Numeric water quality standards are outlined in A.A.C. R18-11-109 and Appendix A. RP refers to an analysis, based on the statistical calculations using the data submitted or consideration of other factors, to determine whether the discharge may exceed the Water Quality Standards. The procedures used to determine RP are outlined in the *Technical Support Document for Water Quality-based Toxics Control (TSD)* (EPA/505/2-90-001). In most cases, the highest reported value for a parameter is multiplied by a factor (determined from the variability of the data and number of samples) to determine a “highest estimated value.” This value is then compared to the lowest applicable Water Quality Standard for the receiving water. If the value is greater than the standard, RP exists and a water quality-based effluent limitation (WQBEL) is required in the permit for that parameter. RP may also be determined from BPJ based on knowledge of the treatment facilities and other factors. The basis for the RP determination for each parameter with a WQBEL is shown in the table below.

It is assumed that RP exists for exceedance of water quality criteria for the pollutants *E. coli* and, if chlorine or bromine is used in the treatment process, total residual chlorine (TRC). These parameters have been shown through extensive monitoring of WWTPs to fluctuate greatly and thus are not conducive to exclusion from limitation due to a lack of RP. Therefore, the permit contains WQBELs for *E. coli* and TRC.

The proposed permit limits were established using a methodology developed by EPA. Long Term Averages (LTA) were calculated for each designated use and the lowest LTA was used to calculate the average monthly limit (AML) and maximum daily limit (MDL) necessary to protect all uses. This methodology is described in Chapter 5 of the *TSD*, and considers water quality criteria, effluent variability, and the number of observations taken to determine compliance with prescribed limits. Limits based on A&W criteria were developed using the “two-value steady state wasteload allocation” described on page 99 of the *TSD*. When the limit is based on human health criteria, the monthly average was set at the level of the applicable standard and a daily maximum limit was determined as specified in Sections 5.4.4 and 5.5.3 of the *TSD*.

Mixing Zone

Arizona water quality rules require that water quality standards be achieved without mixing zones unless the permittee applies and is approved for a mixing zone. Since the receiving stream for this discharge is ephemeral prior to the discharge, no water is available for a mixing zone and all water quality criteria are applied at end-of pipe. This means that the effluent concentration must meet stream standards.

Assessment Levels (ALs)

ALs are listed in Part I.B of the permit. An AL differs from a discharge limit in that an exceedance of an AL is not a permit violation. Instead, ALs serve as triggers, alerting the permitting authority when there is cause for re-evaluation of RP for exceeding a water quality standard, which may result in new permit limitations. The AL numeric values also serve to advise the permittee of the analytical sensitivity needed for meaningful data collection. Trace substance monitoring is required when there is uncertain RP (based on non-detect values or limited datasets) or a need to collect additional data or monitor treatment efficacy on some minimal basis. A reopener clause is included in the permit should future monitoring data indicate water quality standards are being exceeded.

The requirement to monitor for these parameters is included in the permit according to A.A.C. R18-11-104(C) and Appendix A. Except for oil and grease, ALs listed for each parameter were calculated in the same manner that a limit would have been calculated (see Water Quality-Based Effluent Limitations above). The ALs for oil and grease were determined based on BPJ as described above.

Ammonia water quality criteria vary based on the effluent pH and temperature at the time of effluent sampling. As a result, no single ammonia concentration can be included as an assessment level. To overcome this, an Ammonia Impact Ratio (AIR) of 1 for the monthly average and a value of 2 for the maximum daily have been established as the assessment levels for ammonia. The AIR is calculated by dividing the ammonia concentration in the effluent by the

applicable ammonia standard based on the effluent pH and temperature at the time of sampling. AIR values will be reported on DMRs and on the Ammonia Data Log which is included as Appendix C in the permit.

Hardness

The permittee is required to sample hardness as CaCO₃ at the same time the trace metals are sampled because the water quality standards for some metals are calculated using the water hardness values. The hardness value of 111.9 mg/L (the average hardness of the effluent as supplied in the application) was used to calculate the applicable water quality standards and any assessment levels or limits for the hardness dependent metals (cadmium, chromium III, copper, lead, nickel, silver and zinc).

Whole Effluent Toxicity (WET)

WET testing is required in the permit (Parts I.C and IV) to evaluate the discharge according to the narrative toxic standard in A.A.C. R18-11-108(A)(5), as well as whether the discharge has RP for WET per 40 CFR 122.44(d)(iv).

WET testing for acute toxicity is required. The requirement to conduct chronic toxicity testing is contingent upon the frequency or duration of discharges. Since completion of the chronic WET tests for *Ceriodaphnia dubia* and *Pimephales promelas* require the collection of three samples, preferably on days 1, 3, and 5 for daily solution renewal, these chronic tests are not required during any given monitoring period in which the discharge does not occur over seven consecutive calendar days during a monitoring period.

WET testing for acute toxicity shall be conducted using the following two surrogate species:

- *Ceriodaphnia dubia* (water flea) – for evaluating toxicity to invertebrates
- *Pimephales promelas* (fathead minnow) – for evaluating toxicity to vertebrates

ADEQ requires the permittee to analyze WET test data using the Test of Significant Toxicity (TST) statistical approach. This statistical approach is described in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010; TST Implementation Document) and *National Pollutant Discharge Elimination System Test of Significant Toxicity Technical Document* (EPA 833-R-10-004, 2010; TST Technical Document). This statistical approach supports important choices made within a toxicity laboratory which favor quality data and ADEQ’s intended levels for statistical power when true toxicity is statistically determined to be unacceptably high or acceptably low. For both acute and chronic WET test methods, the low-risk Regulatory Management Decision (RMD) threshold is set at a 10 percent mean effect at the Instream-Waste Concentration (IWC). For mean effect levels greater than 10 percent but less than the unacceptable toxicity RMD threshold (20 percent for acute and 25 percent for chronic WET tests), the TST approach will declare the IWC non-toxic depending on within-test variability. The TST maintains ADEQ’s desired low false positive rate for WET methods—the probability of declaring toxicity when true toxicity is acceptably low ≤ 5%—when quality toxicity laboratories conduct toxicity tests (EPA 833-R-10-004, 2010).

ADEQ analyzed the available data and determined that the discharge has indeterminate reasonable potential. This is because no toxicity test result is Fail (1) indicating unacceptable toxicity is not present in the effluent (see Table 1 of this fact sheet and section 1.4 and Appendix E in EPA’s TST Technical Document). However, the minimum number of samples necessary for TST (4 samples) was not met meaning reasonable potential could not be determined. Thus, acute toxicity WQBELs remain required for the permitted discharge (40 CFR § 122.44(d)(1)).

Any failed test during a monitoring period where discharge occurred will trigger follow-up testing to determine if effluent toxicity is persistent. If toxicity above a limit or action level is found in a follow-up test, the permittee will be required to conduct a Toxicity Reduction Evaluation (TRE) based on a TRE Work Plan submitted within 90 days of the permit effective date and possibly a Toxicity Identification Evaluation (TIE) to identify the source of toxicity and decrease toxicity. The conditions described in this paragraph are required to identify and rectify sources of toxicity in

discharges [A.A.C. R18-11-108(A)(5)]. A reopener clause is included in accordance with 40 CFR Parts 122 and 124 and AAC R18-9-B906.

The permit requires composite samples be collected for WET testing. A composite sample type was chosen over the suggested 24-hour composite for WET testing in order to have consistency with the type of sample required for other parameters requiring monitoring in this permit. WET sampling must coincide with testing for all the parameters in Parts I.A and B of the permit when testing of those parameters is required to aid in determining the cause of toxicity if it is detected. Additional procedural requirements for the WET test are included in the permit.

The required WET monitoring frequency for this facility is consistent with the WET testing frequency required for facilities with a similar design flow. The permit requires WET test results to be reported on discharge monitoring reports (DMRs). WET laboratory reports for all WET tests performed must be attached to the corresponding DMR. When a WET limit is exceeded and the facility discharged during the monitoring period when the limit exceedance occurred, the result is subject to the Twenty-four Hour Reporting of Noncompliance requirements, per Part II.C. All action level and limit exceedance results and lab reports shall be emailed to AZPDES@azdeq.gov within five days.

Effluent Characterization (EC)

In addition to monitoring for parameters assigned either a limit or an AL, sampling is required to assess the presence of pollutants in the discharge at certain minimum frequencies for additional suites of parameters, whether the facility is discharging or not. This monitoring is specified in Tables 4.a. through 4.b., *Effluent Characterization Testing*, as follows:

- Table 4.a.—General Chemistry and Microbiology: ammonia, BOD-5, *E. coli*, total residual chlorine (TRC), dissolved oxygen, total Kjeldahl nitrogen (TKN), nitrate/nitrite, oil and grease, pH, phosphorus, temperature, total dissolved solids (TDS), and total suspended solids (TSS)
- Table 4.b.—Selected Metals, Hardness, Cyanide, and WET

NOTE: Some parameters listed in Tables 4.a. and 4.b. are also listed in Tables 1 or 2. In this case, the data from monitoring under Tables 1 or 2 may be used to satisfy the requirements of Tables 4.a. and / or 4.b., provided the specified sample types are the same. In the event the facility does not discharge to a Protected Surface Water during the life of the permit, EC monitoring of representative samples of the effluent is still required.

The purpose of EC monitoring is to characterize the effluent and determine if the parameters of concern are present in the discharge and at what levels. This monitoring will be used to assess RP per 40 CFR 122.44(d)(1)(iii)). EC monitoring is required in accordance with 40 CFR 122.43(a), 40 CFR 122.44(i), and 40 CFR 122.48(b) as well as A.R.S. §49-203(A)(7). If pollutants are noted at levels of concern during the permit term, this permit may also be reopened to add related limits or conditions.

Permit Limitations and Monitoring Requirements

Table 1 summarizes the parameters that are limited in the permit and the rationale for that decision. Also included are the parameters that require monitoring without any limitations or that have not been included in the permit at all and the basis for those decisions. The corresponding monitoring requirements are shown for each parameter. In general, the regulatory basis for monitoring requirements is per 40 CFR §122.44(i) *Monitoring requirements*, and 40 CFR §122.48(b), *Required monitoring*; all of which have been adopted by reference in A.A.C. R18-9-A905, *AZPDES Program Standards*.

Table 1. Permit limitations and monitoring requirements.

Parameter	No. of Samples	Maximum Reported Concentration (1)	RP Multiplier (2)	Critical Concentration (Calculated)	Most Stringent Criterion	Most Stringent Criterion Basis (3)	Does Reasonable Potential Exist?	Proposed Monitoring Requirement/Rationale (4)
Flow	---	---		---	---		---	Discharge flow is to be monitored on a continual basis using a flow meter.
Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS)	BOD: 4 TSS: 4	BOD: 19.7 mg/L TSS: 54 mg/L		N/A	30 mg/L 30-day average 45 mg/L 7-day average	Technology-based limits 40 CFR 133.102	TBELs for BOD and TSS are always applicable to WWTPs.	Monitoring for influent and effluent BOD and TSS to be conducted using composite samples of the influent and the effluent. The sample type required was chosen to be representative of the discharge. The requirement to monitor influent BOD and suspended solids is included to assess compliance with the 85% removal requirement in this permit. At least one sample must coincide with WET testing to aid in the determination of the cause of toxicity, if toxicity is detected.
Chlorine, Total Residual (TRC)	4	9 µg/L		N/A	19 µg/L	A&Wedw acute	RP always expected when chlorine or bromine is used for disinfection.	TRC is to be monitored as a discrete sample and a WQBEL remains in the permit. 40 CFR Part 136 specifies that discrete samples must be collected for chlorine. At least one sample per month must coincide with WET testing to aid in the determination of the cause of toxicity, if toxicity is detected.
Dissolved Oxygen	4	5.2 mg/L	N/A	N/A	The percent saturation of dissolved oxygen is equal to or greater than 90 percent, or single sample minimum concentration of 3 mg/L from 3 hours after sunrise to sunset and 1 mg/L from sunset to 3 hours after sunrise	A&Wedw	No RP	Monitoring is required as a discrete sample for effluent characterization.
<i>E. coli</i>	4	>2419.6		N/A	30-day geometric mean: 126 cfu /100 mL (4 sample minimum) Statistical threshold value: 576 cfu /100 mL	PBC	RP always expected for WWTPs. See explanation above.	<i>E. coli</i> is to be monitored as a discrete sample and a WQBEL remains in the permit.

Table 1. Permit limitations and monitoring requirements.

Parameter	No. of Samples	Maximum Reported Concentration (1)	RP Multiplier (2)	Critical Concentration (Calculated)	Most Stringent Criterion	Most Stringent Criterion Basis (3)	Does Reasonable Potential Exist?	Proposed Monitoring Requirement/Rationale (4)
pH	4	7.2		N/A	Minimum: 6.5 Maximum: 9.0 A.A.C. R18-11-109(B)	A&Wedw and PBC	WQBEL or TBEL is always applicable to WWTPs.	pH is to be monitored using a discrete sample of the effluent and a WQBEL is set. 40 CFR Part 136 specifies that grab samples must be collected for pH. At least one sample must coincide with WET testing to aid in the determination of the cause of toxicity if toxicity is detected. pH sampling must also coincide with ammonia sampling when required (4).
Temperature: Oct-Mar April-Sept	4 4	20°C 20.1°C		N/A	R18-11-109C the discharge shall not cause an increase in the ambient water temperature. no more than 3.0°C	A&Wedw	N/A	Temperature of the effluent is to be monitored for effluent characterization by discrete sample. 40 CFR Part 136 specifies that discrete samples must be collected for temperature. Temperature sampling must also coincide with ammonia sampling when required (5).
Total Dissolved Solids (TDS)	4	1180 mg/L		N/A	No applicable standard	N/A	N/A	Monitoring required for effluent characterization.
Ammonia	4	3.29 mg/L AIR: 0.07 (5)		N/A	Standard varies with temperature and pH	A&Wedw acute	RP Indeterminate (6)	Ammonia is to be monitored by discrete sample and a WQBEL in the form of an ammonia impact ratio (AIR) of 1 is set in the permit (4). An ammonia data log with concurrent pH and temperature monitoring is also required. One sample must coincide with WET sampling to aid in the determination of the cause of toxicity, if toxicity is detected.
Nutrients: Nitrate + Nitrite Total Phosphorus	N: 4 P: 4	N: 57 mg/L P: 9.3 mg/L	N/A	N/A	No applicable standards	N/A	N/A	Monitoring required for effluent characterization.
Oil & Grease	4	4.4 mg/L	N/A	N/A	BPJ Technology-Based Level of 10 mg/L monthly average and 15 mg/L daily maximum	N/A	RP Indeterminate (6)	Monitoring required and an assessment remains in the permit.
Hardness	4	127 mg/L	N/A	N/A	No applicable standard. Hardness is used to determine standards for specific metal parameters.	N/A	N/A	A&W standards for cadmium, chromium III, copper, lead, nickel, silver and zinc used for RP determinations were based on the average effluent hardness concentration of 111.9.

Table 1. Permit limitations and monitoring requirements.


Parameter	No. of Samples	Maximum Reported Concentration (1)	RP Multiplier (2)	Critical Concentration (Calculated)	Most Stringent Criterion	Most Stringent Criterion Basis (3)	Does Reasonable Potential Exist?	Proposed Monitoring Requirement/Rationale (4)
Antimony	4	0.25 µg/L	4.74	1.18 µg/L	747 µg/L	PBC	No RP	Monitoring required for effluent characterization.
Arsenic	4	0.35 µg/L	4.74	1.66 µg/L	280 µg/L	PBC	No RP	Monitoring required for effluent characterization.
Beryllium	4	<1 µg/L	4.74	N/A	65 µg/L	A&Wedw acute	No RP	Monitoring required for effluent characterization.
Cadmium (7)	4	<1 µg/L	4.74	N/A	4.82 µg/L	A&Wedw acute	No RP	Monitoring required for effluent characterization.
Chromium VI	0	No Data			16 µg/L	A&Wedw acute	No RP (Based on Total Chromium Data)	Monitoring required for effluent characterization.
Chromium (Total)	4	2.31 µg/L	4.74	10.94 µg/L	No applicable standard	No applicable standard	No RP	Monitoring required as an indicator parameter for Chromium VI.
Copper (7)	4	113 µg/L	4.74	535.17 µg/L	14.94 µg/L	A&Wedw acute	RP Exists	Monitoring is required and a WQBEL remains.
Cyanide	4	46.5 µg/L	4.74	220.23 µg/L	41 µg/L	A&Wedw acute	RP Exists	Monitoring is required and a WQBEL remains.
Fluoride	0	No Data			140 mg/L	PBC	RP Indeterminate (No data)	Monitoring required for effluent characterization.
Iron	4	465 µg/L	4.74	2202.25 µg/L	No applicable standard	No applicable standard	No RP	Monitoring required and assessment level set.
Lead (7)	4	0.59 µg/L	4.74	2.79 µg/L	15 µg/L	PBC	No RP	Monitoring required for effluent characterization.
Mercury	4	0.00823 µg/L	4.74	0.04 µg/L	2.4 µg/L	A&Wedw acute	No RP	Monitoring required for effluent characterization.
Nickel (7)	4	3.79 µg/L	4.74	17.95 µg/L	514.96 µg/L	A&Wedw acute	No RP	Monitoring required for effluent characterization.
Selenium	4	5.62 µg/L	4.74	26.62 µg/L	4667 µg/L	PBC	No RP	Monitoring required for effluent characterization.
Silver (7)	4	0.83 µg/L	4.74	3.93 µg/L	3.9 µg/L	A&Wedw acute	RP Exists	Monitoring is required and a WQBEL is set.
Thallium	4	<2 µg/L	4.74	N/A	75 µg/L	PBC	No RP	Monitoring required for effluent characterization.
Zinc (7)	4	451 µg/L	4.74	2135.95 µg/L	128.89 µg/L	A&Wedw acute	RP Exists	Monitoring is required and a WQBEL remains.
Whole Effluent Toxicity (WET):								
<i>Ceriodaphnia dubia</i> (Water flea)	1	0 % PE	N/A	N/A	No toxicity (A.A.C. R18-11-108(A) (6))	A&Wedw	RP Indeterminate (6)	Monitoring required and a WQBEL remains.

Table 1. Permit limitations and monitoring requirements.

Parameter	No. of Samples	Maximum Reported Concentration (1)	RP Multiplier (2)	Critical Concentration (Calculated)	Most Stringent Criterion	Most Stringent Criterion Basis (3)	Does Reasonable Potential Exist?	Proposed Monitoring Requirement/Rationale (4)
<i>Pimephales promelas</i> (Fathead minnow)	1	5% PE	N/A	N/A	No toxicity (A.A.C. R18-11-108(A) (6))	A&Wedw	RP Indeterminate (6)	Monitoring required and a WQBEL remains.

Footnotes:

1. Maximum quantified result or maximum reporting limit, whichever is highest. A maximum reporting limit is indicated with less than "<" sign.
2. Reasonable potential (RP) multiplier is a factor applied to the limited dataset reported to ADEQ by the permittee over the current permit term. This factor is a function of the sample count and coefficient of variation for the dataset that is used to approximate the 99th percentile value at a 99% confidence level based on a lognormal distribution.
3. This refers to the applicable designated use that determines the lowest (most protective) water quality standard for each pollutant. Designated use abbreviations are defined in A.A.C. R18-11-101.
4. The monitoring frequencies are as specified in the permit.
5. An AIR will be calculated by dividing effluent ammonia concentration by the applicable standard using the receiving water pH and temperature.
6. Monitoring with ALs or Action Levels always required for WWTPs for these parameters unless RP exists and limits are set.
7. Hardness-dependent metal - the standard for this parameter is based on the average hardness value of the effluent or receiving water as indicated above.



VIII. NARRATIVE WATER QUALITY STANDARDS

Narrative standards applicable to the receiving water are listed in A.A.C. R18-11-108. Part I of the permit contains effluent limitations, other limitations, and monitoring requirements to ensure the discharge is protective of the receiving water, including the narrative standards.

The applicable narrative standards follow below in italics. How ADEQ implements the standard in the permit follows the standard.

A surface water shall not contain pollutants in amounts or combinations that:

Settle to form bottom deposits that inhibit or prohibit the habitation, growth, or propagation of aquatic life;

- The permit requires monitoring with an effluent limitation for Total Suspended Solids (TSS). The effluent limit for TSS ensures the discharge does not cause bottom deposits.

Cause objectionable odor in the area in which the surface water is located;

- The permit contains a narrative requirement that the discharge must not contain objectionable odor.

Cause off-flavor in aquatic organisms; and Are toxic to humans, animals, plants, or other organisms;

- This permit contains requirements for Whole Effluent Toxicity (WET) Testing to ensure the discharge is free from toxicity. The permit also contains effluent characterization monitoring to assess the quality of the effluent and determine what parameters of concern are present in the discharge and at what levels. The permit includes applicable technology-based limitations (TBELs) and water quality based effluent limitations (WQBELs), where reasonable potential exists, to ensure the discharge is non-toxic and safe for aquatic organisms, wildlife, and human health.

Cause the growth of algae or aquatic plants that inhibit or prohibit the habitation, growth, or propagation of other aquatic life or that impair recreational uses;

- The permit contains monitoring requirements for ammonia, nitrate-nitrite, Total Kjeldahl Nitrogen (TKN), and total phosphorus to assess the amount of nutrients present in the discharge. Where reasonable potential exists for these parameters, ADEQ includes effluent limitations for these parameters to prevent the growth of algae and other aquatic plants that may inhibit or prohibit the habitation, growth, or propagation of other aquatic life or impair recreational uses.

Change the color of the surface water from natural background levels of color.

- The permit contains a narrative requirement that the discharge must not contain unnatural color.

A surface water shall not contain oil, grease, or any other pollutant that floats as debris, foam, or scum; or that causes a film or iridescent appearance on the surface of the water; or that causes a deposit on a shoreline, bank, or aquatic vegetation.

- The permit contains a narrative requirement that the discharge shall be free from oil, grease and other pollutants that float as debris, foam, or scum; and a film or iridescent appearance.

A surface water shall not contain a discharge of suspended solids in quantities or concentrations that interfere with the treatment processes at the nearest downstream potable water treatment plant or substantially increase the cost of handling solids produced at the nearest downstream potable water treatment plant.

- The permit contains a monitoring with an effluent limitation for Total Suspended Solids (TSS). The effluent limit for TSS will ensure the discharge does not contain suspended solids in quantities or concentrations that would interfere with or increase the cost to the nearest downstream potable water treatment plant.

A surface water shall not contain solid waste such as refuse, rubbish, demolition or construction debris, trash, garbage, motor vehicles, appliances, or tires.

- The permit contains a narrative requirement that the discharge must not contain refuse, rubbish, demolition or construction debris, trash, or garbage. Motor vehicles, appliances, or tires are not expected to be present in the discharge.

IX. MONITORING AND REPORTING REQUIREMENTS (Part II of Permit)

Section 308 of the Clean Water Act and 40 CFR Part 122.44(i) require that monitoring be included in permits to determine compliance with effluent limitations. Additionally, monitoring may be required to gather data for future effluent limitations or to monitor effluent impacts on receiving water quality.

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility’s performance. Monitoring frequencies for some parameters may be reduced in subsequent permits if all monitoring requirements have been met and the limits or ALs for those parameters have not been exceeded during the first permit term.

For the purposes of this permit, a “composite” sample has been defined as a flow-proportioned mixture of two or more discrete samples (aliquots) obtained at over a period of 1.5 to 2 hours while effluent is being pumped to the spray field. The volume of each aliquot shall be directly proportional to the discharge flow rate at the time of sampling. Samples are to be taken from a tap on the booster station tank that feeds the spray field.

These criteria for composite sampling are included in order to obtain samples that are representative of the discharge given the potential variability in the duration, frequency and magnitude of discharges from this facility. Information in the application indicates that the facility has not discharged since 2002.

Discrete (i.e., grab) samples are specified in the permit for parameters that for varying reasons are not amenable to compositing.

Monitoring locations are specified in the permit (Part I.A and Part II.A) in order to ensure that representative samples of the influent and effluent are consistently obtained.

The requirements in the permit pertaining to Part II, Monitoring and Reporting, are included to ensure that the monitoring data submitted under this permit is accurate in accordance with 40 CFR 122.41(j). The permittee has the responsibility to determine that all data collected for purposes of this permit meet the requirements specified in this permit and is collected, analyzed, and properly reported to ADEQ.

The permit (Part II.A.3) requires the permittee to keep a Quality Assurance (QA) manual at the facility, describing sample collection and analysis processes; the required elements of the QA manual are outlined.

Reporting requirements for monitoring results are detailed in Part II, Section B of the permit, including completion and submittal of Discharge Monitoring Reports (DMRs), Ammonia Data Logs, and AZPDES Flow Record forms.

The permittee is responsible for conducting all required monitoring and reporting the results to ADEQ on DMRs or as otherwise specified in the permit.

Electronic Reporting

The US EPA has published a final regulation that requires electronic reporting and sharing of Clean Water Act National Pollutant Discharge Elimination System (NPDES) program information instead of the current paper-based reporting (Federal Register, Vol. 80, No. 204, October 22, 2015). Beginning December 21, 2016 (one year after the effective date of the regulation), the Federal rule required permittees to make electronic submittals of any monitoring reports and

forms called for in their permits. ADEQ has created an online portal called myDEQ that allows users to submit their discharge monitoring reports and other applicable reports required in the permit.

The permit also requires annual submittal of an Ammonia Data Log that records the results for temperature, pH, and ammonia samples and date of sampling (Part II.B.5). Because the ammonia standards in 18 A.A.C. 11, Article 1, Appendix A are contingent upon the pH and temperature at the time of sampling for ammonia, the permittee must determine the applicable ammonia standard using the ammonia criteria table(s) and calculate the Ammonia Impact Ratio for that ammonia sample result. The AIR is recorded on the DMR.

Requirements for retention of monitoring records are detailed in Part II.D.1 of the permit.

X. BIOSOLIDS REQUIREMENTS (Part III in Permit)

Standard requirements for the monitoring, reporting, record keeping, and handling of biosolids, as well as minimum treatment requirements for biosolids according to 40 CFR Part 503 are incorporated in the permit.

XI. SPECIAL CONDITIONS (Part V in Permit)

Operation

This permit condition requires the permittee to ensure that the WWTP has an operator who is certified at the appropriate level for the facility, in accordance with A.A.C. R18-5-104 through -114. The required certification level for the WWTP operator is based on the class (Wastewater Treatment Plant) and grade of the facility, which is determined by population served, level of treatment, and other factors.

Permit Reopener

This permit may be modified based on newly available information; to add conditions or limits to address demonstrated effluent toxicity; to implement any EPA-approved new Arizona water quality standard; or to re-evaluate reasonable potential (RP), if assessment levels in this permit are exceeded [A.A.C. R18-9-B906 and 40 CFR Part 122.62 (a) and (b)].

XII. ANTIDegradation

Antidegradation rules have been established under A.A.C. R18-11-107 to ensure that existing surface water quality is maintained and protected. The discharge from the Mt. Lemmon Wastewater Reclamation Facility (WRF) will be to an unnamed tributary and Alder Wash that flows to the San Pedro River

Effluent quality limitations and monitoring requirements have been established under the proposed permit to ensure that the discharge will meet the applicable water quality standards. As long as the permittee maintains consistent compliance with these provisions, the designated uses of the receiving water will be presumed protected, and the facility will be deemed to meet currently applicable antidegradation requirements under A.A.C. R18-11-107.

XIII. STANDARD CONDITIONS

Conditions applicable to all NPDES permits in accordance with 40 CFR, Part 122 are attached as an appendix to this permit.

XIV. ADMINISTRATIVE INFORMATION

Public Notice (A.A.C. R18-9-A907)

The public notice is the vehicle for informing all interested parties and members of the general public of the contents of a draft AZPDES permit or other significant action with respect to an AZPDES permit or application. The basic intent of this requirement is to ensure that all interested parties have an opportunity to comment on significant actions of the permitting agency with respect to a permit application or permit. This permit will be public noticed on ADEQ’s website or in a local newspaper after a pre-notice review by the applicant and other affected agencies.

Public Comment Period (A.A.C. R18-9-A908)

Rules require that permits be public noticed on ADEQ’s website or in a newspaper of general circulation within the area affected by the facility or activity and provide a minimum of 30 calendar days for interested parties to respond in writing to ADEQ. After the closing of the public comment period, ADEQ is required to respond to all significant comments at the time a final permit decision is reached or at the same time a final permit is actually issued.

Public Hearing (A.A.C R18-9-A908(B))

A public hearing may be requested in writing by any interested party. The request should state the nature of the issues proposed to be raised during the hearing. A public hearing will be held if the Director determines there is a significant amount of interest expressed during the 30-day public comment period, or if significant new issues arise that were not considered during the permitting process.

EPA Review (A.A.C. R18-9-A908(C))

A copy of this permit and any revisions made to this draft as a result of public comments received will be sent to EPA Region 9 for review. If EPA objects to a provision of the draft, ADEQ will not issue the permit until the objection is resolved.

XV. ADDITIONAL INFORMATION

Additional information relating to this proposed permit may be obtained from:

Arizona Department of Environmental Quality
Water Quality Division – Surface Water Permits Unit
Attn: Benjamin Karls
1110 West Washington Street
Phoenix, Arizona 85007

Or by contacting Benjamin Karls at (520) 628 – 6351 or by e-mail at Karls.benjamin@azdeq.gov.

XVI. INFORMATION SOURCES

While developing effluent limitations, monitoring requirements, and special conditions for the permit, the following information sources were used:

1. AZPDES Permit Application Form(s) 2A and 2S, received March 3, 2026, along with supporting data, facility diagram, and maps submitted by the applicant with the application forms.
2. Supplemental information to the application received by ADEQ on March 12, 2026.
3. ADEQ files on Mt. Lemmon WRP.

4. ADEQ Geographic Information System (GIS) Website.
5. Arizona Administrative Code (AAC) Title 18, Chapter 11, Article 1, *Water Quality Standards for Surface Waters*, adopted December 31, 2016.
6. A.A.C. Title 18, Chapter 9, Article 9. *Arizona Pollutant Discharge Elimination System* rules.
7. Code of Federal Regulations (CFR) Title 40:
 - Part 122, *EPA Administered Permit Programs: The National Pollutant Discharge Elimination System*.
 - Part 124, *Procedures for Decision Making*.
 - Part 133. *Secondary Treatment Regulation*.
 - Part 503. *Standards for the Use or Disposal of Sewage Sludge*.
8. EPA Technical Support Document for Water Quality-based Toxics Control (EPA-505-2-90-001, 1991).
9. U.S. EPA NPDES Permit Writers' Manual, September 2010.
10. The Metals Translator: Guidance for Calculating a Total Recoverable Permit Limit from a Dissolved Criterion, US EPA (EPA-823-B-96-007, 1996).
11. National Pollutant Discharge Elimination System Whole Effluent Toxicity Permit Writers' Manual, U.S. EPA (EPA-833-B-24-001).
12. *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA-821-R-02-012, 2002).
13. *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA-821-R-02-013, 2002).
14. National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document, U.S. EPA (EPA-833-R-10-003, 2010).
15. *Method Guidance and recommendations for Whole Effluent Toxicity (WET) Testing (40 CFR Part 136)* (EPA-821-B-00-004, 2000).
16. National Pollutant Discharge Elimination System Test of Significant Toxicity Technical Document, U.S. EPA (EPA-833-R-10-004, 2010).