

## ARIZONA POLLUTANT DISCHARGE ELIMINATION SYSTEM (AZPDES)

This document gives pertinent information concerning the reissuance of the AZPDES permit listed below. This facility is a wastewater treatment plant (WWTP) with a design capacity of 0.75 million gallons per day (mgd) and is considered to be a minor facility under the NPDES program. The effluent limitations contained in this permit will maintain the Water Quality Standards listed in Arizona Administrative Code (A.A.C.) R18-11-101 *et seq.* This permit is proposed to be issued for a period of 5 years.

<b>I. PERMITTEE INFORMATION</b>	
Permittee's Name:	Town of Superior
Permittee's Mailing Address:	734 South Main Street Superior, AZ 85273
Facility Name:	Town of Superior Wastewater Treatment Plant (WWTP)
Facility Address or Location:	101 Airport Road Superior, AZ 85273
County:	Pinal
Contact Person(s): Phone/e-mail address	Robert Hanus, Operator (602) 327-3460/rhanus@azwastewater.com
AZPDES Permit Number:	AZ021199
Inventory Number:	100687
LTF Number:	96789

<b>II. STATUS OF PERMIT(S)</b>	
AZPDES permit applied for:	Renewal
Date application received:	November 7, 2022
Date application was determined administratively complete:	November 15, 2022
Previous permit expiration date:	May 7, 2023

### **208 Consistency:**

In accordance with A.A.C. R18-9-A903(6), a permit cannot be issued for any discharge inconsistent with a plan or plan amendment approved under section 208(b) of the Clean Water Act.

Due to the new outfall, a 208 Plan Consistency Review was required; the facility was determined to be consistent with the Regional Water Quality Management Plan.

Town of Superior has the following permits issued by ADEQ applicable to the Town of Superior WWTP:		
<b>Type of Permit</b>		
Aquifer Protection Permit (APP)	P100687	Regulates discharges to the local aquifer
Reuse Permit	R105353	Regulates the practice of reusing treated wastewater for beneficial purposes

<b>III. GENERAL FACILITY INFORMATION</b>	
Type of Facility:	Publicly owned treatment works (POTW)
Facility Location Description:	1/4 mile southeast of the Superior Municipal Airport
Permitted Design Flow:	0.75 mgd
Treatment Level (WWTP):	Tertiary
Treatment Processes:	<p>Raw wastewater enters the WWTP through an 18-inch diameter pipe. It flows through a coarse screen where large floating debris is removed. It then passes through a comminutor where any remaining debris is shredded. The raw wastewater is metered as it flows from the comminutor to the raw sewage pump station where is sent to the aeration tank for treatment.</p> <p>At the aeration tank, the flow is directed to the first aeration compartment. In the aeration compartment, the raw sewage is mixed with activated sludge from the reaeration compartment. This mixture then flows to the clarifier for separation. The supernatant then flows out to a sand filter. It is then chlorinated and dechlorinated before being sent for reuse or discharged.</p>
Sludge Handling and Disposal:	Solids are thickened in a digester, conditioned with polymer, and pumped out to drying beds. Dried sludge is hauled to a landfill for disposal.
Nature of Facility Discharge:	Domestic wastewater from residential sources, commercial sources, and one industrial source.
Total Number of Significant Industrial Users (SIUs):	One: OMYA Arizona Inc.
Average Flow Per Discharge:	0.170 mgd.
Service Area:	Town of Superior
Service Population:	2,700
Reuse / Irrigation or other disposal method(s):	There are 12 sites through the Town of Superior where effluent from the Town of Superior WWTP is reused for landscape irrigation.
Continuous or Intermittent Discharge:	Continuous

OMYA Arizona Inc. is a calcium carbonate grinding and packing plant that produces industrial, food and pharmaceutical grade calcium carbonate products. The Town of Superior conducts and reports quarterly monitoring at the end of the OMYA treatment process but prior to discharge to the Town of Superior WWTP.

**IV. RECEIVING WATER**

The State of Arizona has adopted water quality standards to protect the designated uses of its surface waters. Streams have been divided into segments and designated uses assigned to these segments. The water quality standards vary by designated use depending on the level of protection required to maintain that use.

Receiving Water (Federal):	<p>The Water of the U.S. Protected Surface Water (WOTUS PSW) for Outfall 001 is unnamed wash, which is a surface water that is not listed in A.A.C. R18-11 Appendix B, but is a tributary to a listed surface water: Queen Creek (EDW), Below Town of Superior WWTP outfall to confluence with Potts Canyon.</p> <p>The Water of the U.S. Protected Surface Water (WOTUS PSW) for Outfall 002 is Queen Creek, Headwaters to the Town of Superior WWTP outfall at 33°16'33"/111°07'44".</p>
----------------------------	--

River Basin:	Middle Gila River Basin
--------------	-------------------------

Outfall Location(s):	<p>Outfall 001: Township 2S, Range 12E, Section 4 Latitude 33° 16' 50.1" N, Longitude 111°, 07' 29.1" W</p> <p>Outfall 002: Township 2S, Range 12E, Section 3 Latitude 33° 18' 09" N, Longitude 111° 05' 09" W</p>
----------------------	--

Designated uses for the receiving water listed above:	<p>Outfall 001:</p> <p>The receiving water is not listed in A.A.C. R18-11 Appendix B, however the wash is a tributary to Queen Creek. Therefore, the designated uses will be applied to the receiving water according to A.A.C. R18-11-105:</p> <p>Aquatic and Wildlife ephemeral (A&amp;We) Partial Body Contact (PBC)</p> <p>Outfall 002:</p> <p>Aquatic and Wildlife warm water (A&amp;Ww) Partial Body Contact (PBC) Agricultural Livestock watering (AgL)</p>
---	--

Per A.A.C. R18-11-113(D), the water quality standards that apply to effluent-dependent waters (EDWs) will be applied to derive discharge limitations for any point source discharge of wastewater to an ephemeral water. The unnamed wash to which Outfall 001 discharges in an ephemeral water. The AZPDES permit includes discharge limitations and monitoring requirements for Outfall 001 designed to achieve compliance with A&Wedw standards.

Therefore, the following uses are being applied to the receiving water for Outfall 001:

- Aquatic and Wildlife effluent dependent water (A&Wedw)
- Partial Body Contact (PBC)

Designated uses for downstream receiving water:

The Town of Superior WWTP discharges to an unnamed tributary of Queen Creek via Outfall 001. The distance from Outfall 001 to Queen Creek is approximately 0.4 miles. A Discharge Distance Determination (3D) Analysis was completed to determine the run-out distance of the discharge from Outfall 001. The 3D Analysis utilized the design capacity of the WWTP (0.75 MGD). Watershed characteristics were obtained from the U.S. Geological Survey StreamStats application. The 3D Analysis determined the discharge from Outfall 001 had the potential to reach Queen Creek. Therefore, downstream designated uses were considered in the determination of effluent limitations for discharges from Outfall 001. The designated uses of Queen Creek from below Town of Superior WWTP outfall to confluence with Potts Canyon are:

- Aquatic and Wildlife effluent dependent water (A&Wedw)
- Partial Body Contact (PBC)

The designated uses of Queen Creek are the same as to the designated uses of the tributary to which Outfall 001 discharges; therefore, no adjustments were made to designated used to determine permit limits for Outfall 001 based on the downstream receiving water. These permit limits are protective of Queen Creek.

Is the receiving water on the 303(d) list?

Queen Creek from Headwaters to Superior WWTP discharge is impaired for copper (2002) and lead (2010). Queen Creek from Superior WWTP discharge to Potts Canyon is impaired for copper (2004). A TMDL is being developed for Queen Creek.

Given the uses stated above, the applicable narrative water quality standards are described in A.A.C. R18-11-108, and the applicable numeric water quality standards are listed in A.A.C. R18-11-109 and in Appendix A thereof. There are two standards for the Aquatic and Wildlife uses, acute and chronic. In developing AZPDES permits, the standards for all applicable designated uses are compared and limits that will protect for all applicable designated uses are developed based on the standards.

#### V. DESCRIPTION OF DISCHARGE

Because the facility is in operation and discharges have occurred, effluent monitoring data are available. The following is the measured effluent quality reported in the application.

Parameters	Units	Maximum Daily Discharge Concentration
Biochemical Oxygen Demand (BOD)	mg/L	6
Total Suspended Solids (TSS)	mg/L	257
Total Kjeldahl Nitrogen (TKN)	mg/L	1.09
<i>E. coli</i>	mpn/100 mL	18
Facility Design Removal Rates:		BOD 90 % TSS 90 % N 90 %

<b>VI. STATUS OF COMPLIANCE WITH THE EXISTING AZPDES PERMIT</b>	
Date of Most Recent Inspection:	December 1, 2020. ADEQ issued a NOC as a result of this inspection because Town of Superior did not possess an effluent flow meter to monitor discharges from Outfall 001. Town of Superior installed an effluent flow meter and the NOC was closed on April 22, 2021.
Discharge Monitoring Reports (DMR) Reviewed:	May 2018 through October 2022
Lab Reports Reviewed:	February 2019 through October 2022
DMR Exceedances:	Total Suspended Solids (February 2022), Cyanide (1st Quarter 2020, 2nd Quarter 2020, 4th Quarter 2021, 2nd Quarter 2022), Copper (3rd Quarter 2018, 1st Quarter 2022, 3rd Quarter 2022). Action Level exceedance for Pseudokirchneriella subcapitata (Green algae) (Annual 2021).
NOVs Issued:	None
NOVs Closed:	N/A
Formal Enforcement Action(s):	A consent order was issued on February 13, 2018 for intermittent exceedances of the permit limit for copper. On November 8, 2018, ADEQ conducted side-by-side sampling with operators from the Town of Superior WWTP; ADEQ observed improper sampling techniques being used by the Town of Superior that had the potential to cross-contaminated samples. ADEQ provided recommendations for the Town of Superior to improve its sampling procedures. Town of Superior revised their sampling plan and provided employees with training regarding sampling technique. Subsequent samples in December 2018 and February 2019 were non-detects for copper and the compliance order was terminated in April 2019.

<b>VII. PROPOSED PERMIT CHANGES</b>			
The following table lists the major changes from the previous permit in this permit.			
Parameter	Existing Permit	Proposed permit	Reason for change
Noncompliance Reporting Hotline	(602) 771-2330	Noncompliance resulting in imminent threat to human health or the environment must be reported to (602) 771-2330, while all other noncompliance must be reported to (602) 771-1440.	Routing emergency calls to the emergency hotline, but all other calls to a non-emergency number.
Outfalls	Outfall 001	Outfalls 001 and 002	Town of Superior is adding an additional outfall.

Use of Metal Translators to Calculate Total Recoverable Permit Limits from Dissolved Criteria (Applicable to Cadmium, Chromium VI, Copper, Lead, Mercury, Nickel, Silver, and Zinc).	No metal translators were used. Assumed the ratio of dissolved to total recoverable is 1 to 1 for all metals with water quality criteria expressed as dissolved.	WQBELs and ALs were converted from dissolved to total recoverable using the default metal translators from the EPA's <i>The Metals Translator: Guidance for Calculating A Total Recoverable Permit Limit from A Dissolved Criterion</i> .	New procedure for ADEQ to incorporate default metal translators when calculating total recoverable WQBELs and ALs from dissolved criteria.
Lead and Zinc	Limited	Limit removed	Data submitted indicated no reasonable potential (RP) for an exceedance of a standard.
Cadmium	No limit	Limited	Data submitted indicated reasonable potential (RP) for an exceedance of a standard.
Silver	Effluent characterization monitoring	Assessment level monitoring	RP indeterminate due to a high limit of quantitation (LOQ) for some samples.
Whole Effluent Toxicity (WET) - <i>Pseudokirchneriella subcapitata</i> (Green algae)	Action Level	Limited	Data submitted indicated reasonable potential (RP) for an exceedance of a standard.
Phenol	Monitoring required 1x/permit term for Superior and as part of the 1x/permit term priority pollutant scan for OMYA	Monitoring required 1x/year for Superior WWTP and OMYA	Identified as a constituent of concern for OMYA's discharge
Discharge Flow Records	Not Required	Required	Submittal of discharge flow records is now required to provide data for each outfall. The Town of Superior has been submitting discharge flow records with their DMRs, although not required by their current permit.
Anti-backsliding considerations — "Anti-backsliding" refers to statutory (Section 402(o) of the Clean Water Act) and regulatory (40 CFR 122.44(l)) requirements that prohibit the renewal, reissuance, or modification of an existing NPDES permit that contains effluent limits, permit conditions, or standards that are less stringent than those established in the previous permit. The rules and statutes do identify exceptions to these circumstances where backsliding is acceptable. This permit has been reviewed and drafted with consideration of anti-backsliding concerns.			

Limits for the following parameters have been removed from the permit because evaluation of current data allows the conclusion that no reasonable potential (RP) for an exceedance of a standard exists:

- Lead
- Zinc

This is considered allowable backsliding under 303(d)(4). The effluent limitations in the current permit for these two parameters were based on state standards, the respective receiving waters are in attainment for these parameters, and the revisions are consistent with antidegradation requirements. See Section XII for information regarding antidegradation requirements.

Limits are retained in the permit for parameters where reasonable potential (RP) for an exceedance of a standard continues to exist or is indeterminate. In these cases, limits will be recalculated using the most current Arizona Water Quality Standards (WQS). If less stringent limits result due to a change in the WQS then backsliding is allowed in accordance with 303(d)(4) if the new limits are consistent with antidegradation requirements and the receiving water is in attainment of the new standard; see Section XII for information regarding antidegradation requirements.

No limits are less stringent due to a change in the WQS in this permit.

#### VIII. DETERMINATION OF EFFLUENT LIMITATIONS and ASSESSMENT LEVELS

When determining what parameters need monitoring and/or limits included in the permit, both technology-based and water quality-based criteria were compared and the more stringent criteria applied.

**Technology-based Limitations:** As outlined in 40 CFR Part 133:

The regulations found at 40 CFR §133 require that POTWs achieve specified treatment standards for BOD, TSS, and pH based on the type of treatment technology available. Therefore, technology-based effluent limitations (TBELs) have been established in the permit for these parameters. Additionally, oil & grease will be monitored with an assessment level based on best professional judgment (BPJ). The average monthly assessment level of 10 mg/L and daily maximum of 15 mg/L are commonly accepted values that can be achieved by properly operated and maintained WWTPs. This level is also considered protective of the narrative standard at A.A.C. R18-11-108(B).

**Numeric Water Quality Standards:** As outlined in A.A.C. R18-11-109 and Appendix A:

Per 40 CFR 122.44(d)(1)(ii), (iii) and (iv), discharge limits must be included in the permit for parameters with “reasonable potential” (RP), that is, those known to be or expected to be present in the effluent at a level that could potentially cause any applicable numeric water quality standard to be exceeded. RP refers to an analysis, based on the statistical calculations using the data submitted or consideration of other factors, to determine whether the discharge may exceed the Water Quality Standards. The procedures used to determine RP are outlined in the *Technical Support Document for Water Quality-based Toxics Control (TSD)* (EPA/505/2-90-001). In most cases, the highest reported value for a parameter is multiplied by a factor (determined from the variability of the data and number of samples) to determine a “highest estimated value”. This value is then compared to the lowest applicable Water Quality Standard for the receiving water. If the value is greater than the standard, RP exists and a water quality-based effluent limitation (WQBEL) is required in the permit for that parameter. RP may also be determined from BPJ based on knowledge of the treatment facilities and other factors. The basis for the RP determination for each parameter with a WQBEL is shown in the table below.

It is assumed that RP exists for exceedance of water quality criteria for the pollutants *E. coli* and, if chlorine or bromine is used in the treatment process, total residual chlorine (TRC). These parameters have been shown through extensive monitoring of WWTPs to fluctuate greatly and thus are not conducive to exclusion from limitation due to a lack of RP. Therefore, the permit contains WQBELs for *E. coli* and TRC.

The proposed permit limits were established using a methodology developed by EPA. Long Term Averages (LTA) were calculated for each designated use and the lowest LTA was used to calculate the average monthly limit (AML) and maximum daily limit (MDL) necessary to protect all uses. This methodology takes into account criteria, effluent variability, and the number of observations taken to determine compliance with the limit and is described in Chapter 5 of the TSD. Limits based on A&W criteria were developed using the “two-value steady state wasteload allocation” described on page 99 of the TSD. When the limit is based on human health criteria, the monthly average was set at the level of the applicable standard and a daily maximum limit was determined as specified in Section 5.4.4 of the TSD.

**Mixing Zone**

The limits in this permit were determined without the use of a mixing zone. Arizona state water quality rules require that water quality standards be achieved without mixing zones unless the permittee applies for and is approved for a mixing zone.

For Outfall 001, since the receiving stream for this discharge is ephemeral prior to the discharge, no water is available for a mixing zone and all water quality criteria are applied at end-of pipe. This means that the effluent concentration must meet stream standards

For Outfall 002, since a mixing zone was not applied for or granted, all water quality criteria are applied at end-of-pipe.

**Assessment Levels (ALs)**

ALs are listed in Part I.B of the permit. An AL differs from a discharge limit in that an exceedance of an AL is not a permit violation. Instead, ALs serve as triggers, alerting the permitting authority when there is cause for re-evaluation of RP for exceeding a water quality standard, which may result in new permit limitations. The AL numeric values also serve to advise the permittee of the analytical sensitivity needed for meaningful data collection. Trace substance monitoring is required when there is uncertain RP (based on non-detect values or limited datasets) or a need to collect additional data or monitor treatment efficacy on some minimal basis. A reopener clause is included in the permit should future monitoring data indicate water quality standards are being exceeded.

The requirement to monitor for these parameters is included in the permit according to A.A.C. R18-11-104(C) and Appendix A. Except for oil and grease, ALs listed for each parameter were calculated in the same manner that a limit would have been calculated (see Numeric Water Quality Standards Section above). The ALs for oil and grease were determined based on BPJ as described above.

Ammonia water quality criteria vary based on the effluent (for Outfall 001) or receiving water (for Outfall 002) pH and temperature at the time of effluent sampling. As a result, no single ammonia concentration can be included as a permit limit. To overcome this, an Ammonia Impact Ratio (AIR) of 1 for the monthly average and a value of 2 for the maximum daily limits has been established as the permit assessment levels for ammonia. The AIR is calculated by dividing the ammonia concentration in the effluent by the applicable ammonia standard based on the effluent (for Outfall 001) or receiving water (for Outfall 002) pH and temperature at the time of sampling. AIR values will be reported on DMRs and on the Ammonia Data Log which is included as Appendix B in the permit.

The following trace substances were not included as limits or assessment levels in the permit due to a lack of RP based on best professional judgment (BPJ): barium, nitrates, nitrites, and manganese. The numeric standards for these pollutants are well above what would be expected from a WWTP discharge.

**Hardness**

The permittee is required to sample hardness as CaCO<sub>3</sub> at the same time the trace metals are sampled because the water quality standards for some metals are calculated using the water hardness values.



For Outfall 001, the hardness value of 155 mg/L (the average hardness of the effluent as supplied in lab sheets submitted to ADEQ) was used to calculate the applicable water quality standards and any assessment levels or limits for the hardness dependent metals (cadmium, chromium III, copper, lead, nickel, silver and zinc).

For Outfall 002, since no actual receiving water monitoring data are yet available, a protective default hardness value of 120 mg/L was used to calculate the applicable water quality standards and any assessment levels or limits for the hardness-dependent metals (cadmium, chromium III, copper, lead, nickel, silver, and zinc).

**Whole Effluent Toxicity (WET)**

WET testing is required in the permit (Parts I.C, I.D, and IV) to evaluate the discharge according to the narrative toxic standard in A.A.C. R18-11-108(A)(5), as well as whether the discharge has RP for WET per 40 CFR 122.44(d)(iv).

WET testing for chronic toxicity shall be conducted using the following three surrogate species:

- *Ceriodaphnia dubia* (water flea) – for evaluating toxicity to invertebrates
- *Pimephales promelas* (fathead minnow) – for evaluating toxicity to vertebrates
- *Pseudokirchneriella subcapitata* (formerly known as *Selenastrum capricornutum* or *Raphidocelis subcapitata*) (a green alga) – for evaluating toxicity to plant life

ADEQ does not have a numeric standard for Whole Effluent Toxicity. However, ADEQ adopted the EPA recommended chronic toxicity benchmark of 1.0 Toxic Unit-Chronic (TUC) for a four day exposure period. Using this benchmark, the limitations and/or action levels for WET included in the permit were calculated in accordance with the methods specified in the TSD. The species chosen for WET testing are as recommended in the TSD and in *Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs*.

An exceedance of a limit or action level will trigger follow-up testing to determine if effluent toxicity is persistent. If toxicity above a limit or action level is found in a follow-up test, the permittee will be required to conduct a Toxicity Reduction Evaluation (TRE) and possibly a Toxicity Identification Evaluation (TIE) to identify the source of toxicity and reduce toxicity. These conditions are required to ensure that toxicants are not discharged in amounts that are toxic to organisms [A.A.C. R18-11-108(A)(5)]. A reopener clause is included in accordance with 40 CFR Parts 122 and 124 and AAC R18-9-B906.

The permit requires 8-hour composite samples be collected for WET testing. An 8-hour composite sample type was chosen over the suggested 24-hour composite for WET testing in order to have consistency with the type of sample required for other parameters requiring monitoring in this permit. WET sampling must coincide with testing for all the parameters in Parts I.A and B of the permit, when testing of those parameters is required, to aid in the determination of the cause of toxicity if toxicity is detected. Additional procedural requirements for the WET test are included in the proposed permit.

The required WET monitoring frequency for this facility is consistent with the WET testing frequency required for facilities with a similar design flow. The permit requires WET test results to be reported on discharge monitoring reports and submittal of the full WET lab report to ADEQ.

**Effluent Characterization (EC)**

In addition to monitoring for parameters assigned either a limit or an AL, sampling is required to assess the presence of pollutants in the discharge at certain minimum frequencies for additional suites of parameters, whether the facility is discharging or not. This monitoring is specified in Tables 4.a. through 4.e., *Effluent Characterization Testing*, as follows:

- Table 4.a.—General Chemistry and Microbiology: ammonia, BOD-5, *E. coli*, total residual chlorine (TRC), dissolved oxygen, total Kjeldahl nitrogen (TKN), nitrate/nitrite, oil and grease, pH, phosphorus, temperature, total dissolved solids (TDS), and total suspended solids (TSS)

- Table 4.b. —Selected Metals, Hardness, Cyanide, and WET
- Table 4.c. —Selected Volatile Organic Compounds
- Table 4. d. —Selected Acid-Extractible Compounds
- Table 4. e. —Selected Base-Neutral Compounds

NOTE: Some parameters listed in Tables 4.a. and 4.b. are also listed in Tables 1 or 2. In this case, the data from monitoring under Tables 1 or 2 may be used to satisfy the requirements of Tables 4.a. and / or 4.b., provided the specified sample types are the same. In the event the facility does not discharge to a Protected Surface Water during the life of the permit, EC monitoring of representative samples of the effluent is still required.

The purpose of EC monitoring is to characterize the effluent and determine if the parameters of concern are present in the discharge and at what levels. This monitoring will be used to assess RP per 40 CFR 122.44(d)(1)(iii)). EC monitoring is required in accordance with 40 CFR 122.43(a), 40 CFR 122.44(i), and 40 CFR 122.48(b) as well as A.R.S. §49-203(A)(7). If pollutants are noted at levels of concern during the permit term, this permit may also be reopened to add related limits or conditions.

#### **Permit Limitations and Monitoring Requirements**

Tables 1.a. and 1.b. summarize the parameters that are limited in the permit and the rationale for that decision. Also included are the parameters that require monitoring without any limitations or that have not been included in the permit at all and the basis for those decisions. The corresponding monitoring requirements are shown for each parameter. In general, the regulatory basis for monitoring requirements is per 40 CFR §122.44(i) *Monitoring requirements*, and 40 CFR §122.48(b), *Required monitoring*; all of which have been adopted by reference in A.A.C. R18-9-A905, *AZPDES Program Standards*.

**Table 1.a. Permit limitations and monitoring requirements for Outfall 001.**

Parameter	Lowest Standard/Designated Use	Maximum Reported Daily Value	No. of Samples	Estimated Maximum Value	RP Determination	Proposed Monitoring Requirement/Rationale (1)
Flow	---	---	---	---	---	Discharge flow is to be monitored on a continual basis using a flow meter.
Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) (2)	30 mg/L 30-day average 45 mg/L 7-day average Technology-based limits 40 CFR 133.102	BOD: 6 mg/L TSS: 257 mg/L	BOD: 13 TSS: 13	N/A	TBELs for BOD and TSS are always applicable to WWTPs.	Monitoring for influent and effluent BOD and TSS to be conducted using composite samples of the influent and the effluent. The sample type required was chosen to be representative of the discharge. The requirement to monitor influent BOD and suspended solids is included to assess compliance with the 85% removal requirement in this permit. At least one sample must coincide with WET testing to aid in the determination of the cause of toxicity, if toxicity is detected.
Chlorine, Total Residual (TRC)	11 µg/L A&Wedw chronic	<22 µg/L	365	N/A	RP always expected when chlorine or bromine is used for disinfection.	TRC is to be monitored as a discrete sample and a WQBEL remains in the permit. 40 CFR Part 136 specifies that discrete samples must be collected for chlorine. At least one sample per month must coincide with WET testing to aid in the determination of the cause of toxicity, if toxicity is detected.
<i>E. coli</i>	30-day geometric mean: 126 cfu /100 mL (4 sample minimum) Single sample maximum: 575 cfu /100 mL/ PBC	18 mpn/100 mL	61	N/A	RP always expected for WWTPs. See explanation above.	<i>E. coli</i> is to be monitored as a discrete sample and a WQBEL remains in the permit.
pH (2)	Minimum: 6.5 Maximum: 9.0 A&Wedw and PBC A.A.C. R18-11-109(B)  Minimum: 6.0 Maximum: 9.0 Technology-based limits 40 CFR 133.102	7.6	52	N/A	WQBEL or TBEL is always applicable to WWTPs.	pH is to be monitored using a discrete sample of the effluent and a WQBEL is set. 40 CFR Part 136 specifies that grab samples must be collected for pH. At least one sample must coincide with WET testing to aid in the determination of the cause of toxicity if toxicity is detected. pH sampling must also coincide with ammonia sampling when required.
Temperature	R18-11-109C the discharge shall not cause an increase in the ambient water temperature.  A&Wedw: no more than 3.0°C	30.1°C	52	N/A	N/A	Effluent temperature is to be monitored for effluent characterization by discrete sample. 40 CFR Part 136 specifies that discrete samples must be collected for temperature. Temperature sampling must also coincide with ammonia sampling when required.

**Table 1.a. Permit limitations and monitoring requirements for Outfall 001.**

Parameter	Lowest Standard/Designated Use	Maximum Reported Daily Value	No. of Samples	Estimated Maximum Value	RP Determination	Proposed Monitoring Requirement/Rationale (1)
Total Dissolved Solids (TDS)	No applicable standard	543 mg/L	6	N/A	N/A	Monitoring required for effluent characterization.
Ammonia	Standard varies with temperature and pH	<1.0 mg/L	13	N/A	RP Indeterminate (4)	Ammonia is to be monitored by discrete sample and an assessment level in the form of an ammonia impact ratio (AIR) of 1 is set in the permit (5). An ammonia data log with concurrent pH and temperature monitoring is also required. One sample must coincide with WET sampling to aid in the determination of the cause of toxicity, if toxicity is detected.
Total Kjeldahl Nitrogen (TKN)	No applicable standard	1.09 mg/L	13	N/A	N/A	Monitoring required for effluent characterization.
Nitrate/Nitrite (as N)	No applicable standard	13 mg/L	13	N/A	N/A	Monitoring required for effluent characterization.
Total Phosphorus	No applicable standard	4.7 mg/L	6	N/A	N/A	Monitoring required for effluent characterization.
Oil & Grease	BPJ Technology-Based Level of 10 mg/L monthly average and 15 mg/L daily maximum	<5.00 mg/L	10	N/A	N/A (4)	Monitoring required and an assessment level remains in the permit.
Antimony	600 µg/L A&Wedw chronic	2.2 µg/L	17	7.22 µg/L	No RP	Monitoring required for effluent characterization.
Arsenic	150 µg/L A&Wedw chronic	8.2 µg/L	17	12.19 µg/L	No RP	Monitoring required for effluent characterization.
Beryllium	5.3 µg/L A&Wedw chronic	<2 µg/L	17	N/A	No RP	Monitoring required for effluent characterization.
Cadmium (2)	3.1 µg/L A&Wedw chronic	1 µg/L	17	6.77 µg/L	RP Exists	Monitoring is required and a WQBEL is set.
Chromium (Total)	No applicable standard	8.2 µg/L	17	N/A	N/A	Monitoring required as an indicator parameter for Chromium VI.
Chromium VI	11 µg/L A&Wedw chronic	N/A	0	N/A	No RP (Based on total chromium data)	Monitoring required for effluent characterization.
Copper (2)	13 µg/L A&Wedw chronic	78 µg/L	48	193 µg/L	RP Exists	Monitoring is required and a WQBEL is set.
Cyanide	9.7 µg/L A&Wedw chronic	11 µg/L	23	18 µg/L	RP Exists	Monitoring is required and a WQBEL is set.
Hardness	No applicable standard. Hardness is used to determine standards for specific metal parameters.	190 mg/L	18	N/A	N/A	A&W standards for cadmium, chromium III, copper, lead, nickel, silver and zinc used for RP determinations were based on the average effluent hardness value of 155 mg/L. Monitoring for hardness is required whenever monitoring for hardness dependent metals is required.

**Table 1.a. Permit limitations and monitoring requirements for Outfall 001.**

Parameter	Lowest Standard/Designated Use	Maximum Reported Daily Value	No. of Samples	Estimated Maximum Value	RP Determination	Proposed Monitoring Requirement/Rationale (1)	
Hydrogen sulfide	2 µg/L A&Wedw chronic	<40	14	N/A	RP Indeterminate (High LOQ)	Monitoring is required for sulfides as an indicator parameter for hydrogen sulfide. If sulfides are detected, monitoring for hydrogen sulfide is required for the remainder of the permit term.	
Iron	1,000 ug/L A&Wedw chronic	<50 µg/L	5	N/A	No RP	Monitoring required for effluent characterization.	
Lead (2)	4.0 µg/L A&Wedw chronic	1.2 µg/L	17	2.93 µg/L	No RP	Monitoring required for effluent characterization.	
Mercury	0.01 µg/L A&Wedw chronic	<0.2 µg/L	16	N/A	RP Indeterminate (High LOQ)	Monitoring required and a WQBEL remains in the permit.	
Nickel (2)	75.3 µg/L A&Wedw chronic	<20 µg/L	17	N/A	No RP	Monitoring required for effluent characterization.	
Selenium	2 µg/L A&Wedw chronic	<2 µg/L	17	N/A	RP Indeterminate (High LOQ)	Monitoring required and a WQBEL remains in the permit.	
Silver (2)	6.8 µg/L A&Wedw acute	<10 µg/L	4	N/A	RP Indeterminate (High LOQ)	Monitoring required and an assessment level is set.	
Sulfides	No applicable standard	<40 µg/L	15	N/A	N/A	Indicator parameter for hydrogen sulfide. Monitoring required. If sulfides are detected, monitoring for hydrogen sulfide is required for the remainder of the permit term.	
Thallium	75 µg/L PBC	<0.5 µg/L	17	N/A	No RP	Monitoring required for effluent characterization.	
Zinc (2)	170 µg/L A&Wedw acute and chronic	83 µg/L	15	129 µg/L	No RP	Monitoring required for effluent characterization.	
Whole Effluent Toxicity (WET)	No toxicity (A.A.C. R18-11-108(A) (6))	<i>Pseudo-kirchneriella subcapitata</i> (3)	1.97 TUc	3	N/A	RP Exists	Monitoring required and a WQBEL is set.
		<i>Pimephales promelas</i>	1 TUc	3	N/A	RP Indeterminate (4)	Monitoring required and an action level is set.
		<i>Ceriodaphnia dubia</i>	1 TUc	3	N/A	RP Indeterminate (4)	Monitoring required and an action level is set.

**Footnotes:**

1. The monitoring frequencies are as specified in the permit.
2. Hardness-dependent metal - the standard for this parameter is based on the average hardness value of the effluent or receiving water as indicated above.
3. Formerly known as *Selenastrum capricornutum* or *Raphidocelis subcapitata*.
4. Monitoring with ALs or Action Levels always required for WWTPs for these parameters unless RP exists and limits are set.
5. An AIR will be calculated by dividing effluent ammonia concentration by the applicable standard using the receiving water pH and temperature.

**Table 1.b. Permit limitations and monitoring requirements for Outfall 002.**

Parameter	Lowest Standard/Designated Use	Maximum Reported Daily Value	No. of Samples	Estimated Maximum Value	RP Determination	Proposed Monitoring Requirement/Rationale (1)
Flow	---	---	---	---	---	Discharge flow is to be monitored on a continual basis using a flow meter.
Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) (2)	30 mg/L 30-day average 45 mg/L 7-day average Technology-based limits 40 CFR 133.102	BOD: 6 mg/L TSS: 257 mg/L	BOD: 13 TSS: 13	N/A	TBELs for BOD and TSS are always applicable to WWTPs.	Monitoring for influent and effluent BOD and TSS to be conducted using composite samples of the influent and the effluent. The sample type required was chosen to be representative of the discharge. The requirement to monitor influent BOD and suspended solids is included to assess compliance with the 85% removal requirement in this permit. At least one sample must coincide with WET testing to aid in the determination of the cause of toxicity, if toxicity is detected.
Chlorine, Total Residual (TRC)	11 µg/L A&Ww chronic	<22 µg/L	365	N/A	RP always expected when chlorine or bromine is used for disinfection.	TRC is to be monitored as a discrete sample and a WQBEL remains in the permit. 40 CFR Part 136 specifies that discrete samples must be collected for chlorine. At least one sample per month must coincide with WET testing to aid in the determination of the cause of toxicity, if toxicity is detected.
<i>E. coli</i>	30-day geometric mean: 126 cfu /100 mL (4 sample minimum) Single sample maximum: 575 cfu /100 mL/ PBC	18 mpn/100 mL	61	N/A	RP always expected for WWTPs. See explanation above.	<i>E. coli</i> is to be monitored as a discrete sample and a WQBEL remains in the permit.
pH (2)	Minimum: 6.5 Maximum: 9.0 A&Ww and PBC A.A.C. R18-11-109(B)  Minimum: 6.0 Maximum: 9.0 Technology-based limits 40 CFR 133.102	7.6	52	N/A	WQBEL or TBEL is always applicable to WWTPs.	pH is to be monitored using a discrete sample of the effluent and a WQBEL is set. 40 CFR Part 136 specifies that grab samples must be collected for pH. At least one sample must coincide with WET testing to aid in the determination of the cause of toxicity if toxicity is detected. pH sampling must also coincide with ammonia sampling when required.
Temperature	R18-11-109C the discharge shall not cause an increase in the ambient water temperature.  A&Ww: no more than 3.0°C	30.1°C	52	N/A	N/A	Effluent temperature is to be monitored for effluent characterization by discrete sample. 40 CFR Part 136 specifies that discrete samples must be collected for temperature. Temperature sampling must also coincide with ammonia sampling when required.
Total Dissolved Solids (TDS)	No applicable standard	543 mg/L	6	N/A	N/A	Monitoring required for effluent characterization.

**Table 1.b. Permit limitations and monitoring requirements for Outfall 002.**

Parameter	Lowest Standard/Designated Use	Maximum Reported Daily Value	No. of Samples	Estimated Maximum Value	RP Determination	Proposed Monitoring Requirement/Rationale (1)
Ammonia	Standard varies with temperature and pH	<1.0 mg/L	13	N/A	RP Indeterminate (4)	Ammonia is to be monitored by discrete sample and an assessment level in the form of an ammonia impact ratio (AIR) of 1 is set in the permit (5). An ammonia data log with concurrent pH and temperature monitoring is also required. One sample must coincide with WET sampling to aid in the determination of the cause of toxicity, if toxicity is detected.
Total Kjeldahl Nitrogen (TKN)	No applicable standard	1.09 mg/L	13	N/A	N/A	Monitoring required for effluent characterization.
Nitrate/Nitrite (as N)	No applicable standard	13 mg/L	13	N/A	N/A	Monitoring required for effluent characterization.
Total Phosphorus	No applicable standard	4.7 mg/L	6	N/A	N/A	Monitoring required for effluent characterization.
Oil & Grease	BPJ Technology-Based Level of 10 mg/L monthly average and 15 mg/L daily maximum	<5.00 mg/L	10	N/A	N/A (4)	Monitoring required and an assessment level remains in the permit.
Antimony	30 µg/L A&Ww chronic	2.2 µg/L	17	7.22 µg/L	2.2 µg/L	Monitoring required for effluent characterization.
Arsenic	150 µg/L A&Ww chronic	8.2 µg/L	17	12.19 µg/L	8.2 µg/L	Monitoring required for effluent characterization.
Beryllium	5.3 µg/L A&Ww chronic	<2 µg/L	17	N/A	<2 µg/L	Monitoring required for effluent characterization.
Cadmium (2)	2.6 µg/L A&Ww chronic	1 µg/L	17	6.77 µg/L	1 µg/L	Monitoring is required and a WQBEL is set.
Chromium (Total)	1,000 µg/L AgL	8.2 µg/L	17	N/A	8.2 µg/L	Monitoring required for effluent characterization and as an indicator parameter for Chromium VI.
Chromium VI	11 µg/L A&Ww chronic	N/A	0	N/A	N/A	Monitoring required for effluent characterization.
Copper (2)	10 µg/L A&Ww chronic	78 µg/L	48	193 µg/L	78 µg/L	Monitoring is required and a WQBEL is set.
Cyanide	9.7 µg/L A&Ww chronic	11 µg/L	23	18 µg/L	11 µg/L	Monitoring is required and a WQBEL is set.
Hardness	No applicable standard. Hardness is used to determine standards for specific metal parameters.	190 mg/L	18	N/A	190 mg/L	A&W standards for cadmium, chromium III, copper, lead, nickel, silver and zinc used for RP determinations were based on a default receiving water hardness value of 120 mg/L. Monitoring for hardness is required whenever monitoring for hardness dependent metals is required.

**Table 1.b. Permit limitations and monitoring requirements for Outfall 002.**

Parameter	Lowest Standard/Designated Use	Maximum Reported Daily Value	No. of Samples	Estimated Maximum Value	RP Determination	Proposed Monitoring Requirement/Rationale (1)	
Hydrogen sulfide	2 µg/L A&Ww chronic	<40	14	N/A	<40	Monitoring is required for sulfides as an indicator parameter for hydrogen sulfide. If sulfides are detected, monitoring for hydrogen sulfide is required for the remainder of the permit term.	
Iron	1,000 ug/L A&Ww chronic	<50 µg/L	5	N/A	<50 µg/L	Monitoring required for effluent characterization.	
Lead (2)	3.1 µg/L A&Ww chronic	1.2 µg/L	17	2.93 µg/L	1.2 µg/L	Monitoring required for effluent characterization.	
Mercury	0.01 µg/L A&Ww chronic	<0.2 µg/L	16	N/A	<0.2 µg/L	Monitoring required and a WQBEL remains in the permit.	
Nickel (2)	60.7 µg/L A&Ww chronic	<20 µg/L	17	N/A	<20 µg/L	Monitoring required for effluent characterization.	
Selenium	2 µg/L A&Ww chronic	<2 µg/L	17	N/A	<2 µg/L	Monitoring required and a WQBEL remains in the permit.	
Silver (2)	4.4 µg/L A&Ww acute	<10 µg/L	4	N/A	<10 µg/L	Monitoring required and an assessment level is set.	
Sulfides	No applicable standard	<40 µg/L	15	N/A	<40 µg/L	Indicator parameter for hydrogen sulfide. Monitoring required. If sulfides are detected, monitoring for hydrogen sulfide is required for the remainder of the permit term.	
Thallium	75 µg/L PBC	<0.5 µg/L	17	N/A	<0.5 µg/L	Monitoring required for effluent characterization.	
Zinc (2)	137 µg/L A&Wedw acute and chronic	83 µg/L	15	129 µg/L	83 µg/L	Monitoring required for effluent characterization.	
Whole Effluent Toxicity (WET)	No toxicity (A.A.C. R18-11-108(A) (6)	<i>Pseudo-kirchneriella subcapitata</i> (3)	1.97 TUc	3	N/A	RP Exists	Monitoring required and a WQBEL is set.
		<i>Pimephales promelas</i>	1 TUc	3	N/A	RP Indeterminate (4)	Monitoring required and an action level is set.
		<i>Ceriodaphnia dubia</i>	1 TUc	3	N/A	RP Indeterminate (4)	Monitoring required and an action level is set.

**Footnotes:**

1. The monitoring frequencies are as specified in the permit.
2. Hardness-dependent metal - the standard for this parameter is based on the average hardness value of the effluent or receiving water as indicated above.
3. Formerly known as *Selenastrum capricornutum* or *Raphidocelis subcapitata*.
4. Monitoring with ALs or Action Levels always required for WWTPs for these parameters unless RP exists and limits are set.
5. An AIR will be calculated by dividing effluent ammonia concentration by the applicable standard using the receiving water pH and temperature.



### VIII. NARRATIVE WATER QUALITY STANDARDS

All narrative limitations in A.A.C. R18-11-108 that are applicable to the receiving water are included in Part I, Section E of the permit.

### IX. MONITORING AND REPORTING REQUIREMENTS (Part II of Permit)

Section 308 of the Clean Water Act and 40 CFR Part 122.44(i) require that monitoring be included in permits to determine compliance with effluent limitations. Additionally, monitoring may be required to gather data for future effluent limitations or to monitor effluent impacts on receiving water quality.

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility's performance. Monitoring frequencies for some parameters may be reduced in subsequent permits if all monitoring requirements have been met and the limits or ALs for those parameters have not been exceeded during the first permit term.

For the purposes of this permit, an "8-hour composite" sample has been defined as a flow-proportioned mixture of two or more discrete samples (aliquots) obtained at equal time intervals over an 8-hour period (if only two samples are collected, they should be taken approximately 8 hours apart). The volume of each aliquot shall be directly proportional to the discharge flow rate at the time of sampling.

These criteria for composite sampling are included in order to obtain samples that are representative of the discharge given the potential variability in the duration, frequency and magnitude of discharges from this facility.

Discrete (i.e., grab) samples are specified in the permit for parameters that for varying reasons are not amenable to compositing.

Monitoring locations are specified in the permit (Parts I.A, I.B, and II.A) in order to ensure that representative samples of the influent and effluent are consistently obtained.

The requirements in the permit pertaining to Part II, Monitoring and Reporting, are included to ensure that the monitoring data submitted under this permit is accurate in accordance with 40 CFR 122.41(e). The permittee has the responsibility to determine that all data collected for purposes of this permit meet the requirements specified in this permit and is collected, analyzed, and properly reported to ADEQ.

The permit (Part II.A.3) requires the permittee to keep a Quality Assurance (QA) manual at the facility, describing sample collection and analysis processes; the required elements of the QA manual are outlined.

Reporting requirements for monitoring results are detailed in Part II, Section B of the permit, including completion and submittal of Discharge Monitoring Reports (DMRs), Ammonia Data Logs, and AZPDES Flow Record forms.

The permittee is responsible for conducting all required monitoring and reporting the results to ADEQ on DMRs or as otherwise specified in the permit.

#### **Electronic reporting**

The US EPA has published a final regulation that requires electronic reporting and sharing of Clean Water Act National Pollutant Discharge Elimination System (NPDES) program information instead of the current paper-based reporting (Federal Register, Vol. 80, No. 204, October 22, 2015). Beginning December 21, 2016 (one year after the effective date of the regulation), the Federal rule required permittees to make electronic submittals of any monitoring reports and forms called for in their permits. ADEQ has created an online portal called myDEQ that allows users to submit their discharge monitoring reports and other applicable reports required in the permit.

The permit also requires annual submittal of an Ammonia Data Log that records the results for temperature, pH, and ammonia samples and date of sampling (Part II.B.3). Because the ammonia standards in 18 A.A.C. 11, Article 1, Appendix A are contingent upon the pH and temperature at the time of sampling for ammonia, the permittee must determine the applicable ammonia standard using the ammonia criteria table(s) and calculate the Ammonia Impact Ratio for that ammonia sample result. The AIR is recorded on the DMR.

Requirements for retention of monitoring records are detailed in Part II.C.3 of the permit.

#### **X. BIOSOLIDS REQUIREMENTS (Part III in Permit)**

Standard requirements for the monitoring, reporting, record keeping, and handling of biosolids, as well as minimum treatment requirements for biosolids according to 40 CFR Part 503 are incorporated in the permit.

#### **XI. SPECIAL CONDITIONS (Part V in Permit)**

##### **Operation**

This permit condition requires the permittee to ensure that the WWTP has an operator who is certified at the appropriate level for the facility, in accordance with A.A.C. R18-5-104 through -114. The required certification level for the WWTP operator is based on the class (Wastewater Treatment Plant) and grade of the facility, which is determined by population served, level of treatment, and other factors.

##### **Pretreatment**

The Town of Superior WWTP is considered a minor facility and has one significant industrial user, OMYA. There are no pretreatment conditions, however, monitoring and reporting of the OMYA discharge to the WWTP for BOD, TSS, pH, and metals is required in the permit in Part I.E, Table 5. Monitoring for a full priority pollutant scan (40 CFR 122.21 Appendix D) on wastewater after the last treatment process at OMYA but before discharge to the Town of Superior WWTP is required in year 4 of the permit term in order to identify any potential pollutants of concern.

##### **Permit Reopener**

This permit may be modified based on newly available information; to add conditions or limits to address demonstrated effluent toxicity; to implement any EPA-approved new Arizona water quality standard; or to re-evaluate reasonable potential (RP), if assessment levels in this permit are exceeded [A.A.C. R18-9-B906 and 40 CFR Part 122.62 (a) and (b)].

#### **XII. ANTIDegradation**

Antidegradation rules have been established under A.A.C. R18-11-107 to ensure that existing surface water quality is maintained and protected. The discharge from the Town of Superior WWTP Outfall 001 will be to an effluent-dependent water. Except for flows resulting from rain events, the only water in the wash will be the effluent. Therefore, the discharge and the receiving water will normally be one and the same. The discharge from the Town of Superior WWTP 002 will be to an intermittent water which is subject to Tier 1 antidegradation protection. Effluent quality limitations and monitoring requirements have been established under the proposed permit to ensure that the discharge will meet the applicable water quality standards. As long as the permittee maintains consistent compliance with these provisions, the designated uses of the receiving water will be presumed protected, and the facility will be deemed to meet currently applicable antidegradation requirements under A.A.C. R18-11-107.

### **XIII. STANDARD CONDITIONS**

Conditions applicable to all NPDES permits in accordance with 40 CFR, Part 122 are attached as an appendix to this permit.

### **XIV. ADMINISTRATIVE INFORMATION**

#### **Public Notice (A.A.C. R18-9-A907)**

The public notice is the vehicle for informing all interested parties and members of the general public of the contents of a draft AZPDES permit or other significant action with respect to an AZPDES permit or application. The basic intent of this requirement is to ensure that all interested parties have an opportunity to comment on significant actions of the permitting agency with respect to a permit application or permit. This permit will be public noticed in a local newspaper after a pre-notice review by the applicant and other affected agencies.

#### **Public Comment Period (A.A.C. R18-9-A908)**

Rules require that permits be public noticed in a newspaper of general circulation within the area affected by the facility or activity and provide a minimum of 30 calendar days for interested parties to respond in writing to ADEQ. After the closing of the public comment period, ADEQ is required to respond to all significant comments at the time a final permit decision is reached or at the same time a final permit is actually issued.

#### **Public Hearing (A.A.C R18-9-A908(B))**

A public hearing may be requested in writing by any interested party. The request should state the nature of the issues proposed to be raised during the hearing. A public hearing will be held if the Director determines there is a significant amount of interest expressed during the 30-day public comment period, or if significant new issues arise that were not considered during the permitting process.

#### **EPA Review (A.A.C. R18-9-A908(C))**

A copy of this permit and any revisions made to this draft as a result of public comments received will be sent to EPA Region 9 for review. If EPA objects to a provision of the draft, ADEQ will not issue the permit until the objection is resolved.

### **XV. ADDITIONAL INFORMATION**

Additional information relating to this proposed permit may be obtained from:

Arizona Department of Environmental Quality  
Water Quality Division – Surface Water Permits Unit  
Attn: Rachel Heinz  
1110 West Washington Street  
Phoenix, Arizona 85007

Or by contacting Rachel Heinz at (602) 771 – 0180 or by e-mail at [heinz.rachel@azdeq.gov](mailto:heinz.rachel@azdeq.gov).

## XVI. INFORMATION SOURCES

While developing effluent limitations, monitoring requirements, and special conditions for the permit, the following information sources were used:

1. AZPDES Permit Application Form 2A/2S, received November 7, 2022, along with supporting data, facility diagram, and maps submitted by the applicant with the application forms.
2. Supplemental information to the application received by ADEQ on November 18, 2022 and December 23, 2022.
3. ADEQ files on Town of Superior WWTP.
4. Central Arizona Governments Section 208 Water Quality Management Plan, November 23, 2016.
5. ADEQ Geographic Information System (GIS) Web site.
6. Arizona Administrative Code (AAC) Title 18, Chapter 11, Article 1, *Water Quality Standards for Surface Waters*, adopted December 31, 2016.
7. A.A.C. Title 18, Chapter 9, Article 9. *Arizona Pollutant Discharge Elimination System* rules.
8. Code of Federal Regulations (CFR) Title 40:
  - Part 122, *EPA Administered Permit Programs: The National Pollutant Discharge Elimination System.*
  - Part 124, *Procedures for Decision Making.*
  - Part 133. *Secondary Treatment Regulation.*
  - Part 503. *Standards for the Use or Disposal of Sewage Sludge.*
9. EPA Technical Support Document for Water Quality-based Toxics Control dated March 1991.
10. *Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs*, US EPA, May 31, 1996.
11. *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA /821-R-02-013).
12. U.S. EPA NPDES Permit Writers' Manual, September 2010.