

Weekly SQG Inspection Checklist for Central Accumulation Areas 40 CFR §262.16(b)(2)(iv)

Inspection Information		
Area Being Inspected:		
Date:		
Inspector Printed Name* and Signature:		
Hazardous Waste Containers	Y / N	Corrective Action / Observations
Are the containers properly dated with an accumulation start date within the last 180 days? <i>40 CFR § 262.16(b)(6)(C)</i>		
Are containers clearly marked or labeled with an indication of the hazards of the contents? <i>40 CFR § 262.16(b)(6)(B)</i>		
Are containers clearly labeled "Hazardous Waste"? <i>40 CFR § 262.16(b)(6)(A)</i>		
Are wastes stored in compatible containers? <i>40 CFR § 262.16(b)(2)(ii)</i>		
Are all hazardous waste containers closed and fastened? <i>40 CFR § 262.16(b)(2)(iii)(B)</i>		
Is there evidence of container deterioration or damage? <i>40 CFR § 262.16(b)(2)(i)</i>		
Is there adequate aisle spacing between all containers? <i>40 CFR § 262.(b)(8)(v)</i>		
Are incompatible wastes properly segregated? <i>40 CFR § 262.16(b)(2)(v)</i>		
Are there any signs of leaks or spills? <i>40 CFR §262.16(b)(2)(i)</i>		
Are fire extinguishers in place, clearly visible and charged? <i>40 CFR § 262.16(b)(8)(ii)(C)</i>		
Is emergency contact information and locations of emergency equipment clearly posted? <i>40 CFR § 262.16(b)(9)(ii)</i>		
Is spill response equipment adequate & accessible? <i>40 CFR § 262.16(b)(8)(ii)(C)</i>		
Is there water at adequate volume & pressure available? <i>40 CFR § 262.16(b)(8)(ii)(D)</i>		
Are internal and external communication devices accessible? <i>40 CFR § 262.16(b)(8)(ii)(A-B)</i>		

* Employee conducting weekly CAA inspections should have adequate hazardous waste training.

This checklist is provided as a courtesy of ADEQ and is not intended to cover every hazardous waste container risk that may occur at your facility. ADEQ assumes no liability for the use of this checklist in conjunction with safety efforts at your facility.